

SCHEDULE 1

TARIFF, INDEXATION AND ADJUSTMENT

TABLE OF CONTENTS

| | |
|---|----|
| SCHEDULE 1..... | 1 |
| TARIFF, INDEXATION AND ADJUSTMENT | 1 |
| TABLE OF CONTENTS..... | 1 |
| RT I: GENERAL | 2 |
| 1. INTRODUCTION..... | 2 |
| 2. DEFINITIONS | 3 |
| 3. CONSTRUCTION..... | 8 |
| PART II: TARIFF ACKNOWLEDGEMENT..... | 9 |
| 4. TARIFF INVOICE | 9 |
| 5. CAPACITY INVOICES..... | 9 |
| 6. MONTHLY ENERGY INVOICE | 12 |
| 7. LIQUIDATED DAMAGES..... | 15 |
| PART III: SUPPLEMENTAL TARIFFS | 17 |
| 8. Supplemental Tariff Invoice for Pakistan Political Force Majeure Event (PPFME) or Change in Law Force Majeure Event (CLFME)..... | 17 |
| PART IV: ADDITIONAL PAYMENTS..... | 19 |
| 9. Invoices for Net Electrical Output during Testing..... | 19 |
| 10. Start-Up Charges | 19 |
| 11. Black Start Charges | 21 |
| 12. Pass Through Item(s)..... | 22 |
| PART V: INDEXATION..... | 24 |
| ANNEX 1-A: REFERENCE TARIFF TABLE | 25 |
| ANNEX 1-B: REFERENCE STARTUP CHARGES..... | 28 |
| ANNEX 2: PERIOD WEIGHTING FACTORS | 31 |
| ANNEX 3: REFERENCE WORKING CAPITAL COMPONENT & INDEXATION MECHANISM | 32 |
| ANNEX 4-A: KCCPP HEAT RATE DEGRADATION TABLES – GAS (COMBINED & SIMPLE CYCLE)..... | 34 |
| ANNEX 4-B: KCCPP HEAT RATE DEGRADATION TABLES – HSD (COMBINED & SIMPLE CYCLE)..... | 34 |
| ANNEX 4-C: KCCPP OUTPUT DEGRADATION TABLES – GAS (COMBINED & SIMPLE CYCLE)..... | 34 |
| ANNEX 4-D: KCCPP OUTPUT DEGRADATION TABLES – HSD (COMBINED & SIMPLE CYCLE)..... | 34 |
| ANNEX 5-A: KCCPP PART LOAD TABLE – GAS (COMBINED CYCLE)..... | 34 |
| ANNEX 5-B: KCCPP PART LOAD TABLE – GAS (SIMPLE CYCLE)..... | 34 |
| ANNEX 5-C: KCCPP PART LOAD TABLE – HSD (COMBINED CYCLE)..... | 34 |
| ANNEX 5-D: KCCPP PART LOAD TABLE – HSD (SIMPLE CYCLE)..... | 34 |
| ANNEX 6-A: START UP & BLACK START COST VERIFIED BY NESPAK – GAS & HSD | 34 |

PART I: GENERAL

1. INTRODUCTION

- 1.1 This Schedule 1 is attached to and constitutes an integral part of the Agreement (the “**Agreement**”) dated [●] entered between Korangi Combined Cycle Power Plant (“**Power Producer**”) and Network Control Department (“**Offtaker**”).

This Schedule 1 specifies the methods for calculating the invoices to be acknowledged to the Power Producer by the Offtaker or to the Offtaker by the Power Producer, as the case maybe, including but not limited to, under sections Section 9.1 (*Capacity Invoices*), Section 9.2 (*Energy Invoices*), Section 9.3 (*Start-Up Charges*), Section 9.3 (*Pass-Through Item(s); Supplemental Tariffs*), Section 9.4 (*Liquidated Damages*), Section 9.5 (*Billing*), Article VIII (*Testing and Capacity Ratings*) and Section 15.8 (*Supplemental Tariff*) of the Agreement. It also specifies the methods for making adjustments to such invoices for changes in Exchange Rate, Interest Rates, price indices, where applicable.

- (a) The methods for calculating the regular monthly invoices to be made to the Power Producer by the Offtaker or by the Power Producer to the Offtaker, as the case maybe, under Section 9.1 (*Capacity Invoices*), Section 9.2 (*Energy Invoices*) and Section 9.4 (*Liquidated Damages*) of the Agreement are set forth in Part II of Schedule 1.
 - (b) The method for calculating Supplemental Tariff Invoices to be made to the Power Producer by the Offtaker under Section 9.3 and Section 15.8 of the Agreement is set forth in Part III.
 - (c) The method for calculating additional invoices to be made to the Power Producer by the Offtaker or to the Offtaker by the Power Producer, as the case maybe, for the Pass-Through Item(s); Supplemental Tariff under Section 9.3, Invoice for Net Electrical Output during testing under Article VIII, Start-Up Charges and in case of occurrence a PPFME and CLFME that reduces the Company’s ability to declare Available Capacity under section 15.6 of the Agreement are set forth in Part IV.
 - (d) The timelines for the submission of Indices to be used for quarterly indexations (to be used in the formulae as mentioned in the Part II to this Schedule I) against the reference values are set forth in Part V.
 - (e) This Schedule 1 is in accordance with the Tariff Determination by NEPRA and in case of conflict, the Tariff Determination shall prevail.
- 1.2 The billing and invoice procedures as set forth in Article IX of the

Agreement shall apply to all invoice obligations referred to in this Schedule 1, unless otherwise specified therein.

2. DEFINITIONS

Capitalized terms used but not defined in this Schedule 1 shall have the meaning given to them in the Agreement. Wherever the following terms appear in this Schedule 1, they shall have the meanings stated below:

“Actual Premium” Actual amount of insurance premium calculated at the start of the Year, supported by appropriate documentations.

“Adjusted Insurance Component” has the meaning which is formulated for AIC_h in Section 5.2.

“Capacity Price” has the meaning as formulated for Capacity Price_h in Section 5.2 of this Schedule 1 as adjusted from time to time in accordance with the provisions thereof.

“Change in Tax” the adoption, enactment, promulgation, coming into effect, repeal, amendment, re-interpretation, change in application, change in interpretation or modification by any Public Sector Entity of any Law of Pakistan relating to any Tax or Taxes.

“Cost of Working Capital” has the meaning as formulated for Cost of Working Capital_h in Section 5.2.

“Current Indices” means the Exchange Rate, Interest Rate, Pak-CPI (NCPI) and the US-CPI, as applicable, calculated for the Quarter as of the date immediately at the start of current Quarter, and applicable for the current Quarter.

“Energy Price” has meaning as formulated for Energy Price_h in Section 6.3 of this Schedule 1 as adjusted from time to time in accordance with the provisions thereof.

“Exchange Rate” means the TT&OD selling rate for Dollar expressed in Rupees, as published by the National Bank of Pakistan prevailing on the last Business Day of the preceding Quarter.

“Fixed O&M Component” has the meaning as formulated for Fixed O&M_h in Section 5.2 of this Schedule-1.

“Fixed Foreign O&M Component” has the meaning as formulated for Fixed O&M_h in Section 5.2 of this Schedule-1.

“Fixed Local O&M Component” has the meaning as formulated for Fixed O&M_h in Section 5.2 of this Schedule-1.

“Free Start-Up” means the total number of Start-Ups that the Power Producer is required to perform in each Year as a result of complying with

Offtaker's Despatch Instructions before receiving any compensation for additional Start-Ups, of which amount in rupees is shown in Annex 1-B; Free Start-Ups shall not include any Start Up that follows a Forced Outage or Partial Forced Outage (unless such Forced Outage or Partial Forced Outage is account of Grid System variations or an Emergency claimed by the Offtaker), Maintenance Outage, Scheduled Outage or a Force Majeure Event affecting the Power Producer.

"Fuel Cost Component" has the meaning as formulated for FCC_h in Section 6.3.

"Indices" means the collective name for Exchange Rate, Interest Rate, Pak-CPI (NCPI) and the US-CPI used in tariff indexations as per the provisions of this Schedule-I.

"Interest Rate" means KIBOR.

"National Consumer Price Index (NCPI) - General" means the Consumer price index (General) as notified from time to time by the Federal Bureau of Statistics or any successor or replacement agency thereto.

"Pass Through Item(s)" Pass-Through Items shall be acknowledged by the Offtaker to the Power Producer on the basis of the actual costs reasonably incurred by the Power Producer to satisfy the requirements of the Agreement or to the extent the Offtaker is obligated pursuant to the Laws of Pakistan to make acknowledgement for such Pass-Through Item(s).

"Peak Period" The meaning ascribed thereto in Annex 2 of Schedule 1.

"Period Weighing Factor" or "PWF" means a factor set out in or otherwise determined in accordance with Section 5.2, which factor is applied in accordance with this Schedule 1 to the Capacity Price at specified times of the Day, Days of the week and seasons of the Year as an incentive to make capacity available at times when it is most valuable to the Offtaker.

"Reference Capacity Price" means the components comprised of Fixed O&M (Foreign & Local), Adjusted Insurance Component, Cost of Working Capital, Return on Equity and RoRB Cost of Debt (RoRB CoD Local) as set out in Reference Tariff Table Annex 1-A.

"Reference Cost of Debt Component" means the component, in Rs./kW/h, payable to the Power Producer in relation to the cost of debt as set forth in Annex 1-A.

"Reference Cost of Working Capital" means the component, in Rs./kW/h, payable to the Power Producer for financing the cost of working capital, as set forth in Annex 3.

"Reference Depreciation Component" means the component, in Rs./kW/h, payable to the Power Producer for depreciation, as set forth in

Annex 1-A.

“Reference Energy Price” means the components comprised of Fuel Cost Component, the Variable O&M Foreign Component and Variable O&M Local Component as set out in the Reference Tariff Table set in Annex 1-A.

“Reference Exchange Rate” With regards to Dollar means [287.10] Rupees to one (1) Dollar as notified in the Tariff Determination for K-Electric Limited Power Generation plants by NEPRA.

“Reference Fixed O&M Component” means the components comprised of Fixed O&M (Foreign) and Fixed O&M (Local), in Rs./kW/h, payable to the Power Producer for the fixed costs of operation and maintenance, as set forth in Annex 1-A.

“Reference Fixed O&M Foreign Component” means the component in Rs./kW/h, payable to the Power Producer for the foreign portion of fixed costs of operation and maintenance, as set forth in Annex 1-A.

“Reference Fixed O&M Local Component” means the component in Rs./kW/h, payable to the Power Producer for the local portion of fixed costs of operation and maintenance, as set forth in Annex 1-A.

“Reference HSD Fuel Cost Component” means the component payable in Rs./kWh to the Power Producer for the cost of HSD, that is attributable to the generation of Net Electric Output (whether or not such component compensates the Power Producer for the actual cost of such fuel) as set forth in Annex 1-A.

“Reference HSD Price” which has the meaning ascribed in Section 6.3.

“Reference Insurance Component” means the component, in Rs./kW/h, payable to the Power Producer in relation to the insurance as set forth in Annex 1-A.

“Reference NCPI” means the reference consumer price index (NCPI) (General) of 227.96 for the Month of May 2023 as per Tariff Determination.

“Reference Premium” which has the meaning ascribed in Section 5.2.

“Reference Gas Fuel Cost Component” means the component payable in Rs./kWh to the Power Producer for the cost of Gas, that is attributable to the generation of Net Electric Output (whether or not such component compensates the Power Producer for the actual cost of such fuel) as set forth in Annex 1-A.

“Reference Gas Price” which has the meaning ascribed in Section 6.3.

“Reference Return on Equity (ROE) Component” means the component,



in Rs./kW/h, payable to the Power Producer in relation to the return on investment by equity holders as set forth in Annex 1-A.

“Reference Tariff” means the sum of the Reference Capacity Price and the Reference Energy Price as set forth in Annex 1-A

“Reference Variable O&M Component” means the components comprised of Variable O&M (Foreign) and Variable O&M (Local), in Rs./kWh, payable to the Power Producer for the variable costs of operation and maintenance that are attributable to the generation of Net Electrical Output, (whether or not such component compensates the Power Producer for actual cost of providing such Net Electrical Output), as set forth in Annex 1-A.

“Reference Variable O&M Foreign Component” means the tariff component payable in Rs./kWh to the Power Producer for the foreign portion of variable costs of operation and maintenance that are attributable to the generation of Net Electrical Output, (whether or not such component compensates the Power Producer for actual cost of providing such Net Electrical Output), as set forth in Annex 1-A .

“Reference Variable O&M Local Component” means the tariff component payable in Rs./kWh to the Power Producer for the local portion of variable costs of operation and maintenance that are attributable to the generation of Net Electrical Output, which component (whether or not such component compensates the Power Producer for actual cost of providing such Net Electrical Output) as set forth in Annex 1-A .

“Reference US-CPI” means the United State consumer price index (All Urban Consumers), of 304.13 for the Month of May 2023 as per Tariff Determination.

“Return on Equity Component (ROE)” which has the meaning ascribed in Section 5.2.

“Supplemental Tariff Invoices” which has the meaning ascribed in Section 8.1.

“Tariff” means the tariff determination by NEPRA vide its letter No. NEPRA/R/ADG(Trf)/TRF-596/15878-82 dated 22 October 2024 as attached as Annex 1-C and as amended or revised from time to time.

“Test Energy Invoice” has the meaning given to it in Section 9.

“Start-Up Charge” has the meaning given to it in Section 10.

“US-CPI” means the United States Consumer Price Index (All Urban Consumers) issued by US Bureau of Labor Statistics from time to time (or any successor or replacement agency thereto).

“Variable O&M Component” has the meaning given to it in Section

6.3.

“Variable O&M Foreign Component” has the meaning given to it in Section 6.3.

“Variable O&M Local Component” has the meaning given to it in Section 6.3.



3. CONSTRUCTION

- 3.1 This Schedule 1 (including the Annexes) shall be read in conjunction with and to be subject to Tariff Determination, Article VIII and Article IX of the Agreement. To the extent that any provision of this Schedule 1 is inconsistent with Tariff Determination, Article VIII or Article IX or any other article or section of the Agreement, the provisions of Tariff Determination, Article VIII or Article IX or the other relevant article or section of the Agreement, as the case may be, shall prevail unless otherwise specified.
- 3.2 References to Parts, Articles, and Sections in this Schedule 1 are to Parts, Articles, and Sections of this Schedule 1, unless indicated otherwise. References to Tables and Annexes in this Schedule 1 are to the Tables and Annexes of this Schedule 1, unless indicated otherwise. References to Articles and Sections of the Agreement are to articles and sections contained in the main text of the Agreement.



PART II: TARIFF ACKNOWLEDGEMENT

4. TARIFF INVOICE

The Offtaker shall, for each Month of part thereof, acknowledge to the Power Producer, Capacity Invoices and Energy Invoices that shall be calculated in accordance with Sections 5 and 6, respectively.

5. CAPACITY INVOICES

5.1 The Offtaker shall acknowledge the Power Producer the Capacity Invoices, in accordance with the procedures specified in Section 9.6 of the Agreement, for the Available Capacity for each Month (or part-Month) in accordance with Section 9.1 of the Agreement.

5.1.1 In case capacity is declared on HSD, then the Available Capacity (in MW) and Tariff shall be applicable for HSD accordingly. For clarity, maximum capacity on HSD shall be 220.018 MW (i.e. the guaranteed capacity at reference site condition) along with appropriate degradation factor as per the relevant operating hour interval.

5.1.2 In case capacity is declared on both, Gas and HSD simultaneously, then the respective portion of capacity on each Fuel shall be adjusted along with appropriate degradation factor as per the relevant operating hour interval for the respective Fuel.

5.2 The Capacity Invoice for the applicable Month shall be equal to the aggregate sum (for all of the hours in such Month) of Capacity Invoice earned for each hour of the Month, and shall be equal:

$$\text{Capacity Invoice}_M = \sum_{h=1}^n \text{Capacity Invoice}_h$$

Where:

Capacity Invoice_M = Capacity Invoice, in Rupees, payable for the relevant Month;

Capacity Invoice_h = the Capacity Invoice, in Rupees, paid for hour *h* of the Month; and

n = the number of hours in the relevant Month.

$$\text{Capacity Invoice}_h = \text{Capacity Price}_h * \text{AvailCap}_h * \text{Do}_h$$

Where:

Capacity Invoice_h = the Capacity Invoice, in Rupees, payable for hour *h* of the Month;

Capacity Price_h = (Fixed O&M_h + Cost of Working Capital_h + AIC_h + Return on Equity_h + Depreciation_h + RoRBCoD Local_h) * PWF_h

Where:

Fixed O&M_h = Fixed Foreign O&M_{(Rev)h} + Fixed Local O&M_{(Rev)h}

Where:

Fixed Foreign O&M_{(Rev)h} = Fixed Foreign O&M_{(Ref)h} * US CPI_{(Rev)q} / US CPI_(Ref) * ER_{(Rev)q} / ER_(Ref)

Where:

Fixed Foreign O&M_{(Ref)h} = Fixed Foreign O&M_{(Ref)h} Rs./kW/h as per Annex 1-A;

US CPI_{(Rev)q} = The revised US CPI (All Urban Consumers) at the beginning of the Quarter that includes hour h;

US CPI_(Ref) = The Reference US CPI (All Urban Consumers) of 304.13 for May 2023;

ER_{(Rev)q} = The revised TT & OD selling rate of US Dollar notified by the National Bank of Pakistan on the last day of the Quarter preceding the Quarter that includes hour; and

ER_(Ref) = The Reference Exchange Rate of Rs. 287.10/US\$.

Fixed Local O&M_{(Rev)h} = Fixed Local O&M_{(Ref)h} * NCPI_{(Rev)q} / NCPI_(Ref)

Fixed Local O&M_{(Ref)h} = Fixed Local O&M_{(Ref)h} Rs./kW/h as per Annex 1-A;

NCPI_(Rev) = The revised NCPI (General) at the beginning to the Quarter that includes hour h; and

NCPI_(Ref) = The Reference NCPI (General) of 227.96 for May 2023.

Cost of Working Capital

Cost of Working Capital_h = Cost of working capital_{(Ref)h} Rs./kW/h as per Annex 3.

This cost shall be adjusted on a quarterly basis for the following variations:

- Fuel Price
- Fuel Inventory
- Load Factor
- Receivable Cycle
- SBLC Amount



- SBLC Charges
- Value of Stores & Spares
- KIBOR

The adjustment mechanism including indexation of the same for the components of the cost of working capital are set out in Annex – 3, in line with the Tariff determination.

$$AIC_h = \text{Insurance}_{(Ref)h} / P_{(Ref)} * P_{(Act)}$$

Where:

$\text{Insurance}_{(Ref)h}$ = Insurance_{(Ref)h} Rs./kW/h as per Annex 1-A;

$P_{(Ref)}$ = Following Reference Premium at Rs. 287.1/US\$; and

$P_{(Act)}$ = Actual Premium or USD 1.23 million at Exchange Rate prevailing on the 1st day of the insurance coverage period whichever is lower.

$$\text{Return on Equity}_{(Rev)h} = ROE_{(Ref)h} * ER_{(Rev)q} / ER_{(Ref)}$$

Where:

$ROE_{(Ref)h}$ = ROE_{(ref)h} Rs./kW/h as per Annex 1-A;

$ER_{(Rev)q}$ = The revised TT & OD selling rate of US Dollar notified by the National Bank of Pakistan on the last day of the Quarter preceding the Quarter that includes hour; and

$ER_{(Ref)}$ = The Reference Exchange Rate of Rs. 287.10/US\$.

Depreciation = Depreciation_{(Ref)h} Rs./kW/h as per Annex 1-A.

$$\text{RoRBCoD Local}_{(Rev)h} = \text{RoRBCoD Local}_{(Ref)} * \text{CoD Local}_{(Rev)} / \text{CoD Local}_{(Ref)}$$

Where:

$\text{RoRBCoD Local}_{(Ref)}$ = RoRBCoD Local_{(Ref)h} Rs./kW/h as per Annex 1-A;

$\text{CoD Local}_{(Rev)}$ = Revised 3 Month KIBOR notified by State Bank of Pakistan at the beginning of the Quarter + 2.25% allowed spread; and

$\text{CoD Local}_{(Ref)}$ = The Reference KIBOR of Rs. 22.91% + 2.25% allowed spread.

PWF_h = the Period Weighing Factor applicable to hour h of the Month, as set out in Annex-2;

AvailCap_h = the Available Capacity, in kW, for hour h of the relevant Month;

h = each hour in the Month for which a Capacity Invoice is being calculated;
and

Do_h = the output degradation factor as set forth in Annex 4 for the interval of operating hours immediately preceding the interval of operating hours in which hour 'h' occurs

5.3 The Period Weighing Factors (“PWFs”) for each period are as specified in Annex-2. The Offtaker shall have the right to unilaterally revise the PWFs specified in Annex-2 in accordance with Section 5.13 of the Agreement, subject to the following provisions:

- a) the Offtaker shall give notice to the Power Producer of such revision in accordance with Section 5.13 of the Agreement;
- b) the value of the PWF in any hour period shall not be greater than two and one-half (2.5); and the value of the PWF during each period during the Maintenance Months shall not be greater than one (1);
- c) the time-weighted average of the PWFs in a Year shall be equal to one (1); and
- d) there shall be no more than three (3) periods in any one (1) Day or more than five (5) periods in any two (2) Day period.

6. MONTHLY ENERGY INVOICE

6.1 The Offtaker shall acknowledge to the Power Producer the Reference Energy Price in accordance with the procedures specified in Section 9.6 for Despatched and Delivered Net Electrical Output for the relevant Month (or part-Month) in accordance with Section 9.2.

6.2 Energy Invoice for the relevant Month shall be equal to the aggregate sum (for all of the hours in such Month) of the Energy Invoice earned for each hour of the Month, and shall equal:

$$\text{Energy Invoice}_M = \sum_{h=1}^n \text{Energy Invoice}_h$$

Where:

Energy Invoice_M = the Energy Invoice, in Rupees, payable for the relevant Month;

Energy Invoice_h = the Energy Invoice for hour *h*; and

n = the number of hours in the relevant Month.

6.3 The Energy Invoice earned for each hour of a Month shall be calculated as follows:



$$\text{Energy Invoice}_h = \text{Energy Price}_h * \text{NEO}_h$$

Where:

$$\text{Energy Price}_h = \text{FCCG}_{(\text{Rev})h} \text{ or } \text{FCCHSD}_{(\text{Rev})h} \text{ (as applicable)} + \text{Variable O\&M}_h$$

$$\text{FCCG}_{(\text{Rev})h} = \text{FCCG}_{(\text{Ref})h} * \text{FPG}_{(\text{Rev})} / \text{FPG}_{(\text{Ref})} * \text{DH}_{(\text{Gas})h} * \text{K}_L$$

Where:

$$\text{FCCG}_{(\text{Ref})h} = \text{FCCG}_{(\text{Ref})h} \text{ Rs./kWh as per Annex 1-A;}$$

$\text{FPG}_{(\text{Rev})}$ = the revised HHV Gas price in USD notified by the Oil and Gas Regulatory Authority (OGRA) converted to PKR at the invoiced exchange rate by the supplier, from time to time and notified by GOP, and billed by Gas Supplier, consumed during hour h , as applicable;

$\text{FPG}_{(\text{Ref})}$ = The Reference HHV Gas Price for KCCPP is Rs. 3,717/MMBtu in case of RLNG and Rs. 857/MMBtu in case of indigenous gas;

$\text{DH}_{(\text{Gas})h}$ = the heat rate degradation factor for Gas fuel as set forth in Annex 4 for the interval of operating hours immediately preceding the interval of operating hours in which hour 'h' occurs; and

K_L = the load correction factor for the units in hour h , as set forth in Annex 5.

$$\text{FCCHSD}_{(\text{Rev})h} = \text{FCCHSD}_{(\text{Ref})h} * \text{FPHSD}_{(\text{Rev})} / \text{FPHSD}_{(\text{Ref})} * \text{CalHSD}_{(\text{Ref})} / \text{CalHSD}_{(\text{Rev})} * \text{K}_L * \text{DH}_{(\text{HSD})h}$$

Where:

$$\text{FCCHSD}_{(\text{Ref})h} = \text{FCCHSD}_{(\text{ref})h} \text{ Rs./kWh as per Annex 1-A;}$$

$\text{FPHSD}_{(\text{Ref})}$ = Reference HSD Price of Rs. 232.52 per Litre;

$\text{FPHSD}_{(\text{Rev})}$ = The revised net HHV HSD price in PKR / liter for the month based on weighted average formula as illustrated below;

| HSD | Legend | Stock in Liters | Amount - PKR | Weighted average price |
|---------------------------|-----------|-----------------|--------------|------------------------|
| | | i | ii | iii = ii / i |
| Opening | A | 4,824,108 | 1,061 | |
| Purchases | B | - | - | |
| Available for consumption | C = A + B | 4,824,108 | 1,061 | 219.94 |
| Less: Consumption | D | (440,080) | (97) | |
| Closing | E = C - D | 4,384,027 | 964 | |

$D_{H(HSD)h}$ = the heat rate degradation factor for HSD fuel as set forth in Annex 4 for the interval of operating hours immediately preceding the interval of operating hours in which hour 'h' occurs;

K_L = the load correction factor for the units in hour h, as set forth in Annex 5;

$CalHSD_{(Ref)}$ = reference HSD HHV Calorific Value of Rs. 36,252.364 btu per litre; and

$CalHSD_{(Rev)}$ = revised HSD HHV Calorific Value for the Month in btu per litre for the Month as illustrated below.

| Description | Unit | Calculation | Amount | Source |
|-----------------------|-------------|-------------|--------|--|
| Gross Calorific value | btu / lb | a | 19,731 | Actual GCV for the month as per test reports |
| Conversion factor | lb / kg | b | 2.2046 | Standard conversion factor |
| Gross Calorific value | btu / kg | c = a x b | 43,499 | Calculated |
| Density | kg / liter | d | 0.833 | Actual Density for the month as per test reports |
| Gross Calorific value | btu / liter | e = c x d | 36,252 | Calculated |

GCV test is conducted at a frequency of every 10 Days by third party, subject to consumption of HSD, in case of no consumption last test certificate will prevail. The value of GCV so determined in the test is used to determine the Fuel Cost Component for the Month as formulated above. Method of sampling of HSD for every 10 Days shall be defined in the Operating Procedures.

Variable $O\&M_h$ = Variable Local $O\&M_{(Rev)h}$ + Variable Foreign $O\&M_{(Rev)h}$

Where:

Variable Local $O\&M_{(Rev)h}$ = Local Variable $O\&M_{(Ref)h}$ * $NCPI_{(Rev)q}$ / $NCPI_{(Ref)}$

Where:

Variable Local $O\&M_{(Ref)h}$ = Variable Local $O\&M_{(Ref)h}$ Rs./kWh as per Annex 1-A;

$NCPI_{(Rev)q}$ = The revised NCPI (General) at the beginning of the Quarter which includes hour; and

$NCPI_{(Ref)}$ = The Reference NCPI (General) of 227.96 for May 2023.

Variable Foreign O&M_{(Rev)h} = Fixed Variable O&M_{(Ref)h} * US CPI_{(Rev)q} / US CPI_(Ref) * ER_{(Rev)q} / ER_(Ref)

Where:

Variable Foreign O&M_{(Ref)h} = Variable Foreign O&M_{(Ref)h} Rs./kWh as per Annex 1-A;

US CPI_{(Rev)q} = The revised US CPI (All Urban Consumers) at the beginning of the Quarter which includes hour;

US CPI_(Ref) = The Reference US CPI (All Urban Consumers) of 304.13 for May 2023;

ER_{(Rev)q} = The revised TT & OD selling rate of US Dollar notified by the National Bank of Pakistan on the last day of the Quarter preceding the Quarter that includes hour; and

ER_(Ref) = The Reference Exchange Rate of Rs. 287.10/US\$.

NEO_h = Net Electrical Output of the Complex for the respective fuel (i.e. Gas or HSD as applicable), in kWh, for hour *h* of the period.

6.4 For the purpose of NEO for any hour, in case of an interval (as agreed by the Operating Committee) having both electrical energy delivered as well as power imported by the Complex, recorded under electronic data recording system on the Interconnection Point, then:

(a) If the electric energy is delivered to Offtaker on net basis during that interval, the net electrical energy shall be included in NEO during that hour; and

(b) If the electric energy is imported from Offtaker on net basis during that interval, the net electrical energy shall be considered under billing of power imported from Offtaker during that hour.

7. LIQUIDATED DAMAGES

a) Liquidated Damages

Pursuant to Section 9.4(b) of Agreement, the Power Producer shall pay liquidated damages (LDs) to the Offtaker provided that these liquidated damages shall apply and be payable by the Power Producer (only after the number of hours available to the Power Producer under Section 9.1

(c) and (d) have first been utilized) as formulated hereunder:

- i) in the event, when Declared Available Capacity is revised between twelve (12) hours and four (4) hours prior to the beginning of an Operating Day.

$LDs = 10\% * [\text{Declared Available Capacity or Revised Declared Available Capacity (or any Adjusted Declared Available Capacity related thereto), as applicable, prevailing twelve (12) hours before the start of the Operating Day - Revised Declared Available Capacity (or any Adjusted Declared Available Capacity related thereto), as applicable, prevailing four (4) hours before the start of the Operating Day}] * \text{Capacity Price for the relevant hour h. plus}$

- ii) in the event, when Declared Available Capacity is revised within four (4) hours before the beginning of the Operating Day.

$LDs = 20\% * [\text{Declared Available Capacity or Revised Declared Available Capacity (or any Adjusted Declared Available Capacity related thereto), as applicable, prevailing four (4) hours before the start of the Operating Day - Revised Declared Available Capacity (or any Adjusted Declared Available Capacity related thereto), as applicable, prevailing at the start of the Operating Day}] * \text{Capacity Price for the relevant hour, h. plus}$

- iii) in the event, the Power Producer fails to Comply with Despatch Instructions:

$LDs = 100\% * [\text{Declared Available Capacity or Revised Declared Available Capacity (or any Adjusted Declared Available Capacity related thereto), as applicable, at the start of the hour - the Available Capacity for that hour}] * \text{Capacity Price for the relevant hour, h.}$

Provided however, if the Power Producer revises its Available Capacity upwards after the Declaration Deadline, for reasons other than forecasted temperature conditions, and is eligible for Capacity Invoices for such upward revision, but after such upward revision, it fails to deliver such increased capacity when dispatched, then the liquidated damages amount calculated in this subsection (iii) above shall be multiplied by two (2) for purposes of such unavailable capacity.

Provided further, if the Power Producer revises its declaration downward of its Available Capacity on account of unavailability during an Operating Day, the liquidated damages shall not be applicable as per 9.1(d) of the Agreement, unless total outage allowance for the Agreement Year has been utilized.



PART III: SUPPLEMENTAL TARIFFS

8. Supplemental Tariff Invoice for Pakistan Political Force Majeure Event (PPFME) or Change in Law Force Majeure Event (CLFME)

8.1 If, due to a Pakistan Political Force Majeure Event (PPFME) or a Change in Law Force Majeure Event (CLFME), a invoice is due and payable to the Power Producer from the Offtaker as provided in Sections 15.8(b) and 15.8(c) of the Agreement (“**Supplemental Tariff Invoice**”), the Offtaker shall, following the completion of the Restoration, pay to the Power Producer the Supplemental Tariff Invoice, until the recoverable costs of a Restoration have been received in full by the Power Producer from the Offtaker subject to NEPRA determination (which shall be structured to allow the Power Producer to recover the reasonable and necessary costs of a Restoration net of insurance proceeds, if any, over the remainder of the Term, as provided in this Article 8) shall be calculated in accordance with Section 8.2. Each Pakistan Political Force Majeure Event or Change in Law Force Majeure Event, that may be unrelated to each other, may lead to a separate Supplemental Tariff Invoice.

8.2 The Supplemental Tariff Invoice for a Month shall be equal to the aggregate sum of the Supplemental Tariff Invoice for each hour in such Month. The Supplemental Tariff Invoice for each hour of the Month shall be calculated as follows:

$$STP_m = \sum_{h=1}^n STP_h$$

$$STP_h = RRR_{\text{fixed}/h} * AvailCap_h$$

Where:

STP_h = the Supplemental Tariff Invoice for a Restoration, in Rupees, for hour h of the Month; and

$$RRR_{\text{fixed}/h} = R_t / (TC_t * PIT_t)$$

Where:

RRR_{fixed} = the Restoration recovery rate, in Rs./kW/h, which rate shall be calculated one (1) time following the agreement by the Parties on the Restoration costs, as determined by NEPRA, or as per the resolution of a dispute over such costs pursuant to Section 15.6 of the Agreement and shall remain fixed thereafter, and which rate for all hours h shall be equal to:

R_t = the total cost of the Restoration, as determined by NEPRA, or in accordance with Section 15.6 of the Agreement, as applicable;

TC_t = the then-prevailing Tested Capacity at time t , expressed in kW;

PIT_t = the total number of hours remaining in the Term from time t ;

t = following the Day the Parties agree on Restoration costs, to be recovered by the Power Producer or the resolution of a dispute over such costs pursuant to Section 15.6 of the Agreement and in each case, the date that the Complex returns to operation or if the Complex did not cease operation, the date on which the Restoration, is completed;

AvailCap_h = the Available Capacity, in kW, for hour, *h* of the Month provided however that it shall include the period of deemed availability for which the Power Producer shall be paid Capacity Invoices as provided for in Article 9.1 (c) and 9.1 (d) of the Agreement; and

h = an hour in the Month for which a Supplemental Tariff Invoice is calculated pursuant to this Section 8.2.

- 8.3 Unless NEPRA approves an alternate cost of capital (including debt and equity), the Power Producer shall be entitled to receive in accordance with Section 15.8(d) of the Agreement a return equal to KIBOR plus percent (3%) per annum on the scheduled unpaid portion of the total cost of a Restoration through the period of cost recovery. The applicable KIBOR shall be the rate prevailing on the date that the Complex returns to operation or if the Complex did not cease operation, the date on which the Restoration is completed.
- 8.4 At any time after the first (1st) Business Day of each Month, the Power Producer may submit an invoice to the Offtaker stated in Rupees for the Supplemental Tariff Invoice, inclusive of return thereon, for the previous Month, together with supporting information as may reasonably be necessary to substantiate the amounts claimed in the invoice.
- 8.5 The Offtaker may seek to verify the calculation of a Supplemental Tariff Invoice for a Restoration, inclusive of return thereon, and may require the Power Producer to provide to it copies of its calculations, with reasonable supporting information, which the Power Producer shall provide within [30] Days of such request. Within one (1) Year following the commencement of such payments, the Offtaker shall have the right to engage, at its own cost, an independent auditor to audit and examine the costs claimed by the Power Producer, and the Power Producer shall make all of its relevant books and records available to the Offtaker and its auditors in connection with such audit or examination, provided however, if such Restoration cost, is submitted to and approved by NEPRA, no such audit shall be conducted.



PART IV: ADDITIONAL PAYMENTS

9. Invoices for Net Electrical Output during Testing.

- 9.1 The Test Energy Invoice shall be equal to the aggregate sum of the Net Electrical Output delivered during each such hour multiplied by the Fuel Cost Component applicable to each hour in such Month. The Test Energy Invoice earned for each hour shall be calculated as follows:

$$\text{Test Energy Invoice}_M = \sum_{h=1}^n \text{Test Energy Invoice}_h,$$

Where:

Test Energy Invoice_h = **FCCG_{(Rev)h}** or **FCCHSD_{(Rev)h}**, as applicable * **NEO_h**

Where:

FCCG_{(Rev)h} = as ascribed in Section 6.3 to this Schedule;

FCCHSD_{(Rev)h} = as ascribed in Section 6.3 to this Schedule; and

NEO_h = Net Electrical Output of the Complex, in kWh, for hour *h* of the period on the respective fuel (i.e. Gas or HSD).

- 9.2 At any time on or after first (1st) Business Day of each Month and on the first (1st) Business Day falling after the fifteenth (15th) Day of each Month, the Power Producer may submit an invoice to the Offtaker stated in Rupees for the Net Electrical Output delivered during the tests carried out under Article VIII and the Offtaker shall acknowledge the Power Producer the Energy Price, Start up Charges or any other charges in accordance with Section 9.6 to Agreement.
- 9.3 The Offtaker shall acknowledge claims if there occurs a PPFME or a CLFME that reduces the Power Producer's ability to declare Available Capacity subject to and in accordance with Section 15.6 of the Agreement.

10. Start-Up Charges

- 10.1 For each Start-Up that (i) is required to comply with a Despatch Instruction or Revised Despatch Instruction, and (ii) does not follow a Forced or Partial Forced Outage (unless such Forced or Partial Forced Outage is on account of Grid System conditions or an Emergency claimed by the Offtaker), Maintenance Outage, Scheduled Outage, or Force Majeure Event affecting the Power Producer, the Offtaker shall pay to the Power Producer Start-Up Charges as calculated in accordance with Section 10.3 (each such charge, a "Start-Up Charge").
- 10.2 Start-Up Charge = MDI Charge+ Reference Start-Up Charges.

- a) MDI Charge: The MDI charge shall be based on maximum demand recorded during the relevant month at startup and shall be calculated based on the then applicable MDI rate in Rs/kW, from time to time,
- b) Reference Start-Up Charge: This cost will cover the consumables, fuel and equivalent operating hours consumed for the Start-Ups.

The Start-Up Charges for each Start-Up shall be indexed with relevant indices, including fuel prices and applicable degradation factors as of the start of each month as requested below:

| | | |
|------------------|---|---|
| SC_M | = | $MDIR_x \times N1 + ((SCPI_{Ref} \times SCF_{adjustPI}) + ((SCFC_{Ref} \times SCF_{adjustFC})) \times N2$ |
| Where: | | |
| SC_M | = | The Start Up Charges during the Month M |
| $MDIR_x$ | = | Total fixed charges for the month due to distributing segment during the relevant month (based on MDI for the month and MDI charge) divided by the total number of Start Ups performed during the month. |
| $N1$ | = | The number of Start Ups to be claimed, unless any shutdowns claimed during the relevant month in which case this will be considered as zero. |
| $N2$ | = | The number of Start Ups to be claimed |
| $SC_{(Ref)}$ | = | The Reference Start-Up Charge as given below in Annex 1-B. Consists of the following two components: |
| $SCPI_{Ref}$ | = | The Reference Start-Up Charge for the power import from transmission system during GT Startup till synchronization. |
| $SCF_{adjustPI}$ | = | <p>The Startup Charges Adjustment Factor for the hour h for the import of power from transmission network as per following formula:</p> $SCF_{adjustPI} = WAVCT-C3_{(Rev)} / WAVCT-B5_{(Ref)}$ <p>where:</p> <p>WACT-C3_(Rev) = Weighted average of the latest notified variable consumer tariff for the Bulk Supply Consumer Category (C-3), or other category as notified, based on a weightage of 4:20 for Peak & Off-Peak Rates respectively.</p> <p>WACT-B5_(Ref) = Weighted average of the reference notified variable consumer tariff for the Industrial Consumer Category (B-5) based on a weightage of 4:20 for Peak & Off-Peak Rates (i.e. Rs. 30.33 per kWh & Rs. 23.55 per kWh) respectively (i.e. Rs. 24.68 per kWh)</p> |
| $SCFC_{Ref}$ | = | The Reference Start-Up Charge for the fuel consumed during GT Startup till synchronization including ST synchronization, if applicable. |
| $SCF_{adjustFC}$ | = | The Startup Charges Adjustment Factor for the hour h for the consumption of fuel (net off revenue claimed in the hourly fuel cost) as per the following formula: |
| | | <p>For Gas – $SCF_{adjustFC} = (FPG_{Rev} / FPG_{Ref}) \times D_H \times D_O$</p> <p>For HSD – $SCF_{adjustFC} = (FPHSD_{Rev} / FPHSD_{Ref}) \times D_H \times D_O$</p> <p>For above:</p> |

| | | |
|----------------|---|--|
| | | <p>FPG_{Ref} = The Reference HHV Gas price for RLNG is Rs. 3,300.82 based on RLNG price. In case co-mingled gas is provided by SSGC in a month then FPG_{Rev} shall be based on weighted average formula as illustrated below;</p> <p style="text-align: center;">Weighted average cost = (E*D+C*F)/(E+F)</p> <p>Where:</p> <p>C = RLNG price D = Indigenous Gas price E = Indigenous Gas actual volume billed for the month F = RLNG Gas actual volume billed for the month</p> <p>FPHSD_{Ref} = The Reference HSD Price is Rs. 219.94 per Litre.</p> |
| D _H | = | the heat rate degradation factor as set forth in Annex 4 for the relevant interval of operating hours at the start of the month in which the Startup occurs. |
| D _O | = | the output degradation factor as set forth in Annex 4 for the relevant interval of operating hours at the start of the month in which the Startup occurs. |

Subject to Section 10 Start-Up shall be counted as payable to the Power Producer by the Offtaker even if the requested Start-Up is subsequently cancelled as a result of a change in any Despatch Instruction or Revised Despatch Instruction prior to the synchronization to the Grid System unless the Offtaker issued a Revised Despatch Instruction sufficiently prior to the Start-Up to enable the Power Producer to cancel the Start-Up.

11. Black Start Charges

Black Start is the capability to recover from a total or partial shutdown of the transmission system.

Black Start Charges shall be paid when it is necessary for the Power Producer to comply with a Dispatch Instruction or the technical requirements of the Complex.

Black start charges are based on Reference Blackstart charges indexed with relevant indices, including fuel prices and applicable degradation factors as of the start of each month as requested below

The Black-start Charges for each Start-Up shall be calculated as follows:

| | | |
|------------------------|---|--|
| BSCM | = | $\frac{(BSCRef_{BSDG} \times BSCFadjust_{BSDG} + BSCRef_{Other} \times BSCFadjust_{Other}) \times N}{N}$ |
| Where: | | |
| BSCM | = | the Black-start Charges during the Month M; |
| BSCRef | = | the Reference Black-Start Charge as given below in Annex 1-B and consists of the following two components: |
| BSCRef _{BSDG} | = | The Reference Black-Start Charge for BSDG. |

| | | |
|------------------------------|---|---|
| BSCFadjust _{hBSDG} | = | The Black-start Charges Adjustment Factor for the hour h; where: For HSD – $SHCFadjust_{hBSDG} = FCCHSD_{Rev} / FCCHSD_{Ref}$ |
| BSCRef _{Other} | = | The Reference Black-Start Charge for GT including ST where applicable. |
| BSCFadjust _{hOther} | = | The Black-start Charges Adjustment Factor for the hour h; where: For HSD – $SHCFadjust_{hOther} = (FPHSD_{Rev} / FPHSD_{Ref}) \times D_H \times D_o$ $FPHSD_{Ref}$ = The Reference HSD Price of Rs. 219.94 per Litre |
| N | = | The number of Black Startups to be claimed |
| D _H | = | the heat rate degradation factor as set forth in Annex 4 for the relevant interval of operating hours at the start of the month in which the Startup occurs |
| D _o | = | the output degradation factor as set forth in Annex 4 for the relevant interval of operating hours at the start of the month in which the Startup occurs |

Subject to Section 11 Black Start shall be counted as payable to the Power Producer by the Offtaker even if the requested Black Start is subsequently cancelled as a result of a change in any Despatch Instruction or Revised Despatch Instruction prior to the synchronization of the relevant unit to the Grid System unless the Offtaker issued a Revised Despatch Instruction sufficiently prior to the Black Start to enable the Power Producer to cancel the Black Start.

12. Pass Through Item(s)

- 12.1 Pass-Through Items shall be payable by the Offtaker to the Power Producer on the basis of the actual costs reasonably incurred by the Power Producer to satisfy the requirements of the Agreement or to the extent the Power Producer is obligated pursuant to the Laws of Pakistan to make acknowledgement for such Pass-Through Item(s).
- 12.2 The Power Producer may present invoice(s) to the Offtaker for Pass-Through Items at any time on or after the first (1st) Day of the Month following the Month in which the cost(s) was/were incurred by the Power Producer.
- 12.3 The following items shall be Pass-Through Items:
- Any unrecovered cost of outgoing MYT which may be allowed under pending end of term adjustment of the MYT.
 - Gas Infrastructure Development Cess (GIDC) required to be paid by the Power Producer pertaining to prior periods based on court verdict, if any.
 - In the case of any unbundling of the Company in future, one time adjustment for additional costs pursuant to unbundling.

- (d) Any tax that becomes applicable to the Power Producer, including but not limited to the corporate tax.
- (e) WWF/WPPF being separately levied on the Power Producer.

Any other costs reasonably incurred by the Power Producer to satisfy the requirements of Agreement, and allowed by NEPRA

For avoidance of doubt, if a particular type of Tax is stated to be a Pass Through item in this Section 12 then any Change in Tax rate for such Tax upwards or downwards shall be treated as a Pass Through Item.

- 12.4 The Power Producer shall invoice Offtaker in arrears for recovery of the expenditure made with the consent of Offtaker for any upgradation in the protective devices under Article VI or Metering System under Article VII of the Agreement.



PART V: INDEXATION

- 13.1 At the beginning of each Quarter, the Power Producer shall on the fifteenth (15th) Business Day following the end of a Quarter, deliver to the Offtaker the Current Indices and values as submitted to NEPRA for determination. Following the determination of the same by the NEPRA, the Power Producer shall provide the determined Indices and values, to the Offtaker along with the reasonable supporting information if any, within 7 Business Days of the determination by NEPRA.
- 13.2 If any index used herein ceases to be available, the Parties shall request NEPRA to determine an alternative index. Such determination when made available, shall be binding on the Parties for the purpose of such index hereunder. Pending the determination by NEPRA, the last available value of such index shall be used for all relevant purposes hereunder. Upon the determination of such index by NEPRA, either Party shall revise all acknowledgement made during the pendency of alternative index.
- 13.3 One Time Adjustments
- Not Used.

ANNEX 1-A: REFERENCE TARIFF TABLE

K-Electric Limited

KCCP

Reference Generation Tariff (Gas)

Annex-III

| Year | Energy Purchase Price (Rs./kWh) | | | | Capacity Purchase Price (Rs./kWh) | | | | | | | | Total Tariff @ 60% | | |
|------------------|---------------------------------|--------------|---------|-----------|-----------------------------------|---------|-----------|-----------------|--------------|----------------|--------------|-----------|--------------------|---------|-------------|
| | Fuel Cost Component | Variable O&M | | Total EPP | Fixed O&M | | Insurance | Working capital | R&R | | Depreciation | Total CPP | Total CPP @ 40% | Rs./kWh | Costs / kWh |
| | | Local | Foreign | | Local | Foreign | | | Cost of Debt | Cost of Equity | | | | | |
| 1 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 1.6014 | 0.9502 | 0.5803 | 4.4600 | 7.4334 | 39.6023 | 13.7939 |
| 2 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 1.4992 | 0.8895 | 0.5803 | 4.2972 | 7.1620 | 39.3310 | 13.6994 |
| 3 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 1.3970 | 0.8289 | 0.5803 | 4.1344 | 6.8906 | 39.0596 | 13.6049 |
| 4 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 1.2948 | 0.7683 | 0.5803 | 3.9715 | 6.6192 | 38.7882 | 13.5103 |
| 5 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 1.1926 | 0.7076 | 0.5803 | 3.8087 | 6.3478 | 38.5168 | 13.4158 |
| 6 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 1.0904 | 0.6470 | 0.5803 | 3.6459 | 6.0764 | 38.2454 | 13.3213 |
| 7 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.9882 | 0.5864 | 0.5803 | 3.4830 | 5.8051 | 37.9740 | 13.2268 |
| 8 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.8860 | 0.5257 | 0.5803 | 3.3202 | 5.5337 | 37.7026 | 13.1322 |
| 9 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.7838 | 0.4651 | 0.5803 | 3.1574 | 5.2623 | 37.4313 | 13.0377 |
| 10 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.6816 | 0.4044 | 0.5803 | 2.9945 | 4.9909 | 37.1599 | 12.9432 |
| 11 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.5794 | 0.3438 | 0.5803 | 2.8317 | 4.7195 | 36.8885 | 12.8487 |
| 12 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.4772 | 0.2832 | 0.5803 | 2.6689 | 4.4481 | 36.6171 | 12.7541 |
| 13 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.3750 | 0.2225 | 0.5803 | 2.5060 | 4.1767 | 36.3457 | 12.6596 |
| 14 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.2728 | 0.1619 | 0.5803 | 2.3432 | 3.9054 | 36.0743 | 12.5651 |
| 15 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.1707 | 0.1013 | 0.5803 | 2.1804 | 3.6340 | 35.8029 | 12.4705 |
| 16 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.0685 | 0.0406 | 0.5803 | 2.0176 | 3.3626 | 35.5316 | 12.3760 |
| 17 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.0511 | 0.0303 | 0.5803 | 1.9899 | 3.3165 | 35.4855 | 12.3600 |
| Average Tariff | | | | | | | | | | | | | | | |
| 1-17 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 0.7888 | 0.4686 | 0.5803 | 3.1653 | 5.2755 | 37.4445 | 13.0423 |
| Levelized Tariff | | | | | | | | | | | | | | | |
| 1-17 | 30.4024 | 0.0795 | 1.6871 | 32.1690 | 0.4601 | 0.2641 | 0.0618 | 0.5422 | 1.0100 | 0.5993 | 0.5803 | 3.5178 | 5.8630 | 38.0319 | 13.2469 |



K-Electric Limited
KCCP
Reference Generation Tariff (RSD)

| Year | Energy Purchase Price (Rs./kWh) | | | | Capacity Purchase Price (Rs./kW) | | | | | | | Total Tariff @ 60% | |
|------------------|---------------------------------|----------------|---------|-----------|----------------------------------|---------|-----------|-----------------|--------------|----------------|--------------|--------------------|-----------------|
| | Fuel Cost Component | Variable Price | | Total KPP | Fixed O&M | | Insurance | Working capital | Cost of Debt | Cost of Equity | Depreciation | Total CPP | Total CPP @ 60% |
| | | Local | Foreign | | Local | Foreign | | | | | | | |
| 1 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 1.6073 | 0.9537 | 0.5824 | 4.4764 | 7.4607 |
| 2 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 1.5047 | 0.8928 | 0.5824 | 4.3130 | 7.1883 |
| 3 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 1.4031 | 0.8320 | 0.5824 | 4.1496 | 6.9160 |
| 4 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 1.2996 | 0.7711 | 0.5824 | 3.9861 | 6.6436 |
| 5 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 1.1970 | 0.7102 | 0.5824 | 3.8227 | 6.3712 |
| 6 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 1.0944 | 0.6494 | 0.5824 | 3.6593 | 6.0988 |
| 7 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.9918 | 0.5885 | 0.5824 | 3.4959 | 5.8264 |
| 8 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.8893 | 0.5277 | 0.5824 | 3.3324 | 5.5540 |
| 9 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.7867 | 0.4668 | 0.5824 | 3.1690 | 5.2817 |
| 10 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.6841 | 0.4059 | 0.5824 | 3.0056 | 5.0093 |
| 11 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.5816 | 0.3451 | 0.5824 | 2.8421 | 4.7369 |
| 12 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.4790 | 0.2842 | 0.5824 | 2.6787 | 4.4645 |
| 13 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.3764 | 0.2233 | 0.5824 | 2.5153 | 4.1921 |
| 14 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.2738 | 0.1625 | 0.5824 | 2.3518 | 3.9197 |
| 15 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.1713 | 0.1016 | 0.5824 | 2.1884 | 3.6474 |
| 16 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.0687 | 0.0408 | 0.5824 | 2.0250 | 3.3750 |
| 17 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.0087 | 0.0052 | 0.5824 | 1.9294 | 3.2156 |
| Average Tariff | | | | | | | | | | | | | |
| 1-17 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 0.7892 | 0.4683 | 0.5824 | 3.1730 | 5.2883 |
| Levelized Tariff | | | | | | | | | | | | | |
| 1-17 | 50.7461 | 0.0823 | 2.3508 | 53.1793 | 0.4618 | 0.2650 | 0.0620 | 0.5442 | 1.0127 | 0.6009 | 0.5824 | 3.5291 | 5.8818 |



12.3. On the basis of approved heat rates and prevailing prices, the fuel cost component for different plants and fuels have been worked out and approved as provided hereunder:

| Description | Combined Cycle Operation (Rs./kWh) | | | | Open Cycle (Rs./kWh) | |
|-------------------------|------------------------------------|-----------------|---------|---------|----------------------|---------|
| | Gas | RLNG | RFO | HSD | Gas | RLNG |
| BQI Unit 1 | 9.6249 | 41.7506 | 34.6414 | - | - | - |
| BQI Unit 2 | 9.5496 | 41.4241 | 34.5148 | - | - | - |
| BQI Unit 5 | 9.2542 | 40.1426 | 33.3197 | - | - | - |
| BQI Unit 6 | 9.5982 | 41.6347 | 33.9404 | - | - | - |
| BQPS-II (2 Compressors) | 7.0747 | 30.6886 | - | - | 10.5506 | 45.7659 |
| BQPS-II (1 Compressor) | 6.9546 | 30.1674 | - | - | 10.2890 | 44.6312 |
| BQPS-II (No Compressor) | 6.8385 | 29.6637 | - | - | 10.0400 | 43.5513 |
| BQPS-III | - | 20.6731 | - | 43.3356 | - | - |
| KCCP (3 Compressor) | 7.0088 | 30.4024 | - | N/A | 9.0822 | 39.3964 |
| KCCP (No Compressor) | 6.7622 | 29.3328 | - | 50.7461 | 8.6674 | 37.5977 |
| KGTPS | 7.7456 | 33.5986 | - | - | 8.4202 | 36.5247 |
| SGTPS | 7.7677 | 33.6946 | - | - | 8.4750 | 36.7623 |
| Fuel Prices | 857 | 3,717/ 3,262 | 133,637 | 232.52 | 857 | 3,717 |



16

16/65

ANNEX 1-B: REFERENCE STARTUP CHARGES

I. START-UP CHARGES:

In any Month following the Month in which Start-Ups exceed the allowable number of free Start-Ups in any Agreement Year, the Power Producer shall be entitled to invoice the Offtaker for, and receive from the Offtaker, the charges ("Start-Up Charges") as set forth in Table-I of this Section for each Start-Up in excess of the number of requests shown in Table-2 of this section as free Start-Ups in any Agreement Year. There shall be no Start-Up Charges payable to the Power Producer pursuant to this Section for any Start-Up following a Forced Outage, or Partial Forced Outage (unless such forced or partial forced outage is on account of grid conditions or an Emergency claimed by the Offtaker), Maintenance Outage, Scheduled Outage or Force Majeure Event declared by the Power Producer.

If, at any time after (a) the Power Producer has notified the Control Centre that the Power Producer will initiate the starting sequence following a Start-Up order from the Offtaker, and (b) the Power Producer has actually initiated such sequence and the sequence is subsequently abandoned at the request of the Offtaker, then the initiation of such starting sequence shall be deemed to be a Start-Up; provided however, that a Start-Up shall not be deemed to have occurred if the Power Producer is able to act on such order prior to the initiation of the starting sequence. Any such Start-Up, prior to the Offtaker use of the allowable number of free Start-Ups in any Agreement Year, shall be credited against such allowable number, and, after the Offtaker's use of the allowable number of free Start-Ups in any Agreement Year, Start-Up Charges for any such Start-Up shall be payable by the Offtaker.

Start-Up Charges shall be indexed and adjusted over the Term as provided in Section- 10.

"Start-Up Charge" shall consist of two components and is calculated as follows:

"Start-Up Charge = MDI Charge+ Reference Start-Up"

a) MDI Charge.

The MDI charge shall be based on actual cost charged by the distribution company to the Complex for the maximum demand recorded during the relevant month at startups and shall be calculated based on the then applicable MDI rate in Rs/kW, from time to time, applied to the actual MDI in kW for such startup.

b) Reference Start-Up Charge.

This cost will cover the consumables, fuel and equivalent operating hours consumed for the Start-Ups. This cost will be based on the following table and shall escalate as per the formulas provided for in Section 10.

Table 1: Reference Startup Charges PKR (Gas Fuel)

| Description | Startup Category | | | | | | | | | | | |
|---|------------------|-------------|--------------|-------------|-------------|-------------|-------------|-------------|-------------|-----------|-------------|-------------|
| | Full Complex | | | 3 GT CC | | | 2 GT CC | | | 1 GT CC | | |
| | Hot | Warm | Cold | Hot | Warm | Cold | Hot | Warm | Cold | Hot | Warm | Cold |
| Reference Cost: @ Gas Fuel | | | | | | | | | | | | |
| Backfeed charges (SCPI _{Ref}) – A | 237,529 | 237,529 | 237,529 | 229,781 | 229,781 | 229,781 | 206,721 | 206,721 | 206,721 | 134,788 | 134,788 | 134,788 |
| Fuel gas cost for operation on FSNL – B | 195,701 | 195,701 | 195,701 | 146,776 | 146,776 | 146,776 | 97,850 | 97,850 | 97,850 | 48,925 | 48,925 | 48,925 |
| Fuel cost from GT Synch to ST Synch – C | 3,080,841 | 8,531,560 | 13,034,328 | 2,329,580 | 6,451,145 | 9,855,917 | 1,719,620 | 4,762,025 | 7,275,315 | 1,045,601 | 2,895,510 | 4,423,696 |
| Revenue during Open Cycle Operation (For Net Revenue) – D | (2,943,681) | (8,151,732) | (12,454,036) | (2,207,761) | (6,113,799) | (9,340,527) | (1,471,841) | (4,075,866) | (6,227,018) | (735,920) | (2,037,933) | (3,113,509) |
| Fuel Cost Charges (SCFC _{Ref}) – E = B + C + D | 332,861 | 575,529 | 775,993 | 268,596 | 484,122 | 662,186 | 345,629 | 784,009 | 1,146,147 | 358,606 | 906,502 | 1,359,112 |
| Total Reference Startup Cost (SC _{Ref}) – E = A + E | 570,390 | 813,058 | 1,013,522 | 498,376 | 713,902 | 891,946 | 552,351 | 990,730 | 1,352,869 | 483,383 | 1,041,290 | 1,483,800 |

| Description | Startup Category | | | | | | | | | | | |
|---|------------------|---------|---------|---|-------------|-------------|---|-------------|-------------|--|--|--|
| | 1 GT CC | | | 2 GT CC (When 2 GTs already in CC Mode) | | | 1 GT CC (When 2 GTs already in CC Mode) | | | | | |
| | Hot | Warm | Cold | Hot | Warm | Cold | Hot | Warm | Cold | | | |
| Reference Cost: @ Gas Fuel | | | | | | | | | | | | |
| Backfeed charges (SCPI _{Ref}) – A | 108,623 | 108,623 | 108,623 | 206,721 | 206,721 | 206,721 | 134,788 | 134,788 | 134,788 | | | |
| Fuel gas cost for operation on FSNL – B | 48,925 | 48,925 | 48,925 | 97,850 | 97,850 | 97,850 | 48,925 | 48,925 | 48,925 | | | |
| Fuel cost from GT Synch to ST Synch – C | - | - | - | 1,719,620 | 4,762,025 | 7,275,315 | 1,045,601 | 2,895,510 | 4,423,696 | | | |
| Revenue during Open Cycle Operation (For Net Revenue) – D | - | - | - | (1,153,457) | (3,194,187) | (4,880,009) | (593,402) | (1,643,268) | (2,510,549) | | | |
| Fuel Cost Charges (SCFC _{Ref}) – E = B + C + D | 48,925 | 48,925 | 48,925 | 664,013 | 1,665,688 | 2,493,156 | 501,124 | 1,301,167 | 1,962,072 | | | |
| Total Reference Startup Cost (SC _{Ref}) – E = A + E | 157,548 | 157,548 | 157,548 | 870,735 | 1,872,409 | 2,699,878 | 635,911 | 1,435,954 | 2,096,860 | | | |

Table 1.1: Reference Startup Charges PKR (HSD Fuel)

| Description | Startup Category | | | | | | | | | | | |
|---|------------------|--------------|--------------|-------------|-------------|--------------|-------------|-------------|-------------|-------------|-------------|-------------|
| | Full Complex | | | 3 GT CC | | | 2 GT CC | | | 1 GT CC | | |
| | Hot | Warm | Cold | Hot | Warm | Cold | Hot | Warm | Cold | Hot | Warm | Cold |
| Reference Cost: @ HSD Fuel | | | | | | | | | | | | |
| Backfeed charges (SCPI _{Ref}) – A | 95,929 | 95,929 | 95,929 | 97,204 | 97,204 | 97,204 | 64,892 | 64,892 | 64,892 | 61,754 | 61,754 | 61,754 |
| Fuel gas cost for operation on FSNL – B | 343,106 | 343,106 | 343,106 | 257,330 | 257,330 | 257,330 | 171,553 | 171,553 | 171,553 | 85,777 | 85,777 | 85,777 |
| Fuel cost from GT Synch to ST Synch – C | 5,441,069 | 15,067,576 | 23,019,908 | 4,040,279 | 11,188,464 | 17,093,487 | 2,846,515 | 7,882,658 | 12,042,949 | 1,564,884 | 4,333,524 | 6,620,662 |
| Revenue during Open Cycle Operation (For Net Revenue) – D | (4,166,668) | (11,538,464) | (17,628,209) | (3,125,001) | (8,653,848) | (13,221,157) | (2,083,334) | (5,769,232) | (8,814,105) | (1,041,667) | (2,884,616) | (4,407,052) |
| Fuel Cost Charges (SCFC _{Ref}) – E = B + C + D | 1,817,507 | 3,872,218 | 5,734,805 | 1,172,608 | 2,791,946 | 4,129,660 | 934,734 | 2,284,979 | 3,400,397 | 608,994 | 1,534,685 | 2,299,387 |
| Total Reference Startup Cost (SC _{Ref}) – E = A + E | 1,713,437 | 3,968,147 | 5,830,734 | 1,269,812 | 2,889,150 | 4,226,864 | 999,627 | 2,349,871 | 3,466,280 | 670,748 | 1,596,439 | 2,361,141 |

| Description | Startup Category | | | | | | | | | | | |
|---|------------------|---------|---------|---|-------------|-------------|---|-------------|-------------|--|--|--|
| | 1 GT CC | | | 2 GT CC (When 2 GTs already in CC Mode) | | | 1 GT CC (When 2 GTs already in CC Mode) | | | | | |
| | Hot | Warm | Cold | Hot | Warm | Cold | Hot | Warm | Cold | | | |
| Reference Cost: @ HSD Fuel | | | | | | | | | | | | |
| Backfeed charges (SCPI _{Ref}) – A | 36,374 | 36,374 | 36,374 | 64,892 | 64,892 | 64,892 | 61,754 | 61,754 | 61,754 | | | |
| Fuel gas cost for operation on FSNL – B | 85,777 | 85,777 | 85,777 | 171,553 | 171,553 | 171,553 | 85,777 | 85,777 | 85,777 | | | |
| Fuel cost from GT Synch to ST Synch – C | - | - | - | 2,846,515 | 7,882,658 | 12,042,949 | 1,564,884 | 4,333,524 | 6,620,662 | | | |
| Revenue during Open Cycle Operation (For Net Revenue) – D | - | - | - | (2,107,881) | (5,837,208) | (8,917,957) | (1,081,861) | (2,995,924) | (4,577,106) | | | |
| Fuel Cost Charges (SCFC _{Ref}) – E = B + C + D | 85,777 | 85,777 | 85,777 | 916,187 | 2,217,003 | 3,296,545 | 568,800 | 1,423,377 | 2,129,333 | | | |
| Total Reference Startup Cost (SC _{Ref}) – E = A + E | 122,151 | 122,151 | 122,151 | 975,080 | 2,281,895 | 3,361,438 | 630,553 | 1,486,131 | 2,191,067 | | | |

Table 2: Free Startups per Agreement Year

| Description | Startup Category | | |
|--------------------------------------|------------------|------|------|
| | Hot | Warm | Cold |
| No. of Free Startups for the Complex | 15 | 15 | 3 |

II. BLACK START-UP CHARGES:

If, at any time after (a) the Power Producer has notified the Control Centre that the Power Producer will initiate the starting sequence following a Black Start order from the Offtakers, and (b) the Power Producer has actually initiated such sequence and the sequence is subsequently abandoned at the request of the Offtaker, then the initiation of such starting sequence shall be deemed to be a Black Start-Up; provided however, that a Startup shall not be deemed to have occurred if the Power Producer is able to act on such order prior to the initiation of the starting sequence.

Black Start Charges shall be indexed and adjusted over the Term as provided in Section- 10.

"Black Start Charge" shall consist of two components and is calculated as follows:

"Black Start Charge = MDI Charge + Reference Black Start "

a) MDI Charge.

The MDI charge shall be based on actual cost charged by the distribution company to the Complex for the maximum demand recorded during the relevant month at startups and shall be calculated based on the then applicable MDI rate in Rs/kW, from time to time, applied to the actual MDI in kW for such startup. However, this cost shall be claimed unless the same has not been claimed in Start Up Charges subject to Section 10.

b) Reference Black Start Charge.

This cost will cover the consumables, fuel and equivalent operating hours consumed for the Black Start. This cost will be based on the following table and shall escalate as per the formulas provided for in Section 11.

Table 3: Reference Black Start Charges PKR

| Description | Startup Category | | | |
|---|------------------|-------------|-------------|------------|
| | Unit Startup | | | |
| | Hot | Warm | Cold | Without ST |
| Reference Cost: @ HSD Fuel | | | | |
| Backfeed charges ($BSC_{RefBSDG}$) – A | 29,929 | 29,929 | 29,929 | 29,929 |
| Fuel gas cost for operation on FSNL – B | 85,777 | 85,777 | 85,777 | 85,777 |
| Fuel cost from GT Synch to Dead Bus / Grid Energization – C | 466,273 | 466,273 | 466,273 | 466,273 |
| Fuel cost from GT Synch to ST Synch – D | 1,564,884 | 4,333,524 | 6,620,662 | - |
| Revenue during Open Cycle Operation (For Net Revenue) – E | (1,041,667) | (2,884,616) | (4,407,052) | - |
| Fuel Cost Charges ($BSC_{RefOther}$) – F = B + C + D + E | 1,075,266 | 2,000,958 | 2,765,659 | 552,049 |
| Total Reference Startup Cost (BSC_{Ref}) – G = A + F | 1,105,195 | 2,030,886 | 2,795,588 | 581,978 |

ANNEX 2: PERIOD WEIGHTING FACTORS

The initial PWFs (subject to revision pursuant to Section 5.3 of the Agreement) are as follows:

| Season | Day | Time | Period Weighting Factor |
|--------|--------------|----------|-------------------------|
| Summer | Weekend Days | | |
| | | Peak | 1 |
| | | Off-Peak | 1 |
| | | | |
| | Weekdays | | |
| | | Peak | 1 |
| Winter | Weekend Days | Off-Peak | 1 |
| | | | |
| | | Peak | 1 |
| | | Off-Peak | 1 |
| | Weekdays | | |
| | | Peak | 1 |
| | | Off-Peak | 1 |

Periods are defined as:

Weekdays = 0000 hrs to 2400 hrs on Monday through Saturday
Weekend Days = 0000 hrs to 2400 hrs on Sunday
Peak Period = 1200 hrs to 1700 hrs and 2200 hrs to 0100 hrs
Off -Peak Period = All hours that are not in the "Peak" Period



ANNEX 3: REFERENCE WORKING CAPITAL COMPONENT & INDEXATION MECHANISM

K-Electric Limited
Annexure C: Illustration for Indexation of Working Capital Component (WCC) for the Plant
For the Quarter _____

| Description | Unit | Legend | FY 2024 1st Quarter (Reference) | | | | | |
|---------------------------------|------|-------------|---------------------------------|----------------|----------------|----------------|----------------|----------------|
| | | | BQPS-0 | BQPS-01 (2023) | BQPS-02 (2023) | BQPS-03 (2023) | BQPS-04 (2023) | BQPS-05 (2023) |
| Days applicable for the Quarter | days | A | 92 | 92 | 92 | 92 | 92 | 92 |
| Total days in a year | days | B | 364 | 365 | 365 | 365 | 365 | 365 |
| WACC | % | A2 | 22.91% | 22.91% | 22.91% | 22.91% | 22.91% | 22.91% |
| Summ | % | B1 | 2.80% | 2.80% | 2.80% | 2.80% | 2.80% | 2.80% |
| Total | % | C = A2 + B1 | 24.91% | 24.91% | 24.91% | 24.91% | 24.91% | 24.91% |

1. Cost of Borrowing

| | | | | | | | | |
|---------------------------------|------|-------------|--------|--------|--------|--------|--------|--------|
| Days applicable for the Quarter | days | A | 92 | 92 | 92 | 92 | 92 | 92 |
| Total days in a year | days | B | 364 | 365 | 365 | 365 | 365 | 365 |
| WACC | % | A2 | 22.91% | 22.91% | 22.91% | 22.91% | 22.91% | 22.91% |
| Summ | % | B1 | 2.80% | 2.80% | 2.80% | 2.80% | 2.80% | 2.80% |
| Total | % | C = A2 + B1 | 24.91% | 24.91% | 24.91% | 24.91% | 24.91% | 24.91% |

2. Fixed cost (Non-variable costs)

| | | | | | | | | |
|----------------|------|-----------|----|----|----|----|----|----|
| Receipt - days | days | D | 26 | 26 | 26 | 26 | 26 | 26 |
| Payment - days | days | E | 7 | 7 | 7 | 7 | 7 | 7 |
| Net days | days | F = D - E | 20 | 20 | 20 | 20 | 20 | 20 |

3. WACC

| | | | | | | | | |
|-----------------------------------|--------|--|--------|--------|--------|--------|-------|-------|
| Net capacity | MW | G | 88 | 408 | 408 | 221 | 82 | 82 |
| Load factor | % | H | 47% | 50% | 50% | 20% | 20% | 20% |
| Units for 365 days | GWh | I = G x H x 24 x 365 x 10 ³ | 7,968 | 2,648 | 2,648 | 347 | 381 | 382 |
| Allowed Heat Rate for the Quarter | kJ/kWh | J | 8,286 | 6,286 | 6,286 | 6,176 | 6,068 | 6,064 |
| Amount for 365 days | MWh | K = I x J x 10 ³ / 365 | 88,274 | 76,207 | 75,389 | 11,762 | 5,439 | 5,474 |
| Amount for outstanding days | MWh | L = F x K / 365 | 6,626 | 4,619 | 4,619 | 761 | 341 | 345 |
| Sales tax at 18% | % | M = 18% | 28% | 28% | 28% | 18% | 18% | 18% |
| Amount including Sales Tax | MWh | N = L x (1 + M) | 6,626 | 5,951 | 5,951 | 875 | 400 | 407 |
| Cost of working capital | MWh | O = N x C x 365 | 437 | 242 | 243 | 86 | 28 | 28 |

Indexation / Actualization

This will be updated based on actual days for the relevant quarter.
WACC to be based on actual calendar days including impact of Leap Year where applicable.
WACC to be updated as per the Latest 3 - Month BQPS published by SPP on the last day of the previous Quarter.

Taken as 30 Days.
Should be updated as per WACC based on cost of each Fuel type in the preceding quarter and their respective Payable Days each day.

Should be updated as per WACC Dispatch Factor based on cost of each Fuel Type in the preceding quarter.
WACC Heat Rate based on cost of the Heat Rate with applicable Depreciation and Part Load of the previous quarter.
WACC Fuel Price based on cost of the Fuel Price as used in Fuel Price Indexation for the previous quarter.
Sales Tax will be updated as per applicable Laws.

K-Electric Limited
Annexure C: Illustration for Indexation of Working Capital Component (WCC) for the Plant
For the Quarter _____

| Description | Unit | Legend | FY 2024 1st Quarter (Reference) | | | | | |
|---|---------|---------------------------------|---------------------------------|----------------|----------------|----------------|----------------|----------------|
| | | | BQPS-0 | BQPS-01 (2023) | BQPS-02 (2023) | BQPS-03 (2023) | BQPS-04 (2023) | BQPS-05 (2023) |
| Daily gas | MWh/day | Q = G x 1.288 / 10 ³ | 57,889 | 68,884 | 68,884 | 42,541 | 19,887 | 19,871 |
| 90 days | MWh/day | R = Q x 90 | 5,210,010 | 6,200,000 | 6,200,000 | 3,828,690 | 1,789,830 | 1,788,390 |
| Amount of 90 days | MWh/day | S = R x 1.288 / 10 ³ | 21,854 | 13,389 | 13,389 | 9,889 | 4,464 | 4,489 |
| Actual SBLC given | MWh/day | T | 2,118 | 9,361 | 9,361 | 900 | 432 | 436 |
| Lower of 90 days or Actual | MWh/day | U = Lower of S or T | 2,118 | 9,361 | 9,361 | 900 | 432 | 436 |
| SBLC cost at 1% | % | V | 1.80% | 1.80% | 1.80% | 1.20% | 1.80% | 1.80% |
| Maximum Allowed Cost | MWh/day | W = U x V | 5 | 8 | 8 | 2 | 1 | 1 |
| Actual Cost | MWh/day | X | 3 | 5 | 5 | 1 | 1 | 1 |
| Lower of Maximum allowed or actual cost of SBLC | MWh/day | Y = Lower of W or X | 3 | 5 | 5 | 1 | 1 | 1 |

4. Sales of SBLC

| | | | | | | | | |
|---|-----------|--|------------|------------|------------|-----------|--|--|
| SBLC Price | MWh / day | Z | 228 | 228 | 228 | 228 | | |
| GST | % | A6 | 28% | 28% | 28% | 28% | | |
| SBLC Price including GST | MWh / day | A6 + Z x (1 + A6) | 293 | 293 | 293 | 293 | | |
| Net Capacity | MWh | A7 | 88 | 367 | 367 | 228 | | |
| Capacity value | MWh / day | A8 | 26,282 | 26,282 | 26,282 | 26,282 | | |
| SBLC Price | MWh / day | A9 = Z / A7 x 10 ³ | 6,414 | 6,414 | 6,414 | 6,414 | | |
| Allowed Heat Rate for the Quarter | kJ/kWh | A9 | 6,621 | 6,289 | 6,289 | 7,812 | | |
| Lower for 7 days | MWh | A9 = A7 x 1000 x 24 x 7 / A7 x 10 ³ | 17,349,680 | 17,349,680 | 17,349,680 | 8,984,880 | | |
| Amount for 7 days of Fuel Inventory - Maximum Allowed Inventory | MWh/day | A10 = A9 x A7 / 10 ³ | 4,759 | 8,889 | 8,889 | 2,213 | | |
| Actual Amount of Fuel Inventory | MWh/day | A11 | 8 | 8 | 8 | 2,213 | | |
| Lower of Actual or Maximum Allowed Fuel Inventory Levels | MWh/day | A12 = Min(A10, A11) | 8 | 8 | 8 | 2,213 | | |
| Cost of SBLC | MWh/day | A12 = A12 x Z | 8 | 8 | 8 | 138 | | |

Indexation / Actualization

WACC to be updated based on actual SBLC cost at the close of previous quarter.

WACC to be updated based on actual cost of SBLC based on SBLC cost at close of previous quarter.

WACC to be updated based on the Closing Fuel Price as of Last day of previous quarter.
Sales Tax will be updated as per applicable Laws.
Should be updated as per actual on quarterly basis.
WACC Heat Rate based on cost of the Heat Rate with applicable Depreciation and Part Load of the previous quarter.
WACC to be updated as per actual at the close of previous quarter.

Handwritten signature

Handwritten signature

5- Shorter Method
Amounts to be used for Indication of Working Capital Component (WCC) for the Plant
for the Quarter _____

| Item/Item | Unit | Symbol | Q1/20 | Q2/20 | Q3/20 | Q4/20 | Q1/21 | Q2/21 | Q3/21 | Q4/21 | Calculation / Indication |
|-----------------------------------|--------|-------------------------------------|--------|--------|--------|--------|--------|--------|-------|-------|---|
| 1. Cost of other inventory | | | | | | | | | | | |
| Inventory received | USD/ha | RL | 2,897 | 2,376 | 2,376 | 1,364 | 287 | 483 | | | Will be updated upon arrival at the close of previous quarter |
| Cost | USD/ha | $AP \times RL \times C$ | 356 | 348 | 348 | 48 | 34 | 37 | | | - |
| Subtotal of inventory received | USD/ha | $RL \times P + Y + RL \times C$ | 356 | 483 | 483 | 384 | 32 | 55 | | | - |
| Stock Capacity (ha) | ha | nd | 485 | 485 | 485 | 231 | 98 | 98 | | | - |
| Order for the quarter | ha | $AP \times RL \times C \times 1000$ | 1,682 | 588 | 588 | 488 | 388 | 388 | | | Will also be updated based on order days for the relevant quarter |
| Stock Capacity (ha) | ha | nd | 485 | 287 | 287 | 270 | 104 | 104 | | | - |
| Order for the quarter | ha | $AP \times RL \times C \times 1000$ | 1,682 | 788 | 788 | 444 | 344 | 344 | | | This will be updated based on order days for the relevant quarter |
| Working Capital Component | | | | | | | | | | | |
| WCC | USD/ha | $RL \times AP \times C$ | 0.5843 | 0.4889 | 0.4889 | 0.4422 | 0.4448 | 0.4448 | | | |
| WCC | USD/ha | $AP \times RL \times C$ | 0.6376 | 0.6377 | 0.6377 | 0.5442 | 0.5442 | 0.5442 | | | |

Note:
 Calculations for Cost of WCC inventory for plants other than WCCP's indicative only as the same process as allowed by the Authority for WCCP. However the actual response will be requested to Quarterly Indicators post WCC-Commitment of the relevant Plant and approval of WCCP regarding One Time Adjustment in the Working Capital Component for the same.

Ray

AY

**ANNEX 4-A: KCCPP HEAT RATE DEGRADATION TABLES – GAS
(COMBINED & SIMPLE CYCLE)**

**ANNEX 4-B: KCCPP HEAT RATE DEGRADATION TABLES – HSD
(COMBINED & SIMPLE CYCLE)**

**ANNEX 4-C: KCCPP OUTPUT DEGRADATION TABLES – GAS
(COMBINED & SIMPLE CYCLE)**

**ANNEX 4-D: KCCPP OUTPUT DEGRADATION TABLES – HSD
(COMBINED & SIMPLE CYCLE)**


ANNEX 5-A: KCCPP PART LOAD TABLE – GAS (COMBINED CYCLE)

ANNEX 5-B: KCCPP PART LOAD TABLE – GAS (SIMPLE CYCLE)

ANNEX 5-C: KCCPP PART LOAD TABLE – HSD (COMBINED CYCLE)

ANNEX 5-D: KCCPP PART LOAD TABLE – HSD (SIMPLE CYCLE)

**ANNEX 6-A: START UP & BLACK START COST VERIFIED BY NESPAK –
GAS & HSD**



Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|-------------------|-------------------|---------|-------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| FY-19 (Test) | 32.20% | 32.20% | 1.0000 | 41.72% | 41.72% | 1.0000 |
| FY-23 (end) | 32.20% | 31.59% | 1.0193 | 41.72% | 41.10% | 1.0152 |
| +500 | 32.20% | 31.57% | 1.0198 | 41.72% | 41.08% | 1.0156 |
| +1000 | 32.20% | 31.56% | 1.0202 | 41.72% | 41.06% | 1.0160 |
| +1500 | 32.20% | 31.54% | 1.0207 | 41.72% | 41.05% | 1.0164 |
| +2000 | 32.20% | 31.53% | 1.0212 | 41.72% | 41.03% | 1.0168 |
| +2500 | 32.20% | 31.51% | 1.0217 | 41.72% | 41.01% | 1.0173 |
| +3000 | 32.20% | 31.50% | 1.0222 | 41.72% | 41.00% | 1.0177 |
| +3500 | 32.20% | 32.61% | 0.9874 | 41.72% | 41.29% | 1.0105 |
| +4000 | 32.20% | 32.51% | 0.9905 | 41.72% | 41.28% | 1.0108 |
| +4500 | 32.20% | 32.41% | 0.9935 | 41.72% | 41.27% | 1.0111 |
| +5000 | 32.20% | 32.31% | 0.9966 | 41.72% | 41.25% | 1.0113 |
| +5500 | 32.20% | 32.21% | 0.9996 | 41.72% | 41.24% | 1.0116 |
| +6000 | 32.20% | 32.11% | 1.0027 | 41.72% | 41.23% | 1.0119 |
| +6500 | 32.20% | 32.01% | 1.0057 | 41.72% | 41.22% | 1.0122 |
| +7000 | 32.20% | 31.92% | 1.0088 | 41.72% | 41.21% | 1.0124 |
| +7500 | 32.20% | 31.82% | 1.0118 | 41.72% | 41.20% | 1.0127 |
| +8000 | 32.20% | 31.72% | 1.0149 | 41.72% | 41.19% | 1.0130 |
| +8500 | 32.20% | 31.69% | 1.0161 | 41.72% | 41.18% | 1.0133 |
| +9000 | 32.20% | 31.67% | 1.0165 | 41.72% | 41.16% | 1.0136 |
| +9500 | 32.20% | 31.66% | 1.0169 | 41.72% | 41.15% | 1.0139 |
| +10000 | 32.20% | 31.65% | 1.0173 | 41.72% | 41.14% | 1.0142 |
| +10500 | 32.20% | 31.64% | 1.0177 | 41.72% | 41.13% | 1.0145 |
| +11000 | 32.20% | 31.63% | 1.0180 | 41.72% | 41.11% | 1.0148 |
| +11500 | 32.20% | 31.61% | 1.0184 | 41.72% | 41.10% | 1.0151 |
| +12000 | 32.20% | 31.60% | 1.0188 | 41.72% | 41.09% | 1.0154 |
| +12500 | 32.20% | 31.59% | 1.0192 | 41.72% | 41.08% | 1.0157 |
| +13000 | 32.20% | 31.58% | 1.0196 | 41.72% | 41.07% | 1.0160 |
| +13500 | 32.20% | 31.57% | 1.0199 | 41.72% | 41.06% | 1.0162 |
| +14000 | 32.20% | 31.56% | 1.0202 | 41.72% | 41.05% | 1.0165 |
| +14500 | 32.20% | 31.55% | 1.0205 | 41.72% | 41.04% | 1.0167 |
| +15000 | 32.20% | 31.54% | 1.0208 | 41.72% | 41.03% | 1.0170 |
| +15500 | 32.20% | 31.53% | 1.0212 | 41.72% | 41.02% | 1.0172 |
| +16000 | 32.20% | 31.52% | 1.0215 | 41.72% | 41.01% | 1.0175 |
| +16500 | 32.20% | 31.51% | 1.0218 | 41.72% | 41.00% | 1.0177 |
| +17000 | 32.20% | 31.50% | 1.0221 | 41.72% | 40.98% | 1.0180 |
| +17500 | 32.20% | 31.49% | 1.0224 | 41.72% | 40.97% | 1.0182 |
| +18000 | 32.20% | 31.48% | 1.0227 | 41.72% | 40.96% | 1.0185 |
| +18500 | 32.20% | 31.47% | 1.0230 | 41.72% | 40.96% | 1.0187 |



Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| +19000 | 32.20% | 31.47% | 1.0232 | 41.72% | 40.95% | 1.0189 |
| +19500 | 32.20% | 31.46% | 1.0234 | 41.72% | 40.94% | 1.0191 |
| +20000 | 32.20% | 31.45% | 1.0236 | 41.72% | 40.93% | 1.0193 |
| +20500 | 32.20% | 31.45% | 1.0239 | 41.72% | 40.93% | 1.0195 |
| +21000 | 32.20% | 31.44% | 1.0241 | 41.72% | 40.92% | 1.0196 |
| +21500 | 32.20% | 31.43% | 1.0243 | 41.72% | 40.91% | 1.0198 |
| +22000 | 32.20% | 31.43% | 1.0245 | 41.72% | 40.90% | 1.0200 |
| +22500 | 32.20% | 31.42% | 1.0248 | 41.72% | 40.90% | 1.0202 |
| +23000 | 32.20% | 31.41% | 1.0250 | 41.72% | 40.89% | 1.0204 |
| +23500 | 32.20% | 31.41% | 1.0252 | 41.72% | 40.88% | 1.0206 |
| +24000 | 32.20% | 31.40% | 1.0254 | 41.72% | 40.87% | 1.0208 |
| +24500 | 32.20% | 31.39% | 1.0256 | 41.72% | 40.87% | 1.0209 |
| +25000 | 32.20% | 31.39% | 1.0258 | 41.72% | 40.86% | 1.0211 |
| +25500 | 32.20% | 31.38% | 1.0261 | 41.72% | 40.85% | 1.0213 |
| +26000 | 32.20% | 31.37% | 1.0263 | 41.72% | 40.85% | 1.0215 |
| +26500 | 32.20% | 31.37% | 1.0265 | 41.72% | 40.84% | 1.0216 |
| +27000 | 32.20% | 31.36% | 1.0267 | 41.72% | 40.83% | 1.0218 |
| +27500 | 32.20% | 31.35% | 1.0269 | 41.72% | 40.82% | 1.0220 |
| +28000 | 32.20% | 31.35% | 1.0271 | 41.72% | 40.82% | 1.0222 |
| +28500 | 32.20% | 32.65% | 0.9861 | 41.72% | 42.01% | 0.9931 |
| +29000 | 32.20% | 32.62% | 0.9872 | 41.72% | 41.98% | 0.9939 |
| +29500 | 32.20% | 32.58% | 0.9882 | 41.72% | 41.95% | 0.9946 |
| +30000 | 32.20% | 32.54% | 0.9893 | 41.72% | 41.92% | 0.9953 |
| +30500 | 32.20% | 32.51% | 0.9904 | 41.72% | 41.89% | 0.9961 |
| +31000 | 32.20% | 32.47% | 0.9915 | 41.72% | 41.86% | 0.9968 |
| +31500 | 32.20% | 32.44% | 0.9925 | 41.72% | 41.83% | 0.9975 |
| +32000 | 32.20% | 32.40% | 0.9936 | 41.72% | 41.79% | 0.9983 |
| +32500 | 32.20% | 32.37% | 0.9947 | 41.72% | 41.76% | 0.9990 |
| +33000 | 32.20% | 32.33% | 0.9957 | 41.72% | 41.73% | 0.9997 |
| +33500 | 32.20% | 32.30% | 0.9967 | 41.72% | 41.71% | 1.0004 |
| +34000 | 32.20% | 32.28% | 0.9975 | 41.72% | 41.68% | 1.0010 |
| +34500 | 32.20% | 32.25% | 0.9984 | 41.72% | 41.65% | 1.0016 |
| +35000 | 32.20% | 32.22% | 0.9992 | 41.72% | 41.63% | 1.0023 |
| +35500 | 32.20% | 32.19% | 1.0001 | 41.72% | 41.60% | 1.0029 |
| +36000 | 32.20% | 32.17% | 1.0009 | 41.72% | 41.58% | 1.0035 |
| +36500 | 32.20% | 32.14% | 1.0018 | 41.72% | 41.55% | 1.0041 |
| +37000 | 32.20% | 32.11% | 1.0026 | 41.72% | 41.52% | 1.0048 |
| +37500 | 32.20% | 32.09% | 1.0035 | 41.72% | 41.50% | 1.0054 |
| +38000 | 32.20% | 32.06% | 1.0043 | 41.72% | 41.47% | 1.0060 |
| +38500 | 32.20% | 32.03% | 1.0051 | 41.72% | 41.45% | 1.0065 |

(Signature)



(Signature)

(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| +39000 | 32.20% | 32.01% | 1.0058 | 41.72% | 41.44% | 1.0069 |
| +39500 | 32.20% | 31.99% | 1.0065 | 41.72% | 41.42% | 1.0073 |
| +40000 | 32.20% | 31.97% | 1.0072 | 41.72% | 41.40% | 1.0077 |
| +40500 | 32.20% | 31.94% | 1.0079 | 41.72% | 41.39% | 1.0081 |
| +41000 | 32.20% | 31.92% | 1.0086 | 41.72% | 41.37% | 1.0085 |
| +41500 | 32.20% | 31.90% | 1.0093 | 41.72% | 41.35% | 1.0089 |
| +42000 | 32.20% | 31.88% | 1.0100 | 41.72% | 41.34% | 1.0093 |
| +42500 | 32.20% | 31.86% | 1.0107 | 41.72% | 41.32% | 1.0098 |
| +43000 | 32.20% | 31.83% | 1.0114 | 41.72% | 41.30% | 1.0102 |
| +43500 | 32.20% | 31.81% | 1.0120 | 41.72% | 41.29% | 1.0105 |
| +44000 | 32.20% | 31.80% | 1.0126 | 41.72% | 41.27% | 1.0108 |
| +44500 | 32.20% | 31.78% | 1.0132 | 41.72% | 41.26% | 1.0112 |
| +45000 | 32.20% | 31.76% | 1.0138 | 41.72% | 41.25% | 1.0115 |
| +45500 | 32.20% | 31.74% | 1.0144 | 41.72% | 41.23% | 1.0118 |
| +46000 | 32.20% | 31.72% | 1.0149 | 41.72% | 41.22% | 1.0121 |
| +46500 | 32.20% | 31.70% | 1.0155 | 41.72% | 41.21% | 1.0125 |
| +47000 | 32.20% | 31.69% | 1.0161 | 41.72% | 41.19% | 1.0128 |
| +47500 | 32.20% | 31.67% | 1.0167 | 41.72% | 41.18% | 1.0131 |
| +48000 | 32.20% | 31.65% | 1.0173 | 41.72% | 41.17% | 1.0135 |
| +48500 | 32.20% | 31.63% | 1.0178 | 41.72% | 41.15% | 1.0139 |
| +49000 | 32.20% | 31.62% | 1.0183 | 41.72% | 41.13% | 1.0143 |
| +49500 | 32.20% | 31.60% | 1.0188 | 41.72% | 41.12% | 1.0147 |
| +50000 | 32.20% | 31.59% | 1.0193 | 41.72% | 41.10% | 1.0152 |
| +50500 | 32.20% | 31.57% | 1.0198 | 41.72% | 41.08% | 1.0156 |
| +51000 | 32.20% | 31.56% | 1.0202 | 41.72% | 41.06% | 1.0161 |
| +51500 | 32.20% | 31.54% | 1.0207 | 41.72% | 41.04% | 1.0165 |
| +52000 | 32.20% | 31.53% | 1.0212 | 41.72% | 41.03% | 1.0170 |
| +52500 | 32.20% | 31.51% | 1.0217 | 41.72% | 41.01% | 1.0174 |
| +53000 | 32.20% | 31.50% | 1.0222 | 41.72% | 40.99% | 1.0178 |
| +53500 | 32.20% | 32.61% | 0.9874 | 41.72% | 41.28% | 1.0107 |
| +54000 | 32.20% | 32.51% | 0.9905 | 41.72% | 41.27% | 1.0110 |
| +54500 | 32.20% | 32.41% | 0.9935 | 41.72% | 41.25% | 1.0113 |
| +55000 | 32.20% | 32.31% | 0.9966 | 41.72% | 41.24% | 1.0116 |
| +55500 | 32.20% | 32.21% | 0.9996 | 41.72% | 41.23% | 1.0119 |
| +56000 | 32.20% | 32.11% | 1.0027 | 41.72% | 41.22% | 1.0123 |
| +56500 | 32.20% | 32.01% | 1.0057 | 41.72% | 41.20% | 1.0126 |
| +57000 | 32.20% | 31.92% | 1.0088 | 41.72% | 41.19% | 1.0129 |
| +57500 | 32.20% | 31.82% | 1.0118 | 41.72% | 41.18% | 1.0132 |
| +58000 | 32.20% | 31.72% | 1.0149 | 41.72% | 41.17% | 1.0135 |
| +58500 | 32.20% | 31.69% | 1.0161 | 41.72% | 41.15% | 1.0138 |



Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|-------------------|-------------------|---------|-------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| +59000 | 32.20% | 31.67% | 1.0165 | 41.72% | 41.14% | 1.0141 |
| +59500 | 32.20% | 31.66% | 1.0169 | 41.72% | 41.13% | 1.0144 |
| +60000 | 32.20% | 31.65% | 1.0173 | 41.72% | 41.12% | 1.0147 |
| +60500 | 32.20% | 31.64% | 1.0177 | 41.72% | 41.10% | 1.0150 |
| +61000 | 32.20% | 31.63% | 1.0180 | 41.72% | 41.09% | 1.0153 |
| +61500 | 32.20% | 31.61% | 1.0184 | 41.72% | 41.08% | 1.0156 |
| +62000 | 32.20% | 31.60% | 1.0188 | 41.72% | 41.07% | 1.0159 |
| +62500 | 32.20% | 31.59% | 1.0192 | 41.72% | 41.06% | 1.0162 |
| +63000 | 32.20% | 31.58% | 1.0196 | 41.72% | 41.04% | 1.0166 |
| +63500 | 32.20% | 31.57% | 1.0199 | 41.72% | 41.03% | 1.0168 |
| +64000 | 32.20% | 31.56% | 1.0202 | 41.72% | 41.02% | 1.0171 |
| +64500 | 32.20% | 31.55% | 1.0205 | 41.72% | 41.01% | 1.0173 |
| +65000 | 32.20% | 31.54% | 1.0208 | 41.72% | 41.00% | 1.0176 |
| +65500 | 32.20% | 31.53% | 1.0212 | 41.72% | 40.99% | 1.0178 |
| +66000 | 32.20% | 31.52% | 1.0215 | 41.72% | 40.98% | 1.0181 |
| +66500 | 32.20% | 31.51% | 1.0218 | 41.72% | 40.97% | 1.0184 |
| +67000 | 32.20% | 31.50% | 1.0221 | 41.72% | 40.96% | 1.0186 |
| +67500 | 32.20% | 31.49% | 1.0224 | 41.72% | 40.95% | 1.0189 |
| +68000 | 32.20% | 31.48% | 1.0227 | 41.72% | 40.94% | 1.0191 |
| +68500 | 32.20% | 31.47% | 1.0230 | 41.72% | 40.93% | 1.0193 |
| +69000 | 32.20% | 31.47% | 1.0232 | 41.72% | 40.92% | 1.0195 |
| +69500 | 32.20% | 31.46% | 1.0234 | 41.72% | 40.92% | 1.0197 |
| +70000 | 32.20% | 31.45% | 1.0236 | 41.72% | 40.91% | 1.0199 |
| +70500 | 32.20% | 31.45% | 1.0239 | 41.72% | 40.90% | 1.0201 |
| +71000 | 32.20% | 31.44% | 1.0241 | 41.72% | 40.89% | 1.0203 |
| +71500 | 32.20% | 31.43% | 1.0243 | 41.72% | 40.88% | 1.0205 |
| +72000 | 32.20% | 31.43% | 1.0245 | 41.72% | 40.88% | 1.0207 |
| +72500 | 32.20% | 31.42% | 1.0248 | 41.72% | 40.87% | 1.0209 |
| +73000 | 32.20% | 31.41% | 1.0250 | 41.72% | 40.86% | 1.0211 |
| +73500 | 32.20% | 31.41% | 1.0252 | 41.72% | 40.85% | 1.0212 |
| +74000 | 32.20% | 31.40% | 1.0254 | 41.72% | 40.85% | 1.0214 |
| +74500 | 32.20% | 31.39% | 1.0256 | 41.72% | 40.84% | 1.0216 |
| +75000 | 32.20% | 31.39% | 1.0258 | 41.72% | 40.83% | 1.0218 |
| +75500 | 32.20% | 31.38% | 1.0261 | 41.72% | 40.82% | 1.0220 |
| +76000 | 32.20% | 31.37% | 1.0263 | 41.72% | 40.82% | 1.0222 |
| +76500 | 32.20% | 31.37% | 1.0265 | 41.72% | 40.81% | 1.0223 |
| +77000 | 32.20% | 31.36% | 1.0267 | 41.72% | 40.80% | 1.0225 |
| +77500 | 32.20% | 31.35% | 1.0269 | 41.72% | 40.80% | 1.0227 |
| +78000 | 32.20% | 31.35% | 1.0271 | 41.72% | 40.79% | 1.0229 |
| +78500 | 32.20% | 32.65% | 0.9861 | 41.72% | 41.98% | 0.9938 |



Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| +79000 | 32.20% | 32.62% | 0.9872 | 41.72% | 41.95% | 0.9945 |
| +79500 | 32.20% | 32.58% | 0.9882 | 41.72% | 41.92% | 0.9953 |
| +80000 | 32.20% | 32.54% | 0.9893 | 41.72% | 41.89% | 0.9960 |
| +80500 | 32.20% | 32.51% | 0.9904 | 41.72% | 41.86% | 0.9967 |
| +81000 | 32.20% | 32.47% | 0.9915 | 41.72% | 41.83% | 0.9975 |
| +81500 | 32.20% | 32.44% | 0.9925 | 41.72% | 41.80% | 0.9982 |
| +82000 | 32.20% | 32.40% | 0.9936 | 41.72% | 41.77% | 0.9990 |
| +82500 | 32.20% | 32.37% | 0.9947 | 41.72% | 41.73% | 0.9997 |
| +83000 | 32.20% | 32.33% | 0.9957 | 41.72% | 41.70% | 1.0005 |
| +83500 | 32.20% | 32.30% | 0.9967 | 41.72% | 41.68% | 1.0011 |
| +84000 | 32.20% | 32.28% | 0.9975 | 41.72% | 41.65% | 1.0018 |
| +84500 | 32.20% | 32.25% | 0.9984 | 41.72% | 41.62% | 1.0024 |
| +85000 | 32.20% | 32.22% | 0.9992 | 41.72% | 41.60% | 1.0030 |
| +85500 | 32.20% | 32.19% | 1.0001 | 41.72% | 41.57% | 1.0037 |
| +86000 | 32.20% | 32.17% | 1.0009 | 41.72% | 41.54% | 1.0043 |
| +86500 | 32.20% | 32.14% | 1.0018 | 41.72% | 41.52% | 1.0050 |
| +87000 | 32.20% | 32.11% | 1.0026 | 41.72% | 41.49% | 1.0056 |
| +87500 | 32.20% | 32.09% | 1.0035 | 41.72% | 41.46% | 1.0062 |
| +88000 | 32.20% | 32.06% | 1.0043 | 41.72% | 41.44% | 1.0069 |
| +88500 | 32.20% | 32.03% | 1.0051 | 41.72% | 41.41% | 1.0075 |
| +89000 | 32.20% | 32.01% | 1.0058 | 41.72% | 41.39% | 1.0080 |
| +89500 | 32.20% | 31.99% | 1.0065 | 41.72% | 41.37% | 1.0085 |
| +90000 | 32.20% | 31.97% | 1.0072 | 41.72% | 41.35% | 1.0090 |
| +90500 | 32.20% | 31.94% | 1.0079 | 41.72% | 41.33% | 1.0096 |
| +91000 | 32.20% | 31.92% | 1.0086 | 41.72% | 41.31% | 1.0101 |
| +91500 | 32.20% | 31.90% | 1.0093 | 41.72% | 41.28% | 1.0106 |
| +92000 | 32.20% | 31.88% | 1.0100 | 41.72% | 41.26% | 1.0111 |
| +92500 | 32.20% | 31.86% | 1.0107 | 41.72% | 41.24% | 1.0117 |
| +93000 | 32.20% | 31.83% | 1.0114 | 41.72% | 41.22% | 1.0122 |
| +93500 | 32.20% | 31.81% | 1.0120 | 41.72% | 41.20% | 1.0127 |
| +94000 | 32.20% | 31.80% | 1.0126 | 41.72% | 41.18% | 1.0131 |
| +94500 | 32.20% | 31.78% | 1.0132 | 41.72% | 41.16% | 1.0136 |
| +95000 | 32.20% | 31.76% | 1.0138 | 41.72% | 41.15% | 1.0140 |
| +95500 | 32.20% | 31.74% | 1.0144 | 41.72% | 41.13% | 1.0145 |
| +96000 | 32.20% | 31.72% | 1.0149 | 41.72% | 41.11% | 1.0149 |
| +96500 | 32.20% | 31.70% | 1.0155 | 41.72% | 41.09% | 1.0153 |
| +97000 | 32.20% | 31.69% | 1.0161 | 41.72% | 41.07% | 1.0158 |
| +97500 | 32.20% | 31.67% | 1.0167 | 41.72% | 41.06% | 1.0162 |
| +98000 | 32.20% | 31.65% | 1.0173 | 41.72% | 41.04% | 1.0167 |
| +98500 | 32.20% | 31.63% | 1.0178 | 41.72% | 41.02% | 1.0170 |



Handwritten signature/initials.

Handwritten signature/initials.

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| +99000 | 32.20% | 31.62% | 1.0183 | 41.72% | 41.01% | 1.0173 |
| +99500 | 32.20% | 31.60% | 1.0188 | 41.72% | 41.00% | 1.0176 |
| +100000 | 32.20% | 31.59% | 1.0193 | 41.72% | 40.99% | 1.0179 |
| +100500 | 32.20% | 31.57% | 1.0198 | 41.72% | 40.98% | 1.0182 |
| +101000 | 32.20% | 31.56% | 1.0202 | 41.72% | 40.96% | 1.0185 |
| +101500 | 32.20% | 31.54% | 1.0207 | 41.72% | 40.95% | 1.0188 |
| +102000 | 32.20% | 31.53% | 1.0212 | 41.72% | 40.94% | 1.0191 |
| +102500 | 32.20% | 31.51% | 1.0217 | 41.72% | 40.93% | 1.0194 |
| +103000 | 32.20% | 31.50% | 1.0222 | 41.72% | 40.92% | 1.0197 |
| +103500 | 32.20% | 32.61% | 0.9874 | 41.72% | 41.21% | 1.0124 |
| +104000 | 32.20% | 32.51% | 0.9905 | 41.72% | 41.20% | 1.0126 |
| +104500 | 32.20% | 32.41% | 0.9935 | 41.72% | 41.20% | 1.0128 |
| +105000 | 32.20% | 32.31% | 0.9966 | 41.72% | 41.19% | 1.0129 |
| +105500 | 32.20% | 32.21% | 0.9996 | 41.72% | 41.18% | 1.0131 |
| +106000 | 32.20% | 32.11% | 1.0027 | 41.72% | 41.17% | 1.0133 |
| +106500 | 32.20% | 32.01% | 1.0057 | 41.72% | 41.17% | 1.0135 |
| +107000 | 32.20% | 31.92% | 1.0088 | 41.72% | 41.16% | 1.0137 |
| +107500 | 32.20% | 31.82% | 1.0118 | 41.72% | 41.15% | 1.0139 |
| +108000 | 32.20% | 31.72% | 1.0149 | 41.72% | 41.14% | 1.0141 |
| +108500 | 32.20% | 31.69% | 1.0161 | 41.72% | 41.13% | 1.0144 |
| +109000 | 32.20% | 31.67% | 1.0165 | 41.72% | 41.12% | 1.0148 |
| +109500 | 32.20% | 31.66% | 1.0169 | 41.72% | 41.10% | 1.0151 |
| +110000 | 32.20% | 31.65% | 1.0173 | 41.72% | 41.09% | 1.0155 |
| +110500 | 32.20% | 31.64% | 1.0177 | 41.72% | 41.07% | 1.0158 |
| +111000 | 32.20% | 31.63% | 1.0180 | 41.72% | 41.06% | 1.0162 |
| +111500 | 32.20% | 31.61% | 1.0184 | 41.72% | 41.04% | 1.0165 |
| +112000 | 32.20% | 31.60% | 1.0188 | 41.72% | 41.03% | 1.0169 |
| +112500 | 32.20% | 31.59% | 1.0192 | 41.72% | 41.02% | 1.0172 |
| +113000 | 32.20% | 31.58% | 1.0196 | 41.72% | 41.00% | 1.0176 |
| +113500 | 32.20% | 31.57% | 1.0199 | 41.72% | 40.99% | 1.0179 |
| +114000 | 32.20% | 31.56% | 1.0202 | 41.72% | 40.98% | 1.0182 |
| +114500 | 32.20% | 31.55% | 1.0205 | 41.72% | 40.96% | 1.0185 |
| +115000 | 32.20% | 31.54% | 1.0208 | 41.72% | 40.95% | 1.0188 |
| +115500 | 32.20% | 31.53% | 1.0212 | 41.72% | 40.94% | 1.0191 |
| +116000 | 32.20% | 31.52% | 1.0215 | 41.72% | 40.93% | 1.0194 |
| +116500 | 32.20% | 31.51% | 1.0218 | 41.72% | 40.92% | 1.0197 |
| +117000 | 32.20% | 31.50% | 1.0221 | 41.72% | 40.91% | 1.0200 |
| +117500 | 32.20% | 31.49% | 1.0224 | 41.72% | 40.89% | 1.0203 |
| +118000 | 32.20% | 31.48% | 1.0227 | 41.72% | 40.88% | 1.0206 |
| +118500 | 32.20% | 31.47% | 1.0230 | 41.72% | 40.87% | 1.0208 |



Handwritten signature/initials.

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| +119000 | 32.20% | 31.47% | 1.0232 | 41.72% | 40.86% | 1.0210 |
| +119500 | 32.20% | 31.46% | 1.0234 | 41.72% | 40.85% | 1.0213 |
| +120000 | 32.20% | 31.45% | 1.0236 | 41.72% | 40.84% | 1.0215 |
| +120500 | 32.20% | 31.45% | 1.0239 | 41.72% | 40.84% | 1.0217 |
| +121000 | 32.20% | 31.44% | 1.0241 | 41.72% | 40.83% | 1.0219 |
| +121500 | 32.20% | 31.43% | 1.0243 | 41.72% | 40.82% | 1.0221 |
| +122000 | 32.20% | 31.43% | 1.0245 | 41.72% | 40.81% | 1.0224 |
| +122500 | 32.20% | 31.42% | 1.0248 | 41.72% | 40.80% | 1.0226 |
| +123000 | 32.20% | 31.41% | 1.0250 | 41.72% | 40.79% | 1.0228 |
| +123500 | 32.20% | 31.41% | 1.0252 | 41.72% | 40.78% | 1.0230 |
| +124000 | 32.20% | 31.40% | 1.0254 | 41.72% | 40.78% | 1.0232 |
| +124500 | 32.20% | 31.39% | 1.0256 | 41.72% | 40.77% | 1.0234 |
| +125000 | 32.20% | 31.39% | 1.0258 | 41.72% | 40.76% | 1.0236 |
| +125500 | 32.20% | 31.38% | 1.0261 | 41.72% | 40.75% | 1.0238 |
| +126000 | 32.20% | 31.37% | 1.0263 | 41.72% | 40.75% | 1.0240 |
| +126500 | 32.20% | 31.37% | 1.0265 | 41.72% | 40.74% | 1.0242 |
| +127000 | 32.20% | 31.36% | 1.0267 | 41.72% | 40.73% | 1.0243 |
| +127500 | 32.20% | 31.35% | 1.0269 | 41.72% | 40.72% | 1.0245 |
| +128000 | 32.20% | 31.35% | 1.0271 | 41.72% | 40.72% | 1.0247 |
| +128500 | 32.20% | 32.65% | 0.9861 | 41.72% | 41.91% | 0.9954 |
| +129000 | 32.20% | 32.62% | 0.9872 | 41.72% | 41.88% | 0.9962 |
| +129500 | 32.20% | 32.58% | 0.9882 | 41.72% | 41.85% | 0.9969 |
| +130000 | 32.20% | 32.54% | 0.9893 | 41.72% | 41.82% | 0.9976 |
| +130500 | 32.20% | 32.51% | 0.9904 | 41.72% | 41.79% | 0.9984 |
| +131000 | 32.20% | 32.47% | 0.9915 | 41.72% | 41.76% | 0.9991 |
| +131500 | 32.20% | 32.44% | 0.9925 | 41.72% | 41.73% | 0.9998 |
| +132000 | 32.20% | 32.40% | 0.9936 | 41.72% | 41.70% | 1.0006 |
| +132500 | 32.20% | 32.37% | 0.9947 | 41.72% | 41.67% | 1.0013 |
| +133000 | 32.20% | 32.33% | 0.9957 | 41.72% | 41.64% | 1.0021 |
| +133500 | 32.20% | 32.30% | 0.9967 | 41.72% | 41.61% | 1.0027 |
| +134000 | 32.20% | 32.28% | 0.9975 | 41.72% | 41.58% | 1.0034 |
| +134500 | 32.20% | 32.25% | 0.9984 | 41.72% | 41.56% | 1.0040 |
| +135000 | 32.20% | 32.22% | 0.9992 | 41.72% | 41.53% | 1.0046 |
| +135500 | 32.20% | 32.19% | 1.0001 | 41.72% | 41.50% | 1.0052 |
| +136000 | 32.20% | 32.17% | 1.0009 | 41.72% | 41.48% | 1.0059 |
| +136500 | 32.20% | 32.14% | 1.0018 | 41.72% | 41.45% | 1.0065 |
| +137000 | 32.20% | 32.11% | 1.0026 | 41.72% | 41.43% | 1.0071 |
| +137500 | 32.20% | 32.09% | 1.0035 | 41.72% | 41.40% | 1.0078 |
| +138000 | 32.20% | 32.06% | 1.0043 | 41.72% | 41.38% | 1.0084 |
| +138500 | 32.20% | 32.03% | 1.0051 | 41.72% | 41.35% | 1.0089 |



Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - Gas Operations

| Net Heat Rate Degradation Factor - HHV (Gas) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Tested | Revised | | Tested | Revised | |
| +139000 | 32.20% | 32.01% | 1.0058 | 41.72% | 41.33% | 1.0095 |
| +139500 | 32.20% | 31.99% | 1.0065 | 41.72% | 41.31% | 1.0100 |
| +140000 | 32.20% | 31.97% | 1.0072 | 41.72% | 41.29% | 1.0105 |

FY 19 : As per 3rd Party Heat Rate Test on Gas Fuel

FY 23 : As per actual operating hours. Operating hours at end of FY23 : 71,836 hours



(Signature)

(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - HSD Operations

| Net Heat Rate Degradation Factor - HHV (HSD) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Calculated | Revised | | Tested | Revised | |
| FY-21 (Test) | 34.18% | 34.18% | 1.0000 | 43.13% | 43.13% | 1.0000 |
| FY-23 (end) | 34.18% | 33.92% | 1.0078 | 43.13% | 42.93% | 1.0047 |
| +500 | 34.18% | 33.88% | 1.0088 | 43.13% | 42.90% | 1.0053 |
| +1000 | 34.18% | 33.85% | 1.0097 | 43.13% | 42.88% | 1.0058 |
| +1500 | 34.18% | 33.82% | 1.0107 | 43.13% | 42.85% | 1.0064 |
| +2000 | 34.18% | 33.79% | 1.0116 | 43.13% | 42.83% | 1.0069 |
| +2500 | 34.18% | 33.76% | 1.0125 | 43.13% | 42.81% | 1.0075 |
| +3000 | 34.18% | 33.73% | 1.0135 | 43.13% | 42.78% | 1.0080 |
| +3500 | 34.18% | 35.13% | 0.9729 | 43.13% | 43.74% | 0.9861 |
| +4000 | 34.18% | 34.97% | 0.9774 | 43.13% | 43.62% | 0.9886 |
| +4500 | 34.18% | 34.81% | 0.9819 | 43.13% | 43.51% | 0.9912 |
| +5000 | 34.18% | 34.65% | 0.9864 | 43.13% | 43.40% | 0.9937 |
| +5500 | 34.18% | 34.50% | 0.9909 | 43.13% | 43.29% | 0.9963 |
| +6000 | 34.18% | 34.40% | 0.9938 | 43.13% | 43.22% | 0.9979 |
| +6500 | 34.18% | 34.32% | 0.9959 | 43.13% | 43.17% | 0.9990 |
| +7000 | 34.18% | 34.25% | 0.9980 | 43.13% | 43.12% | 1.0002 |
| +7500 | 34.18% | 34.18% | 1.0001 | 43.13% | 43.07% | 1.0013 |
| +8000 | 34.18% | 34.11% | 1.0022 | 43.13% | 43.02% | 1.0025 |
| +8500 | 34.18% | 34.06% | 1.0037 | 43.13% | 42.99% | 1.0033 |
| +9000 | 34.18% | 34.02% | 1.0048 | 43.13% | 42.96% | 1.0039 |
| +9500 | 34.18% | 33.98% | 1.0060 | 43.13% | 42.93% | 1.0045 |
| +10000 | 34.18% | 33.94% | 1.0071 | 43.13% | 42.91% | 1.0051 |
| +10500 | 34.18% | 33.90% | 1.0083 | 43.13% | 42.88% | 1.0058 |
| +11000 | 34.18% | 33.86% | 1.0093 | 43.13% | 42.86% | 1.0063 |
| +11500 | 34.18% | 33.83% | 1.0103 | 43.13% | 42.83% | 1.0069 |
| +12000 | 34.18% | 33.80% | 1.0113 | 43.13% | 42.81% | 1.0074 |
| +12500 | 34.18% | 33.77% | 1.0123 | 43.13% | 42.79% | 1.0079 |
| +13000 | 34.18% | 33.73% | 1.0132 | 43.13% | 42.76% | 1.0085 |
| +13500 | 34.18% | 33.70% | 1.0143 | 43.13% | 42.74% | 1.0091 |
| +14000 | 34.18% | 33.66% | 1.0154 | 43.13% | 42.72% | 1.0096 |
| +14500 | 34.18% | 33.62% | 1.0165 | 43.13% | 42.69% | 1.0102 |
| +15000 | 34.18% | 33.59% | 1.0176 | 43.13% | 42.67% | 1.0108 |
| +15500 | 34.18% | 33.55% | 1.0187 | 43.13% | 42.64% | 1.0114 |
| +16000 | 34.18% | 34.98% | 0.9770 | 43.13% | 43.62% | 0.9888 |
| +16500 | 34.18% | 34.83% | 0.9815 | 43.13% | 43.50% | 0.9913 |
| +17000 | 34.18% | 34.67% | 0.9859 | 43.13% | 43.39% | 0.9939 |
| +17500 | 34.18% | 34.51% | 0.9904 | 43.13% | 43.28% | 0.9964 |
| +18000 | 34.18% | 34.36% | 0.9948 | 43.13% | 43.17% | 0.9989 |
| +18500 | 34.18% | 34.26% | 0.9976 | 43.13% | 43.11% | 1.0005 |
| +19000 | 34.18% | 34.20% | 0.9996 | 43.13% | 43.06% | 1.0015 |
| +19500 | 34.18% | 34.13% | 1.0015 | 43.13% | 43.02% | 1.0026 |
| +20000 | 34.18% | 34.06% | 1.0035 | 43.13% | 42.97% | 1.0037 |



Handwritten signature/initials in blue ink.

Handwritten signature/initials in blue ink.

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - HSD Operations

| Net Heat Rate Degradation Factor - HHV (HSD) | | | | | | |
|--|-------------|---------|-------------------|-------------------|---------|-------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Calculated | Revised | | Tested | Revised | |
| +20500 | 34.18% | 33.99% | 1.0055 | 43.13% | 42.92% | 1.0047 |
| +21000 | 34.18% | 33.95% | 1.0069 | 43.13% | 42.89% | 1.0055 |
| +21500 | 34.18% | 33.91% | 1.0080 | 43.13% | 42.87% | 1.0060 |
| +22000 | 34.18% | 33.87% | 1.0092 | 43.13% | 42.84% | 1.0066 |
| +22500 | 34.18% | 33.83% | 1.0103 | 43.13% | 42.82% | 1.0072 |
| +23000 | 34.18% | 33.79% | 1.0114 | 43.13% | 42.79% | 1.0078 |
| +23500 | 34.18% | 33.76% | 1.0125 | 43.13% | 42.77% | 1.0083 |
| +24000 | 34.18% | 33.73% | 1.0135 | 43.13% | 42.75% | 1.0088 |
| +24500 | 34.18% | 33.69% | 1.0144 | 43.13% | 42.73% | 1.0093 |
| +25000 | 34.18% | 33.66% | 1.0154 | 43.13% | 42.71% | 1.0098 |
| +25500 | 34.18% | 33.63% | 1.0164 | 43.13% | 42.69% | 1.0103 |
| +26000 | 34.18% | 33.59% | 1.0176 | 43.13% | 42.66% | 1.0109 |
| +26500 | 34.18% | 33.55% | 1.0189 | 43.13% | 42.63% | 1.0116 |
| +27000 | 34.18% | 33.51% | 1.0201 | 43.13% | 42.61% | 1.0123 |
| +27500 | 34.18% | 33.46% | 1.0214 | 43.13% | 42.58% | 1.0129 |
| +28000 | 34.18% | 33.42% | 1.0227 | 43.13% | 42.55% | 1.0136 |
| +28500 | 34.18% | 36.32% | 0.9411 | 43.13% | 44.65% | 0.9658 |
| +29000 | 34.18% | 36.06% | 0.9479 | 43.13% | 44.46% | 0.9701 |
| +29500 | 34.18% | 35.81% | 0.9546 | 43.13% | 44.26% | 0.9744 |
| +30000 | 34.18% | 35.56% | 0.9613 | 43.13% | 44.06% | 0.9788 |
| +30500 | 34.18% | 35.31% | 0.9680 | 43.13% | 43.87% | 0.9831 |
| +31000 | 34.18% | 35.14% | 0.9726 | 43.13% | 43.75% | 0.9858 |
| +31500 | 34.18% | 35.02% | 0.9761 | 43.13% | 43.66% | 0.9878 |
| +32000 | 34.18% | 34.89% | 0.9796 | 43.13% | 43.57% | 0.9898 |
| +32500 | 34.18% | 34.77% | 0.9831 | 43.13% | 43.48% | 0.9918 |
| +33000 | 34.18% | 34.64% | 0.9866 | 43.13% | 43.40% | 0.9938 |
| +33500 | 34.18% | 34.56% | 0.9890 | 43.13% | 43.34% | 0.9952 |
| +34000 | 34.18% | 34.50% | 0.9908 | 43.13% | 43.29% | 0.9963 |
| +34500 | 34.18% | 34.43% | 0.9927 | 43.13% | 43.24% | 0.9973 |
| +35000 | 34.18% | 34.37% | 0.9945 | 43.13% | 43.19% | 0.9984 |
| +35500 | 34.18% | 34.31% | 0.9963 | 43.13% | 43.15% | 0.9995 |
| +36000 | 34.18% | 34.26% | 0.9977 | 43.13% | 43.11% | 1.0003 |
| +36500 | 34.18% | 34.22% | 0.9988 | 43.13% | 43.08% | 1.0010 |
| +37000 | 34.18% | 34.18% | 0.9999 | 43.13% | 43.06% | 1.0017 |
| +37500 | 34.18% | 34.14% | 1.0011 | 43.13% | 43.03% | 1.0023 |
| +38000 | 34.18% | 34.11% | 1.0022 | 43.13% | 43.00% | 1.0030 |
| +38500 | 34.18% | 34.07% | 1.0032 | 43.13% | 42.98% | 1.0035 |
| +39000 | 34.18% | 34.04% | 1.0042 | 43.13% | 42.96% | 1.0040 |
| +39500 | 34.18% | 34.00% | 1.0052 | 43.13% | 42.94% | 1.0044 |
| +40000 | 34.18% | 33.97% | 1.0062 | 43.13% | 42.92% | 1.0049 |
| +40500 | 34.18% | 33.94% | 1.0071 | 43.13% | 42.90% | 1.0053 |
| +41000 | 34.18% | 35.36% | 0.9666 | 43.13% | 43.87% | 0.9831 |
| +41500 | 34.18% | 35.20% | 0.9710 | 43.13% | 43.76% | 0.9855 |

By



Signature

Signature

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - HSD Operations

| Net Heat Rate Degradation Factor - HHV (HSD) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Calculated | Revised | | Tested | Revised | |
| +42000 | 34.18% | 35.05% | 0.9753 | 43.13% | 43.66% | 0.9878 |
| +42500 | 34.18% | 34.89% | 0.9796 | 43.13% | 43.56% | 0.9901 |
| +43000 | 34.18% | 34.74% | 0.9840 | 43.13% | 43.46% | 0.9924 |
| +43500 | 34.18% | 34.63% | 0.9870 | 43.13% | 43.39% | 0.9940 |
| +44000 | 34.18% | 34.54% | 0.9895 | 43.13% | 43.33% | 0.9953 |
| +44500 | 34.18% | 34.46% | 0.9920 | 43.13% | 43.28% | 0.9965 |
| +45000 | 34.18% | 34.37% | 0.9945 | 43.13% | 43.22% | 0.9978 |
| +45500 | 34.18% | 34.28% | 0.9970 | 43.13% | 43.17% | 0.9991 |
| +46000 | 34.18% | 34.23% | 0.9987 | 43.13% | 43.13% | 0.9999 |
| +46500 | 34.18% | 34.18% | 1.0000 | 43.13% | 43.11% | 1.0005 |
| +47000 | 34.18% | 34.14% | 1.0013 | 43.13% | 43.08% | 1.0011 |
| +47500 | 34.18% | 34.09% | 1.0026 | 43.13% | 43.06% | 1.0017 |
| +48000 | 34.18% | 34.05% | 1.0039 | 43.13% | 43.03% | 1.0023 |
| +48500 | 34.18% | 34.01% | 1.0050 | 43.13% | 43.00% | 1.0029 |
| +49000 | 34.18% | 33.98% | 1.0059 | 43.13% | 42.98% | 1.0035 |
| +49500 | 34.18% | 33.95% | 1.0069 | 43.13% | 42.95% | 1.0041 |
| +50000 | 34.18% | 33.92% | 1.0078 | 43.13% | 42.93% | 1.0047 |
| +50500 | 34.18% | 33.88% | 1.0088 | 43.13% | 42.90% | 1.0053 |
| +51000 | 34.18% | 33.85% | 1.0097 | 43.13% | 42.88% | 1.0059 |
| +51500 | 34.18% | 33.82% | 1.0107 | 43.13% | 42.85% | 1.0065 |
| +52000 | 34.18% | 33.79% | 1.0116 | 43.13% | 42.83% | 1.0070 |
| +52500 | 34.18% | 33.76% | 1.0125 | 43.13% | 42.80% | 1.0076 |
| +53000 | 34.18% | 33.73% | 1.0135 | 43.13% | 42.78% | 1.0082 |
| +53500 | 34.18% | 35.13% | 0.9729 | 43.13% | 43.73% | 0.9862 |
| +54000 | 34.18% | 34.97% | 0.9774 | 43.13% | 43.61% | 0.9888 |
| +54500 | 34.18% | 34.81% | 0.9819 | 43.13% | 43.50% | 0.9914 |
| +55000 | 34.18% | 34.65% | 0.9864 | 43.13% | 43.39% | 0.9940 |
| +55500 | 34.18% | 34.50% | 0.9909 | 43.13% | 43.27% | 0.9966 |
| +56000 | 34.18% | 34.40% | 0.9938 | 43.13% | 43.20% | 0.9982 |
| +56500 | 34.18% | 34.32% | 0.9959 | 43.13% | 43.15% | 0.9994 |
| +57000 | 34.18% | 34.25% | 0.9980 | 43.13% | 43.10% | 1.0006 |
| +57500 | 34.18% | 34.18% | 1.0001 | 43.13% | 43.05% | 1.0018 |
| +58000 | 34.18% | 34.11% | 1.0022 | 43.13% | 43.00% | 1.0030 |
| +58500 | 34.18% | 34.06% | 1.0037 | 43.13% | 42.97% | 1.0038 |
| +59000 | 34.18% | 34.02% | 1.0048 | 43.13% | 42.94% | 1.0044 |
| +59500 | 34.18% | 33.98% | 1.0060 | 43.13% | 42.91% | 1.0050 |
| +60000 | 34.18% | 33.94% | 1.0071 | 43.13% | 42.88% | 1.0057 |
| +60500 | 34.18% | 33.90% | 1.0083 | 43.13% | 42.86% | 1.0063 |
| +61000 | 34.18% | 33.86% | 1.0093 | 43.13% | 42.83% | 1.0069 |
| +61500 | 34.18% | 33.83% | 1.0103 | 43.13% | 42.81% | 1.0074 |
| +62000 | 34.18% | 33.80% | 1.0113 | 43.13% | 42.79% | 1.0080 |
| +62500 | 34.18% | 33.77% | 1.0123 | 43.13% | 42.76% | 1.0085 |
| +63000 | 34.18% | 33.73% | 1.0132 | 43.13% | 42.74% | 1.0091 |

Qay



SA

MS

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - HSD Operations

| Net Heat Rate Degradation Factor - HHV (HSD) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Calculated | Revised | | Tested | Revised | |
| +63500 | 34.18% | 33.70% | 1.0143 | 43.13% | 42.71% | 1.0097 |
| +64000 | 34.18% | 33.66% | 1.0154 | 43.13% | 42.69% | 1.0102 |
| +64500 | 34.18% | 33.62% | 1.0165 | 43.13% | 42.67% | 1.0108 |
| +65000 | 34.18% | 33.59% | 1.0176 | 43.13% | 42.64% | 1.0114 |
| +65500 | 34.18% | 33.55% | 1.0187 | 43.13% | 42.62% | 1.0120 |
| +66000 | 34.18% | 34.98% | 0.9770 | 43.13% | 43.59% | 0.9894 |
| +66500 | 34.18% | 34.83% | 0.9815 | 43.13% | 43.48% | 0.9919 |
| +67000 | 34.18% | 34.67% | 0.9859 | 43.13% | 43.37% | 0.9945 |
| +67500 | 34.18% | 34.51% | 0.9904 | 43.13% | 43.26% | 0.9970 |
| +68000 | 34.18% | 34.36% | 0.9948 | 43.13% | 43.15% | 0.9995 |
| +68500 | 34.18% | 34.26% | 0.9976 | 43.13% | 43.08% | 1.0011 |
| +69000 | 34.18% | 34.20% | 0.9996 | 43.13% | 43.03% | 1.0022 |
| +69500 | 34.18% | 34.13% | 1.0015 | 43.13% | 42.99% | 1.0032 |
| +70000 | 34.18% | 34.06% | 1.0035 | 43.13% | 42.94% | 1.0043 |
| +70500 | 34.18% | 33.99% | 1.0055 | 43.13% | 42.90% | 1.0054 |
| +71000 | 34.18% | 33.95% | 1.0069 | 43.13% | 42.87% | 1.0061 |
| +71500 | 34.18% | 33.91% | 1.0080 | 43.13% | 42.84% | 1.0067 |
| +72000 | 34.18% | 33.87% | 1.0092 | 43.13% | 42.82% | 1.0073 |
| +72500 | 34.18% | 33.83% | 1.0103 | 43.13% | 42.79% | 1.0079 |
| +73000 | 34.18% | 33.79% | 1.0114 | 43.13% | 42.77% | 1.0084 |
| +73500 | 34.18% | 33.76% | 1.0125 | 43.13% | 42.74% | 1.0090 |
| +74000 | 34.18% | 33.73% | 1.0135 | 43.13% | 42.72% | 1.0095 |
| +74500 | 34.18% | 33.69% | 1.0144 | 43.13% | 42.70% | 1.0100 |
| +75000 | 34.18% | 33.66% | 1.0154 | 43.13% | 42.68% | 1.0105 |
| +75500 | 34.18% | 33.63% | 1.0164 | 43.13% | 42.66% | 1.0110 |
| +76000 | 34.18% | 33.59% | 1.0176 | 43.13% | 42.63% | 1.0116 |
| +76500 | 34.18% | 33.55% | 1.0189 | 43.13% | 42.60% | 1.0123 |
| +77000 | 34.18% | 33.51% | 1.0201 | 43.13% | 42.58% | 1.0130 |
| +77500 | 34.18% | 33.46% | 1.0214 | 43.13% | 42.55% | 1.0136 |
| +78000 | 34.18% | 33.42% | 1.0227 | 43.13% | 42.52% | 1.0143 |
| +78500 | 34.18% | 36.32% | 0.9411 | 43.13% | 44.63% | 0.9664 |
| +79000 | 34.18% | 36.06% | 0.9479 | 43.13% | 44.43% | 0.9707 |
| +79500 | 34.18% | 35.81% | 0.9546 | 43.13% | 44.23% | 0.9751 |
| +80000 | 34.18% | 35.56% | 0.9613 | 43.13% | 44.03% | 0.9794 |
| +80500 | 34.18% | 35.31% | 0.9680 | 43.13% | 43.84% | 0.9837 |
| +81000 | 34.18% | 35.14% | 0.9726 | 43.13% | 43.72% | 0.9865 |
| +81500 | 34.18% | 35.02% | 0.9761 | 43.13% | 43.63% | 0.9885 |
| +82000 | 34.18% | 34.89% | 0.9796 | 43.13% | 43.54% | 0.9905 |
| +82500 | 34.18% | 34.77% | 0.9831 | 43.13% | 43.45% | 0.9925 |
| +83000 | 34.18% | 34.64% | 0.9866 | 43.13% | 43.37% | 0.9945 |
| +83500 | 34.18% | 34.56% | 0.9890 | 43.13% | 43.30% | 0.9959 |
| +84000 | 34.18% | 34.50% | 0.9908 | 43.13% | 43.26% | 0.9970 |
| +84500 | 34.18% | 34.43% | 0.9927 | 43.13% | 43.21% | 0.9981 |

Qm



Ng

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - HSD Operations

| Net Heat Rate Degradation Factor - HHV (HSD) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Calculated | Revised | | Tested | Revised | |
| +85000 | 34.18% | 34.37% | 0.9945 | 43.13% | 43.16% | 0.9992 |
| +85500 | 34.18% | 34.31% | 0.9963 | 43.13% | 43.11% | 1.0003 |
| +86000 | 34.18% | 34.26% | 0.9977 | 43.13% | 43.08% | 1.0011 |
| +86500 | 34.18% | 34.22% | 0.9988 | 43.13% | 43.05% | 1.0018 |
| +87000 | 34.18% | 34.18% | 0.9999 | 43.13% | 43.02% | 1.0025 |
| +87500 | 34.18% | 34.14% | 1.0011 | 43.13% | 42.99% | 1.0032 |
| +88000 | 34.18% | 34.11% | 1.0022 | 43.13% | 42.96% | 1.0039 |
| +88500 | 34.18% | 34.07% | 1.0032 | 43.13% | 42.93% | 1.0045 |
| +89000 | 34.18% | 34.04% | 1.0042 | 43.13% | 42.91% | 1.0051 |
| +89500 | 34.18% | 34.00% | 1.0052 | 43.13% | 42.88% | 1.0057 |
| +90000 | 34.18% | 33.97% | 1.0062 | 43.13% | 42.86% | 1.0062 |
| +90500 | 34.18% | 33.94% | 1.0071 | 43.13% | 42.84% | 1.0068 |
| +91000 | 34.18% | 35.36% | 0.9666 | 43.13% | 43.80% | 0.9846 |
| +91500 | 34.18% | 35.20% | 0.9710 | 43.13% | 43.69% | 0.9870 |
| +92000 | 34.18% | 35.05% | 0.9753 | 43.13% | 43.59% | 0.9895 |
| +92500 | 34.18% | 34.89% | 0.9796 | 43.13% | 43.48% | 0.9919 |
| +93000 | 34.18% | 34.74% | 0.9840 | 43.13% | 43.37% | 0.9944 |
| +93500 | 34.18% | 34.63% | 0.9870 | 43.13% | 43.30% | 0.9961 |
| +94000 | 34.18% | 34.54% | 0.9895 | 43.13% | 43.24% | 0.9975 |
| +94500 | 34.18% | 34.46% | 0.9920 | 43.13% | 43.18% | 0.9989 |
| +95000 | 34.18% | 34.37% | 0.9945 | 43.13% | 43.12% | 1.0003 |
| +95500 | 34.18% | 34.28% | 0.9970 | 43.13% | 43.06% | 1.0016 |
| +96000 | 34.18% | 34.23% | 0.9987 | 43.13% | 43.02% | 1.0026 |
| +96500 | 34.18% | 34.18% | 1.0000 | 43.13% | 42.99% | 1.0033 |
| +97000 | 34.18% | 34.14% | 1.0013 | 43.13% | 42.95% | 1.0040 |
| +97500 | 34.18% | 34.09% | 1.0026 | 43.13% | 42.92% | 1.0047 |
| +98000 | 34.18% | 34.05% | 1.0039 | 43.13% | 42.89% | 1.0055 |
| +98500 | 34.18% | 34.01% | 1.0050 | 43.13% | 42.87% | 1.0060 |
| +99000 | 34.18% | 33.98% | 1.0059 | 43.13% | 42.85% | 1.0065 |
| +99500 | 34.18% | 33.95% | 1.0069 | 43.13% | 42.83% | 1.0069 |
| +100000 | 34.18% | 33.92% | 1.0078 | 43.13% | 42.81% | 1.0074 |
| +100500 | 34.18% | 33.88% | 1.0088 | 43.13% | 42.79% | 1.0078 |
| +101000 | 34.18% | 33.85% | 1.0097 | 43.13% | 42.77% | 1.0083 |
| +101500 | 34.18% | 33.82% | 1.0107 | 43.13% | 42.75% | 1.0087 |
| +102000 | 34.18% | 33.79% | 1.0116 | 43.13% | 42.74% | 1.0092 |
| +102500 | 34.18% | 33.76% | 1.0125 | 43.13% | 42.72% | 1.0096 |
| +103000 | 34.18% | 33.73% | 1.0135 | 43.13% | 42.70% | 1.0100 |
| +103500 | 34.18% | 35.13% | 0.9729 | 43.13% | 43.66% | 0.9878 |
| +104000 | 34.18% | 34.97% | 0.9774 | 43.13% | 43.55% | 0.9903 |
| +104500 | 34.18% | 34.81% | 0.9819 | 43.13% | 43.44% | 0.9928 |
| +105000 | 34.18% | 34.65% | 0.9864 | 43.13% | 43.33% | 0.9953 |
| +105500 | 34.18% | 34.50% | 0.9909 | 43.13% | 43.22% | 0.9978 |
| +106000 | 34.18% | 34.40% | 0.9938 | 43.13% | 43.16% | 0.9993 |

Handwritten signature



Handwritten signature

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - HSD Operations

| Net Heat Rate Degradation Factor - HHV (HSD) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Calculated | Revised | | Tested | Revised | |
| +106500 | 34.18% | 34.32% | 0.9959 | 43.13% | 43.11% | 1.0004 |
| +107000 | 34.18% | 34.25% | 0.9980 | 43.13% | 43.07% | 1.0014 |
| +107500 | 34.18% | 34.18% | 1.0001 | 43.13% | 43.02% | 1.0025 |
| +108000 | 34.18% | 34.11% | 1.0022 | 43.13% | 42.97% | 1.0036 |
| +108500 | 34.18% | 34.06% | 1.0037 | 43.13% | 42.94% | 1.0044 |
| +109000 | 34.18% | 34.02% | 1.0048 | 43.13% | 42.91% | 1.0051 |
| +109500 | 34.18% | 33.98% | 1.0060 | 43.13% | 42.88% | 1.0057 |
| +110000 | 34.18% | 33.94% | 1.0071 | 43.13% | 42.85% | 1.0064 |
| +110500 | 34.18% | 33.90% | 1.0083 | 43.13% | 42.82% | 1.0071 |
| +111000 | 34.18% | 33.86% | 1.0093 | 43.13% | 42.80% | 1.0077 |
| +111500 | 34.18% | 33.83% | 1.0103 | 43.13% | 42.77% | 1.0083 |
| +112000 | 34.18% | 33.80% | 1.0113 | 43.13% | 42.75% | 1.0089 |
| +112500 | 34.18% | 33.77% | 1.0123 | 43.13% | 42.72% | 1.0095 |
| +113000 | 34.18% | 33.73% | 1.0132 | 43.13% | 42.70% | 1.0101 |
| +113500 | 34.18% | 33.70% | 1.0143 | 43.13% | 42.67% | 1.0107 |
| +114000 | 34.18% | 33.66% | 1.0154 | 43.13% | 42.64% | 1.0114 |
| +114500 | 34.18% | 33.62% | 1.0165 | 43.13% | 42.62% | 1.0120 |
| +115000 | 34.18% | 33.59% | 1.0176 | 43.13% | 42.59% | 1.0126 |
| +115500 | 34.18% | 33.55% | 1.0187 | 43.13% | 42.56% | 1.0132 |
| +116000 | 34.18% | 34.98% | 0.9770 | 43.13% | 43.54% | 0.9905 |
| +116500 | 34.18% | 34.83% | 0.9815 | 43.13% | 43.43% | 0.9931 |
| +117000 | 34.18% | 34.67% | 0.9859 | 43.13% | 43.31% | 0.9957 |
| +117500 | 34.18% | 34.51% | 0.9904 | 43.13% | 43.20% | 0.9983 |
| +118000 | 34.18% | 34.36% | 0.9948 | 43.13% | 43.09% | 1.0009 |
| +118500 | 34.18% | 34.26% | 0.9976 | 43.13% | 43.02% | 1.0025 |
| +119000 | 34.18% | 34.20% | 0.9996 | 43.13% | 42.97% | 1.0036 |
| +119500 | 34.18% | 34.13% | 1.0015 | 43.13% | 42.92% | 1.0047 |
| +120000 | 34.18% | 34.06% | 1.0035 | 43.13% | 42.88% | 1.0058 |
| +120500 | 34.18% | 33.99% | 1.0055 | 43.13% | 42.83% | 1.0069 |
| +121000 | 34.18% | 33.95% | 1.0069 | 43.13% | 42.80% | 1.0077 |
| +121500 | 34.18% | 33.91% | 1.0080 | 43.13% | 42.77% | 1.0083 |
| +122000 | 34.18% | 33.87% | 1.0092 | 43.13% | 42.75% | 1.0089 |
| +122500 | 34.18% | 33.83% | 1.0103 | 43.13% | 42.72% | 1.0096 |
| +123000 | 34.18% | 33.79% | 1.0114 | 43.13% | 42.69% | 1.0102 |
| +123500 | 34.18% | 33.76% | 1.0125 | 43.13% | 42.67% | 1.0107 |
| +124000 | 34.18% | 33.73% | 1.0135 | 43.13% | 42.65% | 1.0112 |
| +124500 | 34.18% | 33.69% | 1.0144 | 43.13% | 42.63% | 1.0118 |
| +125000 | 34.18% | 33.66% | 1.0154 | 43.13% | 42.60% | 1.0123 |
| +125500 | 34.18% | 33.63% | 1.0164 | 43.13% | 42.58% | 1.0128 |
| +126000 | 34.18% | 33.59% | 1.0176 | 43.13% | 42.56% | 1.0134 |
| +126500 | 34.18% | 33.55% | 1.0189 | 43.13% | 42.53% | 1.0141 |
| +127000 | 34.18% | 33.51% | 1.0201 | 43.13% | 42.50% | 1.0148 |
| +127500 | 34.18% | 33.46% | 1.0214 | 43.13% | 42.47% | 1.0155 |

(Signature)



(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Heat Rate Degradation Table - HSD Operations

| Net Heat Rate Degradation Factor - HHV (HSD) | | | | | | |
|--|-------------|---------|----------------------|-------------------|---------|----------------------|
| Interval | Gas Turbine | | Correction Factor | Complex (100% LF) | | Correction Factor |
| | Efficiency | | | Efficiency | | |
| | Calculated | Revised | | Tested | Revised | |
| +128000 | 34.18% | 33.42% | 1.0227 | 43.13% | 42.44% | 1.0162 |
| +128500 | 34.18% | 36.32% | 0.9411 | 43.13% | 44.56% | 0.9679 |
| +129000 | 34.18% | 36.06% | 0.9479 | 43.13% | 44.36% | 0.9723 |
| +129500 | 34.18% | 35.81% | 0.9546 | 43.13% | 44.16% | 0.9766 |
| +130000 | 34.18% | 35.56% | 0.9613 | 43.13% | 43.96% | 0.9810 |
| +130500 | 34.18% | 35.31% | 0.9680 | 43.13% | 43.77% | 0.9853 |
| +131000 | 34.18% | 35.14% | 0.9726 | 43.13% | 43.65% | 0.9881 |
| +131500 | 34.18% | 35.02% | 0.9761 | 43.13% | 43.56% | 0.9901 |
| +132000 | 34.18% | 34.89% | 0.9796 | 43.13% | 43.47% | 0.9921 |
| +132500 | 34.18% | 34.77% | 0.9831 | 43.13% | 43.38% | 0.9941 |
| +133000 | 34.18% | 34.64% | 0.9866 | 43.13% | 43.30% | 0.9961 |
| +133500 | 34.18% | 34.56% | 0.9890 | 43.13% | 43.23% | 0.9975 |
| +134000 | 34.18% | 34.50% | 0.9908 | 43.13% | 43.19% | 0.9986 |
| +134500 | 34.18% | 34.43% | 0.9927 | 43.13% | 43.14% | 0.9997 |
| +135000 | 34.18% | 34.37% | 0.9945 | 43.13% | 43.09% | 1.0008 |
| +135500 | 34.18% | 34.31% | 0.9963 | 43.13% | 43.05% | 1.0019 |
| +136000 | 34.18% | 34.26% | 0.9977 | 43.13% | 43.01% | 1.0027 |
| +136500 | 34.18% | 34.22% | 0.9988 | 43.13% | 42.98% | 1.0034 |
| +137000 | 34.18% | 34.18% | 0.9999 | 43.13% | 42.95% | 1.0041 |
| +137500 | 34.18% | 34.14% | 1.0011 | 43.13% | 42.92% | 1.0047 |
| +138000 | 34.18% | 34.11% | 1.0022 | 43.13% | 42.90% | 1.0054 |
| +138500 | 34.18% | 34.07% | 1.0032 | 43.13% | 42.87% | 1.0060 |
| +139000 | 34.18% | 34.04% | 1.0042 | 43.13% | 42.84% | 1.0066 |
| +139500 | 34.18% | 34.00% | 1.0052 | 43.13% | 42.82% | 1.0072 |
| +140000 | 34.18% | 33.97% | 1.0062 | 43.13% | 42.80% | 1.0078 |

FY 21 : As per 3rd Party Heat Rate Test on HSD Fuel

FY 23 : As per actual operating hours. Operating hours at end of FY23 : 71,836 hours

Note: Simple cycle output has been computed from combined cycle 3rd party test results, by removing ST



(Signature)

(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - Gas Operations

| Net Output Degradation Factor - CC (Gas) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| FY-19 (Test) | 220.83 | 220.83 | 1.0000 |
| FY-23 (end) | 220.83 | 212.32 | 1.0401 |
| +500 | 220.83 | 212.14 | 1.0410 |
| +1000 | 220.83 | 211.96 | 1.0419 |
| +1500 | 220.83 | 211.78 | 1.0427 |
| +2000 | 220.83 | 211.60 | 1.0436 |
| +2500 | 220.83 | 211.41 | 1.0445 |
| +3000 | 220.83 | 211.23 | 1.0454 |
| +3500 | 220.83 | 218.46 | 1.0109 |
| +4000 | 220.83 | 218.14 | 1.0123 |
| +4500 | 220.83 | 217.82 | 1.0138 |
| +5000 | 220.83 | 217.51 | 1.0153 |
| +5500 | 220.83 | 217.20 | 1.0167 |
| +6000 | 220.83 | 216.88 | 1.0182 |
| +6500 | 220.83 | 216.57 | 1.0197 |
| +7000 | 220.83 | 216.26 | 1.0211 |
| +7500 | 220.83 | 215.95 | 1.0226 |
| +8000 | 220.83 | 215.64 | 1.0241 |
| +8500 | 220.83 | 215.40 | 1.0252 |
| +9000 | 220.83 | 215.19 | 1.0262 |
| +9500 | 220.83 | 214.98 | 1.0272 |
| +10000 | 220.83 | 214.77 | 1.0282 |
| +10500 | 220.83 | 214.56 | 1.0292 |
| +11000 | 220.83 | 214.35 | 1.0302 |
| +11500 | 220.83 | 214.14 | 1.0312 |
| +12000 | 220.83 | 213.93 | 1.0322 |
| +12500 | 220.83 | 213.72 | 1.0332 |
| +13000 | 220.83 | 213.52 | 1.0342 |
| +13500 | 220.83 | 213.34 | 1.0351 |
| +14000 | 220.83 | 213.18 | 1.0359 |
| +14500 | 220.83 | 213.02 | 1.0367 |
| +15000 | 220.83 | 212.86 | 1.0374 |
| +15500 | 220.83 | 212.70 | 1.0382 |
| +16000 | 220.83 | 212.54 | 1.0390 |
| +16500 | 220.83 | 212.38 | 1.0398 |
| +17000 | 220.83 | 212.22 | 1.0406 |
| +17500 | 220.83 | 212.06 | 1.0414 |
| +18000 | 220.83 | 211.90 | 1.0421 |
| +18500 | 220.83 | 211.77 | 1.0428 |
| +19000 | 220.83 | 211.65 | 1.0433 |
| +19500 | 220.83 | 211.54 | 1.0439 |
| +20000 | 220.83 | 211.42 | 1.0445 |
| +20500 | 220.83 | 211.31 | 1.0451 |
| +21000 | 220.83 | 211.19 | 1.0456 |
| +21500 | 220.83 | 211.08 | 1.0462 |
| +22000 | 220.83 | 210.96 | 1.0468 |
| +22500 | 220.83 | 210.85 | 1.0473 |

| Net Output Degradation Factor - OC (Gas) | | |
|--|----------------------------------|-------------------|
| Tested Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 170.70 | 170.70 | 1.0000 |
| 170.70 | 163.56 | 1.0437 |
| 170.70 | 163.41 | 1.0446 |
| 170.70 | 163.26 | 1.0456 |
| 170.70 | 163.11 | 1.0465 |
| 170.70 | 162.96 | 1.0475 |
| 170.70 | 162.81 | 1.0484 |
| 170.70 | 162.66 | 1.0494 |
| 170.70 | 175.10 | 0.9749 |
| 170.70 | 174.10 | 0.9805 |
| 170.70 | 173.11 | 0.9861 |
| 170.70 | 172.13 | 0.9917 |
| 170.70 | 171.17 | 0.9973 |
| 170.70 | 170.21 | 1.0029 |
| 170.70 | 169.27 | 1.0085 |
| 170.70 | 168.33 | 1.0140 |
| 170.70 | 167.41 | 1.0196 |
| 170.70 | 166.49 | 1.0252 |
| 170.70 | 166.08 | 1.0278 |
| 170.70 | 165.91 | 1.0289 |
| 170.70 | 165.73 | 1.0299 |
| 170.70 | 165.56 | 1.0310 |
| 170.70 | 165.39 | 1.0321 |
| 170.70 | 165.22 | 1.0332 |
| 170.70 | 165.05 | 1.0342 |
| 170.70 | 164.88 | 1.0353 |
| 170.70 | 164.71 | 1.0364 |
| 170.70 | 164.54 | 1.0374 |
| 170.70 | 164.39 | 1.0384 |
| 170.70 | 164.26 | 1.0392 |
| 170.70 | 164.13 | 1.0400 |
| 170.70 | 164.00 | 1.0409 |
| 170.70 | 163.87 | 1.0417 |
| 170.70 | 163.73 | 1.0425 |
| 170.70 | 163.60 | 1.0434 |
| 170.70 | 163.47 | 1.0442 |
| 170.70 | 163.34 | 1.0450 |
| 170.70 | 163.21 | 1.0459 |
| 170.70 | 163.11 | 1.0465 |
| 170.70 | 163.02 | 1.0471 |
| 170.70 | 162.92 | 1.0477 |
| 170.70 | 162.83 | 1.0483 |
| 170.70 | 162.74 | 1.0489 |
| 170.70 | 162.65 | 1.0495 |
| 170.70 | 162.55 | 1.0501 |
| 170.70 | 162.46 | 1.0507 |
| 170.70 | 162.37 | 1.0513 |

Qun



[Signature]

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - Gas Operations

| Net Output Degradation Factor - CC (Gas) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +23000 | 220.83 | 210.73 | 1.0479 |
| +23500 | 220.83 | 210.62 | 1.0485 |
| +24000 | 220.83 | 210.51 | 1.0490 |
| +24500 | 220.83 | 210.39 | 1.0496 |
| +25000 | 220.83 | 210.28 | 1.0502 |
| +25500 | 220.83 | 210.16 | 1.0507 |
| +26000 | 220.83 | 210.05 | 1.0513 |
| +26500 | 220.83 | 209.94 | 1.0519 |
| +27000 | 220.83 | 209.82 | 1.0525 |
| +27500 | 220.83 | 209.71 | 1.0530 |
| +28000 | 220.83 | 209.59 | 1.0536 |
| +28500 | 220.83 | 225.49 | 0.9793 |
| +29000 | 220.83 | 225.14 | 0.9809 |
| +29500 | 220.83 | 224.78 | 0.9824 |
| +30000 | 220.83 | 224.42 | 0.9840 |
| +30500 | 220.83 | 224.06 | 0.9856 |
| +31000 | 220.83 | 223.71 | 0.9871 |
| +31500 | 220.83 | 223.36 | 0.9887 |
| +32000 | 220.83 | 223.00 | 0.9902 |
| +32500 | 220.83 | 222.65 | 0.9918 |
| +33000 | 220.83 | 222.30 | 0.9934 |
| +33500 | 220.83 | 221.90 | 0.9952 |
| +34000 | 220.83 | 221.47 | 0.9971 |
| +34500 | 220.83 | 221.04 | 0.9990 |
| +35000 | 220.83 | 220.62 | 1.0010 |
| +35500 | 220.83 | 220.19 | 1.0029 |
| +36000 | 220.83 | 219.77 | 1.0048 |
| +36500 | 220.83 | 219.35 | 1.0067 |
| +37000 | 220.83 | 218.93 | 1.0087 |
| +37500 | 220.83 | 218.52 | 1.0106 |
| +38000 | 220.83 | 218.10 | 1.0125 |
| +38500 | 220.83 | 217.78 | 1.0140 |
| +39000 | 220.83 | 217.51 | 1.0153 |
| +39500 | 220.83 | 217.23 | 1.0165 |
| +40000 | 220.83 | 216.96 | 1.0178 |
| +40500 | 220.83 | 216.69 | 1.0191 |
| +41000 | 220.83 | 216.42 | 1.0204 |
| +41500 | 220.83 | 216.15 | 1.0216 |
| +42000 | 220.83 | 215.88 | 1.0229 |
| +42500 | 220.83 | 215.61 | 1.0242 |
| +43000 | 220.83 | 215.35 | 1.0255 |
| +43500 | 220.83 | 215.11 | 1.0266 |
| +44000 | 220.83 | 214.88 | 1.0277 |
| +44500 | 220.83 | 214.65 | 1.0288 |
| +45000 | 220.83 | 214.43 | 1.0298 |
| +45500 | 220.83 | 214.20 | 1.0309 |
| +46000 | 220.83 | 213.98 | 1.0320 |
| +46500 | 220.83 | 213.75 | 1.0331 |

| Net Output Degradation Factor - OC (Gas) | | |
|--|----------------------------------|-------------------|
| Tested Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 170.70 | 162.28 | 1.0519 |
| 170.70 | 162.19 | 1.0525 |
| 170.70 | 162.10 | 1.0531 |
| 170.70 | 162.00 | 1.0537 |
| 170.70 | 161.91 | 1.0543 |
| 170.70 | 161.82 | 1.0549 |
| 170.70 | 161.73 | 1.0554 |
| 170.70 | 161.64 | 1.0560 |
| 170.70 | 161.55 | 1.0566 |
| 170.70 | 161.46 | 1.0572 |
| 170.70 | 161.36 | 1.0578 |
| 170.70 | 175.54 | 0.9724 |
| 170.70 | 175.20 | 0.9743 |
| 170.70 | 174.86 | 0.9762 |
| 170.70 | 174.52 | 0.9781 |
| 170.70 | 174.18 | 0.9800 |
| 170.70 | 173.84 | 0.9819 |
| 170.70 | 173.50 | 0.9838 |
| 170.70 | 173.17 | 0.9857 |
| 170.70 | 172.83 | 0.9876 |
| 170.70 | 172.50 | 0.9895 |
| 170.70 | 172.14 | 0.9916 |
| 170.70 | 171.77 | 0.9938 |
| 170.70 | 171.40 | 0.9959 |
| 170.70 | 171.03 | 0.9980 |
| 170.70 | 170.67 | 1.0002 |
| 170.70 | 170.30 | 1.0023 |
| 170.70 | 169.94 | 1.0045 |
| 170.70 | 169.58 | 1.0066 |
| 170.70 | 169.22 | 1.0088 |
| 170.70 | 168.86 | 1.0109 |
| 170.70 | 168.57 | 1.0126 |
| 170.70 | 168.31 | 1.0142 |
| 170.70 | 168.05 | 1.0157 |
| 170.70 | 167.80 | 1.0173 |
| 170.70 | 167.54 | 1.0188 |
| 170.70 | 167.29 | 1.0204 |
| 170.70 | 167.03 | 1.0219 |
| 170.70 | 166.78 | 1.0235 |
| 170.70 | 166.53 | 1.0250 |
| 170.70 | 166.28 | 1.0266 |
| 170.70 | 166.05 | 1.0280 |
| 170.70 | 165.84 | 1.0293 |
| 170.70 | 165.63 | 1.0306 |
| 170.70 | 165.42 | 1.0319 |
| 170.70 | 165.21 | 1.0332 |
| 170.70 | 165.00 | 1.0345 |
| 170.70 | 164.80 | 1.0358 |

(Signature)



(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - Gas Operations

| Net Output Degradation Factor - CC (Gas) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +47000 | 220.83 | 213.53 | 1.0342 |
| +47500 | 220.83 | 213.31 | 1.0353 |
| +48000 | 220.83 | 213.08 | 1.0363 |
| +48500 | 220.83 | 212.88 | 1.0373 |
| +49000 | 220.83 | 212.70 | 1.0382 |
| +49500 | 220.83 | 212.51 | 1.0392 |
| +50000 | 220.83 | 212.32 | 1.0401 |
| +50500 | 220.83 | 212.13 | 1.0410 |
| +51000 | 220.83 | 211.95 | 1.0419 |
| +51500 | 220.83 | 211.76 | 1.0428 |
| +52000 | 220.83 | 211.57 | 1.0437 |
| +52500 | 220.83 | 211.39 | 1.0447 |
| +53000 | 220.83 | 211.20 | 1.0456 |
| +53500 | 220.83 | 218.41 | 1.0111 |
| +54000 | 220.83 | 218.09 | 1.0125 |
| +54500 | 220.83 | 217.77 | 1.0140 |
| +55000 | 220.83 | 217.45 | 1.0155 |
| +55500 | 220.83 | 217.13 | 1.0170 |
| +56000 | 220.83 | 216.81 | 1.0185 |
| +56500 | 220.83 | 216.49 | 1.0200 |
| +57000 | 220.83 | 216.18 | 1.0215 |
| +57500 | 220.83 | 215.86 | 1.0230 |
| +58000 | 220.83 | 215.55 | 1.0245 |
| +58500 | 220.83 | 215.30 | 1.0257 |
| +59000 | 220.83 | 215.09 | 1.0267 |
| +59500 | 220.83 | 214.88 | 1.0277 |
| +60000 | 220.83 | 214.67 | 1.0287 |
| +60500 | 220.83 | 214.45 | 1.0297 |
| +61000 | 220.83 | 214.24 | 1.0307 |
| +61500 | 220.83 | 214.03 | 1.0317 |
| +62000 | 220.83 | 213.82 | 1.0328 |
| +62500 | 220.83 | 213.61 | 1.0338 |
| +63000 | 220.83 | 213.41 | 1.0348 |
| +63500 | 220.83 | 213.23 | 1.0356 |
| +64000 | 220.83 | 213.07 | 1.0364 |
| +64500 | 220.83 | 212.91 | 1.0372 |
| +65000 | 220.83 | 212.74 | 1.0380 |
| +65500 | 220.83 | 212.58 | 1.0388 |
| +66000 | 220.83 | 212.42 | 1.0396 |
| +66500 | 220.83 | 212.26 | 1.0404 |
| +67000 | 220.83 | 212.10 | 1.0411 |
| +67500 | 220.83 | 211.94 | 1.0419 |
| +68000 | 220.83 | 211.78 | 1.0427 |
| +68500 | 220.83 | 211.65 | 1.0434 |
| +69000 | 220.83 | 211.54 | 1.0439 |
| +69500 | 220.83 | 211.42 | 1.0445 |
| +70000 | 220.83 | 211.31 | 1.0451 |
| +70500 | 220.83 | 211.19 | 1.0456 |

| Net Output Degradation Factor - OC (Gas) | | |
|--|----------------------------------|-------------------|
| Tested Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 170.70 | 164.59 | 1.0371 |
| 170.70 | 164.38 | 1.0384 |
| 170.70 | 164.17 | 1.0397 |
| 170.70 | 164.00 | 1.0408 |
| 170.70 | 163.85 | 1.0418 |
| 170.70 | 163.70 | 1.0427 |
| 170.70 | 163.56 | 1.0437 |
| 170.70 | 163.41 | 1.0446 |
| 170.70 | 163.26 | 1.0456 |
| 170.70 | 163.11 | 1.0465 |
| 170.70 | 162.96 | 1.0475 |
| 170.70 | 162.81 | 1.0484 |
| 170.70 | 162.66 | 1.0494 |
| 170.70 | 175.10 | 0.9749 |
| 170.70 | 174.10 | 0.9805 |
| 170.70 | 173.11 | 0.9861 |
| 170.70 | 172.13 | 0.9917 |
| 170.70 | 171.17 | 0.9973 |
| 170.70 | 170.21 | 1.0029 |
| 170.70 | 169.27 | 1.0085 |
| 170.70 | 168.33 | 1.0140 |
| 170.70 | 167.41 | 1.0196 |
| 170.70 | 166.49 | 1.0252 |
| 170.70 | 166.08 | 1.0278 |
| 170.70 | 165.91 | 1.0289 |
| 170.70 | 165.73 | 1.0299 |
| 170.70 | 165.56 | 1.0310 |
| 170.70 | 165.39 | 1.0321 |
| 170.70 | 165.22 | 1.0332 |
| 170.70 | 165.05 | 1.0342 |
| 170.70 | 164.88 | 1.0353 |
| 170.70 | 164.71 | 1.0364 |
| 170.70 | 164.54 | 1.0374 |
| 170.70 | 164.39 | 1.0384 |
| 170.70 | 164.26 | 1.0392 |
| 170.70 | 164.13 | 1.0400 |
| 170.70 | 164.00 | 1.0409 |
| 170.70 | 163.87 | 1.0417 |
| 170.70 | 163.73 | 1.0425 |
| 170.70 | 163.60 | 1.0434 |
| 170.70 | 163.47 | 1.0442 |
| 170.70 | 163.34 | 1.0450 |
| 170.70 | 163.21 | 1.0459 |
| 170.70 | 163.11 | 1.0465 |
| 170.70 | 163.02 | 1.0471 |
| 170.70 | 162.92 | 1.0477 |
| 170.70 | 162.83 | 1.0483 |
| 170.70 | 162.74 | 1.0489 |

(Signature)



(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - Gas Operations

| Net Output Degradation Factor - CC (Gas) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +71000 | 220.83 | 211.08 | 1.0462 |
| +71500 | 220.83 | 210.96 | 1.0468 |
| +72000 | 220.83 | 210.85 | 1.0473 |
| +72500 | 220.83 | 210.73 | 1.0479 |
| +73000 | 220.83 | 210.62 | 1.0485 |
| +73500 | 220.83 | 210.50 | 1.0491 |
| +74000 | 220.83 | 210.39 | 1.0496 |
| +74500 | 220.83 | 210.27 | 1.0502 |
| +75000 | 220.83 | 210.16 | 1.0508 |
| +75500 | 220.83 | 210.04 | 1.0514 |
| +76000 | 220.83 | 209.93 | 1.0519 |
| +76500 | 220.83 | 209.81 | 1.0525 |
| +77000 | 220.83 | 209.70 | 1.0531 |
| +77500 | 220.83 | 209.58 | 1.0537 |
| +78000 | 220.83 | 209.47 | 1.0542 |
| +78500 | 220.83 | 225.35 | 0.9799 |
| +79000 | 220.83 | 224.99 | 0.9815 |
| +79500 | 220.83 | 224.63 | 0.9831 |
| +80000 | 220.83 | 224.27 | 0.9847 |
| +80500 | 220.83 | 223.91 | 0.9862 |
| +81000 | 220.83 | 223.56 | 0.9878 |
| +81500 | 220.83 | 223.20 | 0.9894 |
| +82000 | 220.83 | 222.85 | 0.9909 |
| +82500 | 220.83 | 222.50 | 0.9925 |
| +83000 | 220.83 | 222.15 | 0.9941 |
| +83500 | 220.83 | 221.74 | 0.9959 |
| +84000 | 220.83 | 221.31 | 0.9978 |
| +84500 | 220.83 | 220.88 | 0.9998 |
| +85000 | 220.83 | 220.45 | 1.0017 |
| +85500 | 220.83 | 220.03 | 1.0036 |
| +86000 | 220.83 | 219.60 | 1.0056 |
| +86500 | 220.83 | 219.18 | 1.0075 |
| +87000 | 220.83 | 218.76 | 1.0094 |
| +87500 | 220.83 | 218.34 | 1.0114 |
| +88000 | 220.83 | 217.92 | 1.0133 |
| +88500 | 220.83 | 217.59 | 1.0149 |
| +89000 | 220.83 | 217.29 | 1.0163 |
| +89500 | 220.83 | 217.00 | 1.0177 |
| +90000 | 220.83 | 216.70 | 1.0190 |
| +90500 | 220.83 | 216.41 | 1.0204 |
| +91000 | 220.83 | 216.11 | 1.0218 |
| +91500 | 220.83 | 215.82 | 1.0232 |
| +92000 | 220.83 | 215.53 | 1.0246 |
| +92500 | 220.83 | 215.24 | 1.0260 |
| +93000 | 220.83 | 214.95 | 1.0273 |
| +93500 | 220.83 | 214.69 | 1.0286 |
| +94000 | 220.83 | 214.44 | 1.0298 |
| +94500 | 220.83 | 214.19 | 1.0310 |

| Net Output Degradation Factor - OC (Gas) | | |
|--|----------------------------------|-------------------|
| Tested Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 170.70 | 162.65 | 1.0495 |
| 170.70 | 162.55 | 1.0501 |
| 170.70 | 162.46 | 1.0507 |
| 170.70 | 162.37 | 1.0513 |
| 170.70 | 162.28 | 1.0519 |
| 170.70 | 162.19 | 1.0525 |
| 170.70 | 162.10 | 1.0531 |
| 170.70 | 162.00 | 1.0537 |
| 170.70 | 161.91 | 1.0543 |
| 170.70 | 161.82 | 1.0549 |
| 170.70 | 161.73 | 1.0554 |
| 170.70 | 161.64 | 1.0560 |
| 170.70 | 161.55 | 1.0566 |
| 170.70 | 161.46 | 1.0572 |
| 170.70 | 161.36 | 1.0578 |
| 170.70 | 175.54 | 0.9724 |
| 170.70 | 175.20 | 0.9743 |
| 170.70 | 174.86 | 0.9762 |
| 170.70 | 174.52 | 0.9781 |
| 170.70 | 174.18 | 0.9800 |
| 170.70 | 173.84 | 0.9819 |
| 170.70 | 173.50 | 0.9838 |
| 170.70 | 173.17 | 0.9857 |
| 170.70 | 172.83 | 0.9876 |
| 170.70 | 172.50 | 0.9895 |
| 170.70 | 172.14 | 0.9916 |
| 170.70 | 171.77 | 0.9938 |
| 170.70 | 171.40 | 0.9959 |
| 170.70 | 171.03 | 0.9980 |
| 170.70 | 170.67 | 1.0002 |
| 170.70 | 170.30 | 1.0023 |
| 170.70 | 169.94 | 1.0045 |
| 170.70 | 169.58 | 1.0066 |
| 170.70 | 169.22 | 1.0088 |
| 170.70 | 168.86 | 1.0109 |
| 170.70 | 168.57 | 1.0126 |
| 170.70 | 168.31 | 1.0142 |
| 170.70 | 168.05 | 1.0157 |
| 170.70 | 167.80 | 1.0173 |
| 170.70 | 167.54 | 1.0188 |
| 170.70 | 167.29 | 1.0204 |
| 170.70 | 167.03 | 1.0219 |
| 170.70 | 166.78 | 1.0235 |
| 170.70 | 166.53 | 1.0250 |
| 170.70 | 166.28 | 1.0266 |
| 170.70 | 166.05 | 1.0280 |
| 170.70 | 165.84 | 1.0293 |
| 170.70 | 165.63 | 1.0306 |

Handwritten signature



Handwritten signature

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - Gas Operations

| Net Output Degradation Factor - CC (Gas) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +95000 | 220.83 | 213.95 | 1.0322 |
| +95500 | 220.83 | 213.70 | 1.0333 |
| +96000 | 220.83 | 213.46 | 1.0345 |
| +96500 | 220.83 | 213.21 | 1.0357 |
| +97000 | 220.83 | 212.97 | 1.0369 |
| +97500 | 220.83 | 212.73 | 1.0381 |
| +98000 | 220.83 | 212.48 | 1.0393 |
| +98500 | 220.83 | 212.30 | 1.0402 |
| +99000 | 220.83 | 212.14 | 1.0410 |
| +99500 | 220.83 | 211.98 | 1.0417 |
| +100000 | 220.83 | 211.82 | 1.0425 |
| +100500 | 220.83 | 211.66 | 1.0433 |
| +101000 | 220.83 | 211.50 | 1.0441 |
| +101500 | 220.83 | 211.35 | 1.0449 |
| +102000 | 220.83 | 211.19 | 1.0456 |
| +102500 | 220.83 | 211.03 | 1.0464 |
| +103000 | 220.83 | 210.88 | 1.0472 |
| +103500 | 220.83 | 210.88 | 1.0472 |
| +104000 | 220.83 | 210.88 | 1.0472 |
| +104500 | 220.83 | 210.88 | 1.0472 |
| +105000 | 220.83 | 210.88 | 1.0472 |
| +105500 | 220.83 | 210.88 | 1.0472 |
| +106000 | 220.83 | 210.88 | 1.0472 |
| +106500 | 220.83 | 210.88 | 1.0472 |
| +107000 | 220.83 | 210.88 | 1.0472 |
| +107500 | 220.83 | 210.88 | 1.0472 |
| +108000 | 220.83 | 210.88 | 1.0472 |
| +108500 | 220.83 | 210.88 | 1.0472 |
| +109000 | 220.83 | 210.88 | 1.0472 |
| +109500 | 220.83 | 210.88 | 1.0472 |
| +110000 | 220.83 | 210.88 | 1.0472 |
| +110500 | 220.83 | 210.88 | 1.0472 |
| +111000 | 220.83 | 210.88 | 1.0472 |
| +111500 | 220.83 | 210.88 | 1.0472 |
| +112000 | 220.83 | 210.88 | 1.0472 |
| +112500 | 220.83 | 210.88 | 1.0472 |
| +113000 | 220.83 | 210.88 | 1.0472 |
| +113500 | 220.83 | 210.88 | 1.0472 |
| +114000 | 220.83 | 210.88 | 1.0472 |
| +114500 | 220.83 | 210.88 | 1.0472 |
| +115000 | 220.83 | 210.88 | 1.0472 |
| +115500 | 220.83 | 210.88 | 1.0472 |
| +116000 | 220.83 | 210.88 | 1.0472 |
| +116500 | 220.83 | 210.88 | 1.0472 |
| +117000 | 220.83 | 210.88 | 1.0472 |
| +117500 | 220.83 | 210.88 | 1.0472 |
| +118000 | 220.83 | 210.88 | 1.0472 |
| +118500 | 220.83 | 210.88 | 1.0472 |

| Net Output Degradation Factor - OC (Gas) | | |
|--|----------------------------------|-------------------|
| Tested Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 170.70 | 165.42 | 1.0319 |
| 170.70 | 165.21 | 1.0332 |
| 170.70 | 165.00 | 1.0345 |
| 170.70 | 164.80 | 1.0358 |
| 170.70 | 164.59 | 1.0371 |
| 170.70 | 164.38 | 1.0384 |
| 170.70 | 164.17 | 1.0397 |
| 170.70 | 164.00 | 1.0408 |
| 170.70 | 163.85 | 1.0418 |
| 170.70 | 163.70 | 1.0427 |
| 170.70 | 163.56 | 1.0437 |
| 170.70 | 163.41 | 1.0446 |
| 170.70 | 163.26 | 1.0456 |
| 170.70 | 163.11 | 1.0465 |
| 170.70 | 162.96 | 1.0475 |
| 170.70 | 162.81 | 1.0484 |
| 170.70 | 162.66 | 1.0493 |
| 170.70 | 162.51 | 1.0502 |
| 170.70 | 162.36 | 1.0511 |
| 170.70 | 162.21 | 1.0520 |
| 170.70 | 162.06 | 1.0529 |
| 170.70 | 161.91 | 1.0538 |
| 170.70 | 161.76 | 1.0547 |
| 170.70 | 161.61 | 1.0556 |
| 170.70 | 161.46 | 1.0565 |
| 170.70 | 161.31 | 1.0574 |
| 170.70 | 161.16 | 1.0583 |
| 170.70 | 161.01 | 1.0592 |
| 170.70 | 160.86 | 1.0601 |
| 170.70 | 160.71 | 1.0610 |
| 170.70 | 160.56 | 1.0619 |
| 170.70 | 160.41 | 1.0628 |
| 170.70 | 160.26 | 1.0637 |
| 170.70 | 160.11 | 1.0646 |
| 170.70 | 160.00 | 1.0655 |
| 170.70 | 159.89 | 1.0664 |
| 170.70 | 159.78 | 1.0673 |
| 170.70 | 159.67 | 1.0682 |
| 170.70 | 159.56 | 1.0691 |
| 170.70 | 159.45 | 1.0700 |
| 170.70 | 159.34 | 1.0709 |
| 170.70 | 159.23 | 1.0718 |
| 170.70 | 159.12 | 1.0727 |
| 170.70 | 159.01 | 1.0736 |
| 170.70 | 158.90 | 1.0745 |
| 170.70 | 158.79 | 1.0754 |
| 170.70 | 158.68 | 1.0763 |
| 170.70 | 158.57 | 1.0772 |
| 170.70 | 158.46 | 1.0781 |
| 170.70 | 158.35 | 1.0790 |
| 170.70 | 158.24 | 1.0799 |
| 170.70 | 158.13 | 1.0808 |
| 170.70 | 158.02 | 1.0817 |
| 170.70 | 157.91 | 1.0826 |
| 170.70 | 157.80 | 1.0835 |
| 170.70 | 157.69 | 1.0844 |
| 170.70 | 157.58 | 1.0853 |
| 170.70 | 157.47 | 1.0862 |
| 170.70 | 157.36 | 1.0871 |
| 170.70 | 157.25 | 1.0880 |
| 170.70 | 157.14 | 1.0889 |
| 170.70 | 157.03 | 1.0898 |
| 170.70 | 156.92 | 1.0907 |
| 170.70 | 156.81 | 1.0916 |
| 170.70 | 156.70 | 1.0925 |
| 170.70 | 156.59 | 1.0934 |
| 170.70 | 156.48 | 1.0943 |
| 170.70 | 156.37 | 1.0952 |
| 170.70 | 156.26 | 1.0961 |
| 170.70 | 156.15 | 1.0970 |
| 170.70 | 156.04 | 1.0979 |
| 170.70 | 155.93 | 1.0988 |
| 170.70 | 155.82 | 1.0997 |
| 170.70 | 155.71 | 1.1006 |
| 170.70 | 155.60 | 1.1015 |
| 170.70 | 155.49 | 1.1024 |
| 170.70 | 155.38 | 1.1033 |
| 170.70 | 155.27 | 1.1042 |
| 170.70 | 155.16 | 1.1051 |
| 170.70 | 155.05 | 1.1060 |
| 170.70 | 154.94 | 1.1069 |
| 170.70 | 154.83 | 1.1078 |
| 170.70 | 154.72 | 1.1087 |
| 170.70 | 154.61 | 1.1096 |
| 170.70 | 154.50 | 1.1105 |
| 170.70 | 154.39 | 1.1114 |
| 170.70 | 154.28 | 1.1123 |
| 170.70 | 154.17 | 1.1132 |
| 170.70 | 154.06 | 1.1141 |
| 170.70 | 153.95 | 1.1150 |
| 170.70 | 153.84 | 1.1159 |
| 170.70 | 153.73 | 1.1168 |
| 170.70 | 153.62 | 1.1177 |
| 170.70 | 153.51 | 1.1186 |
| 170.70 | 153.40 | 1.1195 |
| 170.70 | 153.29 | 1.1204 |
| 170.70 | 153.18 | 1.1213 |
| 170.70 | 153.07 | 1.1222 |
| 170.70 | 152.96 | 1.1231 |
| 170.70 | 152.85 | 1.1240 |
| 170.70 | 152.74 | 1.1249 |
| 170.70 | 152.63 | 1.1258 |
| 170.70 | 152.52 | 1.1267 |
| 170.70 | 152.41 | 1.1276 |
| 170.70 | 152.30 | 1.1285 |
| 170.70 | 152.19 | 1.1294 |
| 170.70 | 152.08 | 1.1303 |
| 170.70 | 151.97 | 1.1312 |
| 170.70 | 151.86 | 1.1321 |
| 170.70 | 151.75 | 1.1330 |
| 170.70 | 151.64 | 1.1339 |
| 170.70 | 151.53 | 1.1348 |
| 170.70 | 151.42 | 1.1357 |
| 170.70 | 151.31 | 1.1366 |
| 170.70 | 151.20 | 1.1375 |
| 170.70 | 151.09 | 1.1384 |
| 170.70 | 150.98 | 1.1393 |
| 170.70 | 150.87 | 1.1402 |
| 170.70 | 150.76 | 1.1411 |
| 170.70 | 150.65 | 1.1420 |
| 170.70 | 150.54 | 1.1429 |
| 170.70 | 150.43 | 1.1438 |
| 170.70 | 150.32 | 1.1447 |
| 170.70 | 150.21 | 1.1456 |
| 170.70 | 150.10 | 1.1465 |
| 170.70 | 150.00 | 1.1474 |

(Signature)



(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - Gas Operations

| Net Output Degradation Factor - CC (Gas) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +119000 | 220.83 | 211.26 | 1.0453 |
| +119500 | 220.83 | 211.14 | 1.0459 |
| +120000 | 220.83 | 211.02 | 1.0465 |
| +120500 | 220.83 | 210.90 | 1.0471 |
| +121000 | 220.83 | 210.78 | 1.0477 |
| +121500 | 220.83 | 210.66 | 1.0483 |
| +122000 | 220.83 | 210.54 | 1.0489 |
| +122500 | 220.83 | 210.42 | 1.0495 |
| +123000 | 220.83 | 210.30 | 1.0501 |
| +123500 | 220.83 | 210.19 | 1.0506 |
| +124000 | 220.83 | 210.07 | 1.0512 |
| +124500 | 220.83 | 209.95 | 1.0518 |
| +125000 | 220.83 | 209.84 | 1.0524 |
| +125500 | 220.83 | 209.72 | 1.0529 |
| +126000 | 220.83 | 209.61 | 1.0535 |
| +126500 | 220.83 | 209.49 | 1.0541 |
| +127000 | 220.83 | 209.38 | 1.0547 |
| +127500 | 220.83 | 209.26 | 1.0553 |
| +128000 | 220.83 | 209.15 | 1.0558 |
| +128500 | 220.83 | 224.97 | 0.9816 |
| +129000 | 220.83 | 224.62 | 0.9831 |
| +129500 | 220.83 | 224.26 | 0.9847 |
| +130000 | 220.83 | 223.91 | 0.9863 |
| +130500 | 220.83 | 223.55 | 0.9878 |
| +131000 | 220.83 | 223.20 | 0.9894 |
| +131500 | 220.83 | 222.85 | 0.9909 |
| +132000 | 220.83 | 222.50 | 0.9925 |
| +132500 | 220.83 | 222.15 | 0.9940 |
| +133000 | 220.83 | 221.80 | 0.9956 |
| +133500 | 220.83 | 221.40 | 0.9974 |
| +134000 | 220.83 | 220.97 | 0.9993 |
| +134500 | 220.83 | 220.55 | 1.0013 |
| +135000 | 220.83 | 220.13 | 1.0032 |
| +135500 | 220.83 | 219.71 | 1.0051 |
| +136000 | 220.83 | 219.29 | 1.0070 |
| +136500 | 220.83 | 218.87 | 1.0090 |
| +137000 | 220.83 | 218.45 | 1.0109 |
| +137500 | 220.83 | 218.03 | 1.0128 |
| +138000 | 220.83 | 217.62 | 1.0147 |
| +138500 | 220.83 | 217.29 | 1.0163 |
| +139000 | 220.83 | 216.99 | 1.0177 |
| +139500 | 220.83 | 216.70 | 1.0191 |
| +140000 | 220.83 | 216.41 | 1.0204 |

| Net Output Degradation Factor - OC (Gas) | | |
|--|----------------------------------|-------------------|
| Tested Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 170.70 | 163.02 | 1.0471 |
| 170.70 | 162.92 | 1.0477 |
| 170.70 | 162.83 | 1.0483 |
| 170.70 | 162.74 | 1.0489 |
| 170.70 | 162.65 | 1.0495 |
| 170.70 | 162.55 | 1.0501 |
| 170.70 | 162.46 | 1.0507 |
| 170.70 | 162.37 | 1.0513 |
| 170.70 | 162.28 | 1.0519 |
| 170.70 | 162.19 | 1.0525 |
| 170.70 | 162.10 | 1.0531 |
| 170.70 | 162.00 | 1.0537 |
| 170.70 | 161.91 | 1.0543 |
| 170.70 | 161.82 | 1.0549 |
| 170.70 | 161.73 | 1.0554 |
| 170.70 | 161.64 | 1.0560 |
| 170.70 | 161.55 | 1.0566 |
| 170.70 | 161.46 | 1.0572 |
| 170.70 | 161.36 | 1.0578 |
| 170.70 | 175.54 | 0.9724 |
| 170.70 | 175.20 | 0.9743 |
| 170.70 | 174.86 | 0.9762 |
| 170.70 | 174.52 | 0.9781 |
| 170.70 | 174.18 | 0.9800 |
| 170.70 | 173.84 | 0.9819 |
| 170.70 | 173.50 | 0.9838 |
| 170.70 | 173.17 | 0.9857 |
| 170.70 | 172.83 | 0.9876 |
| 170.70 | 172.50 | 0.9895 |
| 170.70 | 172.14 | 0.9916 |
| 170.70 | 171.77 | 0.9938 |
| 170.70 | 171.40 | 0.9959 |
| 170.70 | 171.03 | 0.9980 |
| 170.70 | 170.67 | 1.0002 |
| 170.70 | 170.30 | 1.0023 |
| 170.70 | 169.94 | 1.0045 |
| 170.70 | 169.58 | 1.0066 |
| 170.70 | 169.22 | 1.0088 |
| 170.70 | 168.86 | 1.0109 |
| 170.70 | 168.57 | 1.0126 |
| 170.70 | 168.31 | 1.0142 |
| 170.70 | 168.05 | 1.0157 |
| 170.70 | 167.80 | 1.0173 |

FY 19 : As per 3rd Party Heat Rate Test on Gas Fuel

FY 23 : As per actual operating hours. Operating hours at end of FY23 : 71,836 hours



Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - HSD Operations

| Net Output Degradation Factor - CC (HSD) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| FY-21 (Test) | 220.02 | 220.02 | 1.0000 |
| FY-23 (end) | 220.02 | 217.16 | 1.0132 |
| +500 | 220.02 | 216.81 | 1.0148 |
| +1000 | 220.02 | 216.49 | 1.0163 |
| +1500 | 220.02 | 216.17 | 1.0178 |
| +2000 | 220.02 | 215.86 | 1.0193 |
| +2500 | 220.02 | 215.55 | 1.0207 |
| +3000 | 220.02 | 215.24 | 1.0222 |
| +3500 | 220.02 | 232.93 | 0.9446 |
| +4000 | 220.02 | 230.69 | 0.9537 |
| +4500 | 220.02 | 228.49 | 0.9629 |
| +5000 | 220.02 | 226.33 | 0.9721 |
| +5500 | 220.02 | 224.22 | 0.9813 |
| +6000 | 220.02 | 222.95 | 0.9868 |
| +6500 | 220.02 | 222.10 | 0.9906 |
| +7000 | 220.02 | 221.25 | 0.9944 |
| +7500 | 220.02 | 220.42 | 0.9982 |
| +8000 | 220.02 | 219.58 | 1.0020 |
| +8500 | 220.02 | 219.03 | 1.0045 |
| +9000 | 220.02 | 218.62 | 1.0064 |
| +9500 | 220.02 | 218.21 | 1.0083 |
| +10000 | 220.02 | 217.80 | 1.0102 |
| +10500 | 220.02 | 217.39 | 1.0121 |
| +11000 | 220.02 | 217.03 | 1.0138 |
| +11500 | 220.02 | 216.70 | 1.0153 |
| +12000 | 220.02 | 216.37 | 1.0169 |
| +12500 | 220.02 | 216.03 | 1.0184 |
| +13000 | 220.02 | 215.70 | 1.0200 |
| +13500 | 220.02 | 215.35 | 1.0217 |
| +14000 | 220.02 | 214.98 | 1.0234 |
| +14500 | 220.02 | 214.62 | 1.0251 |
| +15000 | 220.02 | 214.26 | 1.0269 |
| +15500 | 220.02 | 213.90 | 1.0286 |
| +16000 | 220.02 | 231.47 | 0.9505 |
| +16500 | 220.02 | 229.30 | 0.9595 |
| +17000 | 220.02 | 227.17 | 0.9685 |
| +17500 | 220.02 | 225.08 | 0.9775 |
| +18000 | 220.02 | 223.03 | 0.9865 |
| +18500 | 220.02 | 221.84 | 0.9918 |
| +19000 | 220.02 | 221.07 | 0.9953 |
| +19500 | 220.02 | 220.29 | 0.9987 |
| +20000 | 220.02 | 219.53 | 1.0022 |
| +20500 | 220.02 | 218.77 | 1.0057 |
| +21000 | 220.02 | 218.25 | 1.0081 |
| +21500 | 220.02 | 217.84 | 1.0100 |
| +22000 | 220.02 | 217.43 | 1.0119 |

| Net Output Degradation Factor - OC (HSD) | | |
|--|----------------------------------|-------------------|
| Calculated Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 174.38 | 174.38 | 1.0000 |
| 174.38 | 171.77 | 1.0151 |
| 174.38 | 171.46 | 1.0170 |
| 174.38 | 171.16 | 1.0188 |
| 174.38 | 170.88 | 1.0205 |
| 174.38 | 170.59 | 1.0222 |
| 174.38 | 170.31 | 1.0239 |
| 174.38 | 170.03 | 1.0256 |
| 174.38 | 186.49 | 0.9350 |
| 174.38 | 184.40 | 0.9456 |
| 174.38 | 182.36 | 0.9562 |
| 174.38 | 180.36 | 0.9668 |
| 174.38 | 178.40 | 0.9774 |
| 174.38 | 177.23 | 0.9839 |
| 174.38 | 176.43 | 0.9883 |
| 174.38 | 175.64 | 0.9928 |
| 174.38 | 174.86 | 0.9972 |
| 174.38 | 174.09 | 1.0017 |
| 174.38 | 173.57 | 1.0046 |
| 174.38 | 173.19 | 1.0069 |
| 174.38 | 172.80 | 1.0091 |
| 174.38 | 172.42 | 1.0113 |
| 174.38 | 172.04 | 1.0136 |
| 174.38 | 171.70 | 1.0156 |
| 174.38 | 171.39 | 1.0174 |
| 174.38 | 171.08 | 1.0192 |
| 174.38 | 170.78 | 1.0211 |
| 174.38 | 170.47 | 1.0229 |
| 174.38 | 170.14 | 1.0249 |
| 174.38 | 169.80 | 1.0270 |
| 174.38 | 169.46 | 1.0290 |
| 174.38 | 169.12 | 1.0311 |
| 174.38 | 168.78 | 1.0331 |
| 174.38 | 185.10 | 0.9421 |
| 174.38 | 183.09 | 0.9524 |
| 174.38 | 181.11 | 0.9628 |
| 174.38 | 179.19 | 0.9732 |
| 174.38 | 177.30 | 0.9835 |
| 174.38 | 176.19 | 0.9897 |
| 174.38 | 175.47 | 0.9938 |
| 174.38 | 174.75 | 0.9979 |
| 174.38 | 174.03 | 1.0020 |
| 174.38 | 173.32 | 1.0061 |
| 174.38 | 172.83 | 1.0089 |
| 174.38 | 172.45 | 1.0112 |
| 174.38 | 172.07 | 1.0134 |

(Signature)



Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - HSD Operations

| Net Output Degradation Factor - CC (HSD) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +22500 | 220.02 | 217.03 | 1.0138 |
| +23000 | 220.02 | 216.63 | 1.0157 |
| +23500 | 220.02 | 216.27 | 1.0173 |
| +24000 | 220.02 | 215.93 | 1.0189 |
| +24500 | 220.02 | 215.60 | 1.0205 |
| +25000 | 220.02 | 215.27 | 1.0221 |
| +25500 | 220.02 | 214.94 | 1.0236 |
| +26000 | 220.02 | 214.54 | 1.0255 |
| +26500 | 220.02 | 214.11 | 1.0276 |
| +27000 | 220.02 | 213.69 | 1.0296 |
| +27500 | 220.02 | 213.26 | 1.0317 |
| +28000 | 220.02 | 212.84 | 1.0337 |
| +28500 | 220.02 | 242.65 | 0.9067 |
| +29000 | 220.02 | 239.86 | 0.9173 |
| +29500 | 220.02 | 237.14 | 0.9278 |
| +30000 | 220.02 | 234.47 | 0.9384 |
| +30500 | 220.02 | 231.87 | 0.9489 |
| +31000 | 220.02 | 229.96 | 0.9568 |
| +31500 | 220.02 | 228.38 | 0.9634 |
| +32000 | 220.02 | 226.83 | 0.9700 |
| +32500 | 220.02 | 225.30 | 0.9766 |
| +33000 | 220.02 | 223.79 | 0.9831 |
| +33500 | 220.02 | 222.84 | 0.9873 |
| +34000 | 220.02 | 222.16 | 0.9903 |
| +34500 | 220.02 | 221.49 | 0.9934 |
| +35000 | 220.02 | 220.82 | 0.9964 |
| +35500 | 220.02 | 220.15 | 0.9994 |
| +36000 | 220.02 | 219.67 | 1.0016 |
| +36500 | 220.02 | 219.28 | 1.0034 |
| +37000 | 220.02 | 218.89 | 1.0052 |
| +37500 | 220.02 | 218.50 | 1.0070 |
| +38000 | 220.02 | 218.11 | 1.0088 |
| +38500 | 220.02 | 217.78 | 1.0103 |
| +39000 | 220.02 | 217.48 | 1.0117 |
| +39500 | 220.02 | 217.19 | 1.0130 |
| +40000 | 220.02 | 216.89 | 1.0144 |
| +40500 | 220.02 | 216.60 | 1.0158 |
| +41000 | 220.02 | 235.00 | 0.9363 |
| +41500 | 220.02 | 232.80 | 0.9451 |
| +42000 | 220.02 | 230.65 | 0.9539 |
| +42500 | 220.02 | 228.53 | 0.9628 |
| +43000 | 220.02 | 226.45 | 0.9716 |
| +43500 | 220.02 | 225.08 | 0.9775 |
| +44000 | 220.02 | 224.05 | 0.9820 |
| +44500 | 220.02 | 223.03 | 0.9865 |
| +45000 | 220.02 | 222.02 | 0.9910 |
| +45500 | 220.02 | 221.02 | 0.9955 |

| Net Output Degradation Factor - OC (HSD) | | |
|--|----------------------------------|-------------------|
| Calculated Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 174.38 | 171.69 | 1.0156 |
| 174.38 | 171.31 | 1.0179 |
| 174.38 | 170.97 | 1.0199 |
| 174.38 | 170.66 | 1.0218 |
| 174.38 | 170.35 | 1.0236 |
| 174.38 | 170.03 | 1.0255 |
| 174.38 | 169.72 | 1.0274 |
| 174.38 | 169.35 | 1.0297 |
| 174.38 | 168.96 | 1.0321 |
| 174.38 | 168.56 | 1.0345 |
| 174.38 | 168.17 | 1.0369 |
| 174.38 | 167.78 | 1.0393 |
| 174.38 | 196.53 | 0.8873 |
| 174.38 | 193.78 | 0.8999 |
| 174.38 | 191.10 | 0.9125 |
| 174.38 | 188.50 | 0.9251 |
| 174.38 | 185.96 | 0.9377 |
| 174.38 | 184.13 | 0.9470 |
| 174.38 | 182.64 | 0.9547 |
| 174.38 | 181.18 | 0.9624 |
| 174.38 | 179.74 | 0.9702 |
| 174.38 | 178.32 | 0.9779 |
| 174.38 | 177.43 | 0.9828 |
| 174.38 | 176.80 | 0.9863 |
| 174.38 | 176.17 | 0.9898 |
| 174.38 | 175.54 | 0.9933 |
| 174.38 | 174.92 | 0.9969 |
| 174.38 | 174.48 | 0.9994 |
| 174.38 | 174.11 | 1.0015 |
| 174.38 | 173.74 | 1.0036 |
| 174.38 | 173.38 | 1.0057 |
| 174.38 | 173.02 | 1.0078 |
| 174.38 | 172.70 | 1.0097 |
| 174.38 | 172.40 | 1.0114 |
| 174.38 | 172.11 | 1.0132 |
| 174.38 | 171.81 | 1.0149 |
| 174.38 | 171.52 | 1.0166 |
| 174.38 | 188.74 | 0.9239 |
| 174.38 | 186.64 | 0.9343 |
| 174.38 | 184.58 | 0.9447 |
| 174.38 | 182.57 | 0.9551 |
| 174.38 | 180.60 | 0.9655 |
| 174.38 | 179.30 | 0.9725 |
| 174.38 | 178.32 | 0.9779 |
| 174.38 | 177.35 | 0.9832 |
| 174.38 | 176.39 | 0.9886 |
| 174.38 | 175.44 | 0.9940 |

(Signature)



(Signature)

(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - HSD Operations

| Net Output Degradation Factor - CC (HSD) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +46000 | 220.02 | 220.39 | 0.9983 |
| +46500 | 220.02 | 219.94 | 1.0003 |
| +47000 | 220.02 | 219.50 | 1.0024 |
| +47500 | 220.02 | 219.05 | 1.0044 |
| +48000 | 220.02 | 218.61 | 1.0064 |
| +48500 | 220.02 | 218.22 | 1.0082 |
| +49000 | 220.02 | 217.87 | 1.0099 |
| +49500 | 220.02 | 217.51 | 1.0115 |
| +50000 | 220.02 | 217.16 | 1.0132 |
| +50500 | 220.02 | 216.81 | 1.0148 |
| +51000 | 220.02 | 216.48 | 1.0164 |
| +51500 | 220.02 | 216.16 | 1.0179 |
| +52000 | 220.02 | 215.84 | 1.0194 |
| +52500 | 220.02 | 215.52 | 1.0209 |
| +53000 | 220.02 | 215.21 | 1.0224 |
| +53500 | 220.02 | 232.89 | 0.9447 |
| +54000 | 220.02 | 230.64 | 0.9539 |
| +54500 | 220.02 | 228.44 | 0.9631 |
| +55000 | 220.02 | 226.28 | 0.9723 |
| +55500 | 220.02 | 224.15 | 0.9815 |
| +56000 | 220.02 | 222.89 | 0.9871 |
| +56500 | 220.02 | 222.03 | 0.9909 |
| +57000 | 220.02 | 221.18 | 0.9948 |
| +57500 | 220.02 | 220.33 | 0.9986 |
| +58000 | 220.02 | 219.49 | 1.0024 |
| +58500 | 220.02 | 218.94 | 1.0049 |
| +59000 | 220.02 | 218.53 | 1.0068 |
| +59500 | 220.02 | 218.12 | 1.0087 |
| +60000 | 220.02 | 217.71 | 1.0106 |
| +60500 | 220.02 | 217.30 | 1.0125 |
| +61000 | 220.02 | 216.94 | 1.0142 |
| +61500 | 220.02 | 216.60 | 1.0158 |
| +62000 | 220.02 | 216.27 | 1.0174 |
| +62500 | 220.02 | 215.93 | 1.0189 |
| +63000 | 220.02 | 215.60 | 1.0205 |
| +63500 | 220.02 | 215.24 | 1.0222 |
| +64000 | 220.02 | 214.88 | 1.0239 |
| +64500 | 220.02 | 214.52 | 1.0256 |
| +65000 | 220.02 | 214.16 | 1.0274 |
| +65500 | 220.02 | 213.79 | 1.0291 |
| +66000 | 220.02 | 231.34 | 0.9510 |
| +66500 | 220.02 | 229.18 | 0.9600 |
| +67000 | 220.02 | 227.05 | 0.9690 |
| +67500 | 220.02 | 224.96 | 0.9780 |
| +68000 | 220.02 | 222.92 | 0.9870 |
| +68500 | 220.02 | 221.73 | 0.9923 |
| +69000 | 220.02 | 220.95 | 0.9958 |

| Net Output Degradation Factor - OC (HSD) | | |
|--|----------------------------------|-------------------|
| Calculated Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 174.38 | 174.83 | 0.9974 |
| 174.38 | 174.39 | 0.9999 |
| 174.38 | 173.95 | 1.0024 |
| 174.38 | 173.51 | 1.0050 |
| 174.38 | 173.08 | 1.0075 |
| 174.38 | 172.72 | 1.0096 |
| 174.38 | 172.41 | 1.0114 |
| 174.38 | 172.09 | 1.0133 |
| 174.38 | 171.77 | 1.0151 |
| 174.38 | 171.46 | 1.0170 |
| 174.38 | 171.16 | 1.0188 |
| 174.38 | 170.88 | 1.0205 |
| 174.38 | 170.59 | 1.0222 |
| 174.38 | 170.31 | 1.0239 |
| 174.38 | 170.03 | 1.0256 |
| 174.38 | 186.49 | 0.9350 |
| 174.38 | 184.40 | 0.9456 |
| 174.38 | 182.36 | 0.9562 |
| 174.38 | 180.36 | 0.9668 |
| 174.38 | 178.40 | 0.9774 |
| 174.38 | 177.23 | 0.9839 |
| 174.38 | 176.43 | 0.9883 |
| 174.38 | 175.64 | 0.9928 |
| 174.38 | 174.86 | 0.9972 |
| 174.38 | 174.09 | 1.0017 |
| 174.38 | 173.57 | 1.0046 |
| 174.38 | 173.19 | 1.0069 |
| 174.38 | 172.80 | 1.0091 |
| 174.38 | 172.42 | 1.0113 |
| 174.38 | 172.04 | 1.0136 |
| 174.38 | 171.70 | 1.0156 |
| 174.38 | 171.39 | 1.0174 |
| 174.38 | 171.08 | 1.0192 |
| 174.38 | 170.78 | 1.0211 |
| 174.38 | 170.47 | 1.0229 |
| 174.38 | 170.14 | 1.0249 |
| 174.38 | 169.80 | 1.0270 |
| 174.38 | 169.46 | 1.0290 |
| 174.38 | 169.12 | 1.0311 |
| 174.38 | 168.78 | 1.0331 |
| 174.38 | 185.10 | 0.9421 |
| 174.38 | 183.09 | 0.9524 |
| 174.38 | 181.11 | 0.9628 |
| 174.38 | 179.19 | 0.9732 |
| 174.38 | 177.30 | 0.9835 |
| 174.38 | 176.19 | 0.9897 |
| 174.38 | 175.47 | 0.9938 |

(Signature)



(Signature)

(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - HSD Operations

| Net Output Degradation Factor - CC (HSD) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +69500 | 220.02 | 220.18 | 0.9993 |
| +70000 | 220.02 | 219.41 | 1.0028 |
| +70500 | 220.02 | 218.65 | 1.0062 |
| +71000 | 220.02 | 218.13 | 1.0086 |
| +71500 | 220.02 | 217.72 | 1.0105 |
| +72000 | 220.02 | 217.32 | 1.0124 |
| +72500 | 220.02 | 216.91 | 1.0143 |
| +73000 | 220.02 | 216.51 | 1.0162 |
| +73500 | 220.02 | 216.15 | 1.0179 |
| +74000 | 220.02 | 215.82 | 1.0195 |
| +74500 | 220.02 | 215.48 | 1.0210 |
| +75000 | 220.02 | 215.15 | 1.0226 |
| +75500 | 220.02 | 214.82 | 1.0242 |
| +76000 | 220.02 | 214.42 | 1.0261 |
| +76500 | 220.02 | 213.99 | 1.0281 |
| +77000 | 220.02 | 213.57 | 1.0302 |
| +77500 | 220.02 | 213.14 | 1.0323 |
| +78000 | 220.02 | 212.72 | 1.0343 |
| +78500 | 220.02 | 242.49 | 0.9073 |
| +79000 | 220.02 | 239.71 | 0.9179 |
| +79500 | 220.02 | 236.99 | 0.9284 |
| +80000 | 220.02 | 234.32 | 0.9389 |
| +80500 | 220.02 | 231.72 | 0.9495 |
| +81000 | 220.02 | 229.81 | 0.9574 |
| +81500 | 220.02 | 228.24 | 0.9640 |
| +82000 | 220.02 | 226.69 | 0.9706 |
| +82500 | 220.02 | 225.16 | 0.9772 |
| +83000 | 220.02 | 223.65 | 0.9838 |
| +83500 | 220.02 | 222.70 | 0.9880 |
| +84000 | 220.02 | 222.02 | 0.9910 |
| +84500 | 220.02 | 221.34 | 0.9940 |
| +85000 | 220.02 | 220.67 | 0.9970 |
| +85500 | 220.02 | 220.01 | 1.0001 |
| +86000 | 220.02 | 219.52 | 1.0023 |
| +86500 | 220.02 | 219.13 | 1.0041 |
| +87000 | 220.02 | 218.73 | 1.0059 |
| +87500 | 220.02 | 218.34 | 1.0077 |
| +88000 | 220.02 | 217.95 | 1.0095 |
| +88500 | 220.02 | 217.61 | 1.0111 |
| +89000 | 220.02 | 217.29 | 1.0126 |
| +89500 | 220.02 | 216.97 | 1.0140 |
| +90000 | 220.02 | 216.66 | 1.0155 |
| +90500 | 220.02 | 216.34 | 1.0170 |
| +91000 | 220.02 | 234.67 | 0.9376 |
| +91500 | 220.02 | 232.45 | 0.9465 |
| +92000 | 220.02 | 230.28 | 0.9554 |
| +92500 | 220.02 | 228.15 | 0.9644 |

| Net Output Degradation Factor - OC (HSD) | | |
|--|----------------------------------|-------------------|
| Calculated Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 174.38 | 174.75 | 0.9979 |
| 174.38 | 174.03 | 1.0020 |
| 174.38 | 173.32 | 1.0061 |
| 174.38 | 172.83 | 1.0089 |
| 174.38 | 172.45 | 1.0112 |
| 174.38 | 172.07 | 1.0134 |
| 174.38 | 171.69 | 1.0156 |
| 174.38 | 171.31 | 1.0179 |
| 174.38 | 170.97 | 1.0199 |
| 174.38 | 170.66 | 1.0218 |
| 174.38 | 170.35 | 1.0236 |
| 174.38 | 170.03 | 1.0255 |
| 174.38 | 169.72 | 1.0274 |
| 174.38 | 169.35 | 1.0297 |
| 174.38 | 168.96 | 1.0321 |
| 174.38 | 168.56 | 1.0345 |
| 174.38 | 168.17 | 1.0369 |
| 174.38 | 167.78 | 1.0393 |
| 174.38 | 196.53 | 0.8873 |
| 174.38 | 193.78 | 0.8999 |
| 174.38 | 191.10 | 0.9125 |
| 174.38 | 188.50 | 0.9251 |
| 174.38 | 185.96 | 0.9377 |
| 174.38 | 184.13 | 0.9470 |
| 174.38 | 182.64 | 0.9547 |
| 174.38 | 181.18 | 0.9624 |
| 174.38 | 179.74 | 0.9702 |
| 174.38 | 178.32 | 0.9779 |
| 174.38 | 177.43 | 0.9828 |
| 174.38 | 176.80 | 0.9863 |
| 174.38 | 176.17 | 0.9898 |
| 174.38 | 175.54 | 0.9933 |
| 174.38 | 174.92 | 0.9969 |
| 174.38 | 174.48 | 0.9994 |
| 174.38 | 174.11 | 1.0015 |
| 174.38 | 173.74 | 1.0036 |
| 174.38 | 173.38 | 1.0057 |
| 174.38 | 173.02 | 1.0078 |
| 174.38 | 172.70 | 1.0097 |
| 174.38 | 172.40 | 1.0114 |
| 174.38 | 172.11 | 1.0132 |
| 174.38 | 171.81 | 1.0149 |
| 174.38 | 171.52 | 1.0166 |
| 174.38 | 188.74 | 0.9239 |
| 174.38 | 186.64 | 0.9343 |
| 174.38 | 184.58 | 0.9447 |
| 174.38 | 182.57 | 0.9551 |

(Signature)



(Signature)

(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - HSD Operations

| Net Output Degradation Factor - CC (HSD) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +93000 | 220.02 | 226.05 | 0.9733 |
| +93500 | 220.02 | 224.67 | 0.9793 |
| +94000 | 220.02 | 223.62 | 0.9839 |
| +94500 | 220.02 | 222.58 | 0.9885 |
| +95000 | 220.02 | 221.55 | 0.9931 |
| +95500 | 220.02 | 220.54 | 0.9977 |
| +96000 | 220.02 | 219.89 | 1.0006 |
| +96500 | 220.02 | 219.42 | 1.0027 |
| +97000 | 220.02 | 218.96 | 1.0048 |
| +97500 | 220.02 | 218.50 | 1.0070 |
| +98000 | 220.02 | 218.04 | 1.0091 |
| +98500 | 220.02 | 217.66 | 1.0108 |
| +99000 | 220.02 | 217.34 | 1.0123 |
| +99500 | 220.02 | 217.01 | 1.0139 |
| +100000 | 220.02 | 216.68 | 1.0154 |
| +100500 | 220.02 | 216.36 | 1.0169 |
| +101000 | 220.02 | 216.06 | 1.0183 |
| +101500 | 220.02 | 215.77 | 1.0197 |
| +102000 | 220.02 | 215.48 | 1.0211 |
| +102500 | 220.02 | 215.19 | 1.0225 |
| +103000 | 220.02 | 214.90 | 1.0238 |
| +103500 | 220.02 | 232.55 | 0.9461 |
| +104000 | 220.02 | 230.33 | 0.9552 |
| +104500 | 220.02 | 228.16 | 0.9643 |
| +105000 | 220.02 | 226.02 | 0.9734 |
| +105500 | 220.02 | 223.93 | 0.9825 |
| +106000 | 220.02 | 222.68 | 0.9880 |
| +106500 | 220.02 | 221.85 | 0.9917 |
| +107000 | 220.02 | 221.02 | 0.9955 |
| +107500 | 220.02 | 220.20 | 0.9992 |
| +108000 | 220.02 | 219.38 | 1.0029 |
| +108500 | 220.02 | 218.83 | 1.0054 |
| +109000 | 220.02 | 218.41 | 1.0074 |
| +109500 | 220.02 | 217.99 | 1.0093 |
| +110000 | 220.02 | 217.57 | 1.0112 |
| +110500 | 220.02 | 217.16 | 1.0132 |
| +111000 | 220.02 | 216.79 | 1.0149 |
| +111500 | 220.02 | 216.44 | 1.0165 |
| +112000 | 220.02 | 216.10 | 1.0181 |
| +112500 | 220.02 | 215.76 | 1.0197 |
| +113000 | 220.02 | 215.42 | 1.0213 |
| +113500 | 220.02 | 215.06 | 1.0230 |
| +114000 | 220.02 | 214.69 | 1.0248 |
| +114500 | 220.02 | 214.32 | 1.0266 |
| +115000 | 220.02 | 213.95 | 1.0283 |
| +115500 | 220.02 | 213.59 | 1.0301 |
| +116000 | 220.02 | 231.09 | 0.9521 |

| Net Output Degradation Factor - OC (HSD) | | |
|--|----------------------------------|-------------------|
| Calculated Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 174.38 | 180.60 | 0.9655 |
| 174.38 | 179.30 | 0.9725 |
| 174.38 | 178.32 | 0.9779 |
| 174.38 | 177.35 | 0.9832 |
| 174.38 | 176.39 | 0.9886 |
| 174.38 | 175.44 | 0.9940 |
| 174.38 | 174.83 | 0.9974 |
| 174.38 | 174.39 | 0.9999 |
| 174.38 | 173.95 | 1.0024 |
| 174.38 | 173.51 | 1.0050 |
| 174.38 | 173.08 | 1.0075 |
| 174.38 | 172.72 | 1.0096 |
| 174.38 | 172.41 | 1.0114 |
| 174.38 | 172.09 | 1.0133 |
| 174.38 | 171.77 | 1.0151 |
| 174.38 | 171.46 | 1.0170 |
| 174.38 | 171.16 | 1.0188 |
| 174.38 | 170.88 | 1.0205 |
| 174.38 | 170.59 | 1.0222 |
| 174.38 | 170.31 | 1.0239 |
| 174.38 | 170.03 | 1.0256 |
| 174.38 | 186.49 | 0.9350 |
| 174.38 | 184.40 | 0.9456 |
| 174.38 | 182.36 | 0.9562 |
| 174.38 | 180.36 | 0.9668 |
| 174.38 | 178.40 | 0.9774 |
| 174.38 | 177.23 | 0.9839 |
| 174.38 | 176.43 | 0.9883 |
| 174.38 | 175.64 | 0.9928 |
| 174.38 | 174.86 | 0.9972 |
| 174.38 | 174.09 | 1.0017 |
| 174.38 | 173.57 | 1.0046 |
| 174.38 | 173.19 | 1.0069 |
| 174.38 | 172.80 | 1.0091 |
| 174.38 | 172.42 | 1.0113 |
| 174.38 | 172.04 | 1.0136 |
| 174.38 | 171.70 | 1.0156 |
| 174.38 | 171.39 | 1.0174 |
| 174.38 | 171.08 | 1.0192 |
| 174.38 | 170.78 | 1.0211 |
| 174.38 | 170.47 | 1.0229 |
| 174.38 | 170.14 | 1.0249 |
| 174.38 | 169.80 | 1.0270 |
| 174.38 | 169.46 | 1.0290 |
| 174.38 | 169.12 | 1.0311 |
| 174.38 | 168.78 | 1.0331 |
| 174.38 | 185.10 | 0.9421 |

(Signature)



(Signature)

(Signature)

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - HSD Operations

| Net Output Degradation Factor - CC (HSD) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +116500 | 220.02 | 228.92 | 0.9611 |
| +117000 | 220.02 | 226.79 | 0.9701 |
| +117500 | 220.02 | 224.70 | 0.9792 |
| +118000 | 220.02 | 222.65 | 0.9882 |
| +118500 | 220.02 | 221.46 | 0.9935 |
| +119000 | 220.02 | 220.68 | 0.9970 |
| +119500 | 220.02 | 219.90 | 1.0005 |
| +120000 | 220.02 | 219.14 | 1.0040 |
| +120500 | 220.02 | 218.37 | 1.0075 |
| +121000 | 220.02 | 217.85 | 1.0100 |
| +121500 | 220.02 | 217.44 | 1.0119 |
| +122000 | 220.02 | 217.02 | 1.0138 |
| +122500 | 220.02 | 216.62 | 1.0157 |
| +123000 | 220.02 | 216.21 | 1.0176 |
| +123500 | 220.02 | 215.85 | 1.0193 |
| +124000 | 220.02 | 215.52 | 1.0209 |
| +124500 | 220.02 | 215.18 | 1.0225 |
| +125000 | 220.02 | 214.85 | 1.0241 |
| +125500 | 220.02 | 214.52 | 1.0256 |
| +126000 | 220.02 | 214.12 | 1.0275 |
| +126500 | 220.02 | 213.69 | 1.0296 |
| +127000 | 220.02 | 213.27 | 1.0317 |
| +127500 | 220.02 | 212.84 | 1.0337 |
| +128000 | 220.02 | 212.42 | 1.0358 |
| +128500 | 220.02 | 242.10 | 0.9088 |
| +129000 | 220.02 | 239.33 | 0.9193 |
| +129500 | 220.02 | 236.62 | 0.9298 |
| +130000 | 220.02 | 233.97 | 0.9404 |
| +130500 | 220.02 | 231.38 | 0.9509 |
| +131000 | 220.02 | 229.47 | 0.9588 |
| +131500 | 220.02 | 227.91 | 0.9654 |
| +132000 | 220.02 | 226.36 | 0.9720 |
| +132500 | 220.02 | 224.84 | 0.9786 |
| +133000 | 220.02 | 223.34 | 0.9851 |
| +133500 | 220.02 | 222.39 | 0.9893 |
| +134000 | 220.02 | 221.72 | 0.9923 |
| +134500 | 220.02 | 221.04 | 0.9954 |
| +135000 | 220.02 | 220.38 | 0.9984 |
| +135500 | 220.02 | 219.72 | 1.0014 |
| +136000 | 220.02 | 219.23 | 1.0036 |
| +136500 | 220.02 | 218.84 | 1.0054 |
| +137000 | 220.02 | 218.45 | 1.0072 |
| +137500 | 220.02 | 218.06 | 1.0090 |
| +138000 | 220.02 | 217.68 | 1.0108 |
| +138500 | 220.02 | 217.34 | 1.0123 |
| +139000 | 220.02 | 217.02 | 1.0138 |
| +139500 | 220.02 | 216.70 | 1.0153 |

| Net Output Degradation Factor - OC (HSD) | | |
|--|----------------------------------|-------------------|
| Calculated Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 174.38 | 183.09 | 0.9524 |
| 174.38 | 181.11 | 0.9628 |
| 174.38 | 179.19 | 0.9732 |
| 174.38 | 177.30 | 0.9835 |
| 174.38 | 176.19 | 0.9897 |
| 174.38 | 175.47 | 0.9938 |
| 174.38 | 174.75 | 0.9979 |
| 174.38 | 174.03 | 1.0020 |
| 174.38 | 173.32 | 1.0061 |
| 174.38 | 172.83 | 1.0089 |
| 174.38 | 172.45 | 1.0112 |
| 174.38 | 172.07 | 1.0134 |
| 174.38 | 171.69 | 1.0156 |
| 174.38 | 171.31 | 1.0179 |
| 174.38 | 170.97 | 1.0199 |
| 174.38 | 170.66 | 1.0218 |
| 174.38 | 170.35 | 1.0236 |
| 174.38 | 170.03 | 1.0255 |
| 174.38 | 169.72 | 1.0274 |
| 174.38 | 169.35 | 1.0297 |
| 174.38 | 168.96 | 1.0321 |
| 174.38 | 168.56 | 1.0345 |
| 174.38 | 168.17 | 1.0369 |
| 174.38 | 167.78 | 1.0393 |
| 174.38 | 196.53 | 0.8873 |
| 174.38 | 193.78 | 0.8999 |
| 174.38 | 191.10 | 0.9125 |
| 174.38 | 188.50 | 0.9251 |
| 174.38 | 185.96 | 0.9377 |
| 174.38 | 184.13 | 0.9470 |
| 174.38 | 182.64 | 0.9547 |
| 174.38 | 181.18 | 0.9624 |
| 174.38 | 179.74 | 0.9702 |
| 174.38 | 178.32 | 0.9779 |
| 174.38 | 177.43 | 0.9828 |
| 174.38 | 176.80 | 0.9863 |
| 174.38 | 176.17 | 0.9898 |
| 174.38 | 175.54 | 0.9933 |
| 174.38 | 174.92 | 0.9969 |
| 174.38 | 174.48 | 0.9994 |
| 174.38 | 174.11 | 1.0015 |
| 174.38 | 173.74 | 1.0036 |
| 174.38 | 173.38 | 1.0057 |
| 174.38 | 173.02 | 1.0078 |
| 174.38 | 172.70 | 1.0097 |
| 174.38 | 172.40 | 1.0114 |
| 174.38 | 172.11 | 1.0132 |

Qury



Qury

Qury

Korangi Combined Cycle Power Plant (KCCPP)
Power Output Degradation Table - HSD Operations

| Net Output Degradation Factor - CC (HSD) | | | |
|--|-----------------------------------|------------------------------------|-------------------|
| Interval | Tested Combined Cycle Output (MW) | Revised Combined Cycle Output (MW) | Correction Factor |
| +140000 | 220.02 | 216.39 | 1.0168 |

| Net Output Degradation Factor - OC (HSD) | | |
|--|----------------------------------|-------------------|
| Calculated Simple Cycle Output (MW) | Revised Simple Cycle Output (MW) | Correction Factor |
| 174.38 | 171.81 | 1.0149 |

FY 21 : As per 3rd Party Heat Rate Test on HSD Fuel

FY 23 : As per actual operating hours. Operating hours at end of FY23 : 71,836 hours

Note: Simple cycle output has been computed from combined cycle 3rd party test results, by removing ST



| Project No. | Document Name | Document Number | Revision date | Prepared by |
|----------------|-------------------|-------------------------------------|---------------|--|
| IEI/KE/01/2022 | List of Documents | IEI/KE/01/2022 - PL - 001_A_Results | 13/08/2024 | IEI Stroenergo International, s.r.o. |

| Percent Load Factor | Correction Factor on Gas fuel for Combined Cycle |
|---------------------|--|
| 100.00% | 1.0000 |
| 95.00% | 1.0064 |
| 90.00% | 1.0143 |
| 85.00% | 1.0232 |
| 80.00% | 1.0347 |
| 75% (Note-1) | 1.0533 |
| 71.00% | 1.0104 |
| 67.00% | 1.0383 |
| 64.00% | 1.0380 |
| 60.00% | 1.0400 |
| 56.00% | 1.0545 |
| 53.00% | 1.0736 |
| 49% (Note-2) | 1.0428 |
| 47.00% | 1.0525 |
| 44.00% | 1.0631 |
| 42.00% | 1.0763 |
| 40.00% | 1.0934 |
| 37.00% | 1.1123 |
| 35.00% | 1.1362 |
| 32.00% | 1.1680 |
| 30.00% | 1.2138 |
| 25% (Note-3) | 1.0643 |
| 24.00% | 1.0759 |
| 22.00% | 1.0888 |
| 21.00% | 1.1041 |
| 20.00% | 1.1279 |
| 19.00% | 1.1469 |
| 17.00% | 1.1741 |
| 16.00% | 1.2116 |
| 15.00% | 1.2619 |
| 12.00% | 1.4119 |
| 11.00% | 1.5157 |
| 10.00% | 1.6528 |
| 8.00% | 1.8466 |

Note-1 Heat Rate Values from 75% to 55% assumes 09 gas turbines in operation, this assumes 01 gas turbine will be shutdown
Note-2 Heat Rate Values from 49% to 30% assumes 03 gas turbines in operation, this assumes 02 gas turbine will be shutdown
Note-3 Heat Rate Values from 25% to 8% assumes 01 gas turbine in operation, this assumes 03 gas turbine will be shutdown

Note: Use linear interpolation when the load variation values fall between the stated values

IEI STROENERGO
INTERNATIONAL, s. r. o.

Průmyslová 2222, Brno, Czech Republic
IČO: 250 68 123, DIČ: CZ250 68 123
Výroba a montáž strojírenských zařízení

[Handwritten signature]



Mujid Munir

[Handwritten signature]

[Handwritten signature]

| Project | Document Name | Document Number | Revision date | Prepared by |
|---|--|------------------------------------|---------------|--|
| K-Electric Limited 348 MW Combined Cycle Power Plant Korangi Creek Karachi Pakistan | Part Load Adjustment Factor Table for Hot Heat Rate (Natural Gas Fuel) | 01/02/04/2022 PL - GSA, A, Basinda | 11.12.2022 | IEI Stroenergo International, s.r.o. |

| Percent Load Factor | Correction Factor on Gas Heat for Simple Cycle |
|---------------------|--|
| 100.00% | 1.0000 |
| 95.00% | 1.0047 |
| 90.00% | 1.0112 |
| 85.00% | 1.0209 |
| 80.00% | 1.0333 |
| 75% (Note-1) | 0.9983 |
| 70.00% | 1.0027 |
| 65.00% | 1.0090 |
| 60.00% | 1.0185 |
| 55.00% | 1.0307 |
| 50.00% | 1.0460 |
| 45.00% | 1.0653 |
| 40.00% | 1.0881 |
| 35.00% | 1.1243 |
| 30.00% | 1.1626 |
| 25.00% | 1.2095 |
| 20.00% | 1.2643 |
| 15.00% | 1.3280 |
| 10.00% | 1.4000 |



Note-1: Heat Rate Values from 75% to 50% assumes G1 gas turbines in operation, the assumes G2 gas turbine will be shutdown
Note-2: Heat Rate Values from 30% to 20% assumes G2 gas turbines in operation, the assumes G1 gas turbine will be shutdown
Note-3: Heat Rate Values from 25% to 10% assumes G1 gas turbine in operation, the assumes G2 gas turbine will be shutdown

Note: Use linear interpolation when the load variation values fall between the stated values

IEI STROENERGO
INTERNATIONAL, s. r. o.
of A. Strojnicka 24 rČ. 35 520 984
884 01 Louny, Czechia rČ. IČV: 313520150005

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

| | | | | |
|-------------|-------------------|----------------------------------|---------------|---------------------------------------|
| Project No. | Document Name | Document Number | Revision Date | Prepared by |
| IEI/01/2022 | List of Documents | IEI/01/2022 - PL - 001_A_Results | 11/11/2024 | IEI Stroenergo International, s.p. |


| Percent Load Factor | Operation Factor (see Note-1 for the Calculation) |
|---------------------|---|
| 100.00% | 1.0000 |
| 95.00% | 1.0000 |
| 90.00% | 1.0000 |
| 85.00% | 1.0193 |
| 80.00% | 1.0294 |
| 75% (Note-1) | 1.007 |
| 71.00% | 1.0126 |
| 67.00% | 1.0197 |
| 63.00% | 1.0287 |
| 60.00% | 1.0368 |
| 56.00% | 1.0488 |
| 52.00% | 1.0588 |
| 48% (Note-2) | 1.0599 |
| 47.00% | 1.041 |
| 44.00% | 1.0486 |
| 42.00% | 1.06 |
| 39.00% | 1.0727 |
| 37.00% | 1.0841 |
| 34.00% | 1.0942 |
| 32.00% | 1.1074 |
| 30.00% | 1.1195 |
| 27.00% | 1.1367 |
| 25% (Note-3) | 1.0507 |
| 24.00% | 1.0593 |
| 22.00% | 1.0697 |
| 21.00% | 1.0824 |
| 20.00% | 1.0977 |
| 19.00% | 1.1116 |
| 17.00% | 1.1251 |
| 16.00% | 1.139 |
| 15.00% | 1.1562 |
| 12.00% | 1.3275 |
| 11.00% | 1.4245 |
| 10.00% | 1.5326 |
| 8.00% | 1.6789 |

Note-1 Heat Rate Values from 75% to 52% assumes C2 gas turbines in operation, this assumes C1 gas turbine will be shutdown

Note-2 Heat Rate Values from 48% to 27% assumes C2 gas turbines in operation, this assumes C1 gas turbine will be shutdown


Note-3 Heat Rate Values from 25% to 8% assumes C1 gas turbine in operation, this assumes C2 gas turbine will be shutdown


Note: Use linear interpolation when the load variation values fall between the stated values



STROENERGO
INTERNATIONAL, s. p. a.

Stroenergo International, s.p.a. is a company with registered office in Italy, at Via S. Stefano 10, 00187 Roma, Italy. Tel: +39 06 49811111. Fax: +39 06 49811112. Email: info@stroenergo.it





| Project | Document Name | Document Number | Revision date | Prepared by |
|---|---|----------------------------------|---------------|--|
| W-Electric Limited 248 MW Combined Cycle Power Plant Rawalpindi, Capital City, Pakistan | Part Load Adjustment Factor Table for Hot Heat Rate (HR) Fuel | W/HR/01/0002 - PL - HR_A_Results | 11.10.2022 | IEI International Engineering Services Pakistan (Pvt) Ltd. |

| Percent Load Factor | Correction Factor on HR for Simple Cycle |
|---------------------|--|
| 100.00% | 1.0000 |
| 95.00% | 1.0039 |
| 90.00% | 1.0080 |
| 85.00% | 1.0148 |
| 80.00% | 1.0228 |
| 75% (Note-1) | 1.0033 |
| 71.00% | 1.0074 |
| 68.00% | 1.0117 |
| 64.00% | 1.0188 |
| 60.00% | 1.0270 |
| 56.00% | 1.0394 |
| 52.00% | 1.0500 |
| 50% (Note-2) | 1.0093 |
| 45.00% | 1.0184 |
| 40.00% | 1.0347 |
| 35.00% | 1.0592 |
| 30.00% | 1.1014 |
| 25% (Note-3) | 1.0290 |
| 20.00% | 1.0604 |
| 15.00% | 1.1396 |
| 10.00% | 1.5381 |



- Note-1: Heat Rate Values from 75% to 52% assumes G1 gas turbine in operation, this assumes G2 gas turbine will be shutdown
- Note-2: Heat Rate Values from 50% to 20% assumes G2 gas turbine in operation, this assumes G1 gas turbine will be shutdown
- Note-3: Heat Rate Values from 25% to 10% assumes G1 gas turbine in operation, this assumes G2 gas turbine will be shutdown

Note: Use linear interpolation when the load variation values fall between the stated values.

IEI STROENERGO
INTERNATIONAL, s. r. l.

U A. Stradivari 24 ICD: 35 528 984
034 01 Lancia, Genova IC DPH: 340620135886

Korangi Combined Cycle Power Plant (KCCPP) Startup Cost - Gas

[illegible]

Note 3: Efficiency used above represents Base year efficiencies, which shall be updated based on applicable degradation as per the curve



17

| FUEL COMPLEX Startup | | 3 GT GC | | | | | | 2 GTCC (where 2 GTs already in CC Mode) | | | | | | GTCC (where 2 GTs already in CC Mode) | | | | | |
|--|------------------|------------------|------------------|------------------|------------------|------------------|------------------|---|------------------|------------------|------------------|------------------|------------------|---------------------------------------|------------------|------------------|------------------|--|--|
| Heat Startup | | Warm Startup | | Cold Startup | | Heat Startup | | Warm Startup | | Cold Startup | | Heat Startup | | Warm Startup | | Cold Startup | | | |
| 60 min | 9.17 MW | 60 min | 9.17 MW | 60 min | 9.17 MW | 60 min | 9.17 MW | 60 min | 9.17 MW | 60 min | 9.17 MW | 60 min | 9.17 MW | 60 min | 9.17 MW | 60 min | 9.17 MW | | |
| Baseline charges (EPlus GT Syrch) | | | | | | | | | | | | | | | | | | | |
| Baseline import duration | | | | | | | | | | | | | | | | | | | |
| 9.17 MW | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | | |
| Power import rate | | | | | | | | | | | | | | | | | | | |
| 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | 34.68 POC/Wh | | |
| Baseline charges | | | | | | | | | | | | | | | | | | | |
| 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | 357,229.57 POC | | |
| Gas prices (per MWh) | | | | | | | | | | | | | | | | | | | |
| 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | | |
| 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | 1,309.52 POC/MWh | | |
| Gas cost from start to 1 Syrch | | | | | | | | | | | | | | | | | | | |
| 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | | |
| Gas cost for operation up to 1 Syrch | | | | | | | | | | | | | | | | | | | |
| 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | 14,769.44 POC | | |
| Heat Cost Price GT Syrch operation up to 1 Syrch | | | | | | | | | | | | | | | | | | | |
| 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | | |
| Operation from GT Syrch to 1 Syrch | | | | | | | | | | | | | | | | | | | |
| 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | | |
| Load from GT Syrch to 1 Syrch (MW) | | | | | | | | | | | | | | | | | | | |
| 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | 34.68 MW | | |
| Load (Stage of base load of GT) | | | | | | | | | | | | | | | | | | | |
| 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | | |
| Baseline GT efficiency | | | | | | | | | | | | | | | | | | | |
| 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | | |
| Part load GT efficiency heat rate ratio | | | | | | | | | | | | | | | | | | | |
| 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | 92 min | 34.68 MW | | |
| Part load from GT Syrch to 1 Syrch | | | | | | | | | | | | | | | | | | | |



Ques

47

Karachi Combined Cycle Power Plant (KCCPP) Startup Cost - HSD

| | FULL COMPLEX Startup | | | | | | 2 GT CC | | | | | | 2 GT CC | | | | | |
|--|----------------------|-----------|--------------|-----------|--------------|-----------|-------------|-----------|--------------|-----------|--------------|-----------|-------------|-----------|--------------|-----------|--------------|-----------|
| Backfeed charges (Up to GT Synchron) | Hot Startup | | Warm Startup | | Cold Startup | | Hot Startup | | Warm Startup | | Cold Startup | | Hot Startup | | Warm Startup | | Cold Startup | |
| Backfeed import duration | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min |
| Power import | 3.70 | MW | 3.70 | MW | 3.70 | MW | 3.75 | MW | 3.75 | MW | 3.75 | MW | 2.30 | MW | 2.50 | MW | 2.50 | MW |
| Power import rate | 24.68 | PKR/MWh | 24.68 | PKR/MWh | 24.68 | PKR/MWh | 24.68 | PKR/MWh | 24.68 | PKR/MWh | 24.68 | PKR/MWh | 24.68 | PKR/MWh | 24.68 | PKR/MWh | 24.68 | PKR/MWh |
| Backfeed charge | 99,828.86 | PKR | 99,828.86 | PKR | 99,828.86 | PKR | 97,285.99 | PKR | 97,285.99 | PKR | 97,285.99 | PKR | 64,882.36 | PKR | 64,882.36 | PKR | 64,882.36 | PKR |
| HSD price (Baku) | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu | 6,066.91 | PKR/MMBtu |
| HSD GCV | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu | 36,252.36 | btu / Btu |
| Fuel Cost from GT Synchronisation on up to GT Synchronisation on HSD consumption from start to Sync | 1,560.00 | Liter | 1,560.00 | Liter | 1,560.00 | Liter | 1,170.00 | Liter | 1,170.00 | Liter | 1,170.00 | Liter | 780.00 | Liter | 780.00 | Liter | 780.00 | Liter |
| Fuel cost for operation up to sync | 349,586.40 | PKR | 349,586.40 | PKR | 349,586.40 | PKR | 257,529.88 | PKR | 257,529.88 | PKR | 257,529.88 | PKR | 171,553.38 | PKR | 171,553.38 | PKR | 171,553.38 | PKR |
| Fuel Cost from GT Synchronisation on up to GT Synchronisation on Operation from GT Synchronisation to ST Synchronisation | 52 | min | 144 | min | 220 | min | 52 | min | 144 | min | 220 | min | 52 | min | 144 | min | 220 | min |
| Lead from GT Synchronisation to ST Synchronisation (MW) | 100 | MW | 100 | MW | 100 | MW | 75 | MW | 75 | MW | 75 | MW | 50 | MW | 50 | MW | 50 | MW |
| Open Cycle Station base load | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW |
| Load (Range of base load of GT) | 57.44% | | 57.44% | | 57.44% | | 43.08% | | 43.08% | | 43.08% | | 28.72% | | 28.72% | | 28.72% | |
| Base load GT efficiency | 34.13% | | 34.13% | | 34.13% | | 34.13% | | 34.13% | | 34.13% | | 34.13% | | 34.13% | | 34.13% | |
| Part load GT efficiency heat rate ratio | 1.0349 | | 1.0349 | | 1.0349 | | 1.0347 | | 1.0347 | | 1.0347 | | 1.0349 | | 1.0349 | | 1.0349 | |
| Fuel cost from GT Synchronisation to ST Synchronisation | 5,842,889 | PKR | 15,867,576 | PKR | 25,849,908 | PKR | 4,440,279 | PKR | 11,186,464 | PKR | 17,993,487 | PKR | 2,846,519 | PKR | 7,882,658 | PKR | 12,842,848 | PKR |
| Start-up Charges (HSD Fuel) | 5,806,384 | PKR | 15,804,611 | PKR | 25,808,943 | PKR | 4,394,000 | PKR | 11,180,996 | PKR | 17,948,881 | PKR | 2,802,543 | PKR | 7,819,189 | PKR | 12,779,995 | PKR |
| Fuel Cost from GT Synchronisation on up to GT Synchronisation on Operation from GT Synchronisation to ST Synchronisation | 52 | min | 144 | min | 220 | min | 52 | min | 144 | min | 220 | min | 52 | min | 144 | min | 220 | min |
| Lead from GT Synchronisation to ST Synchronisation (MW) | 100 | MW | 100 | MW | 100 | MW | 75 | MW | 75 | MW | 75 | MW | 50 | MW | 50 | MW | 50 | MW |
| Base load GT efficiency (HSD) | 43.13% | | 43.13% | | 43.13% | | 43.13% | | 43.13% | | 43.13% | | 43.13% | | 43.13% | | 43.13% | |
| Part load GT efficiency heat rate ratio | 1 | | 1 | | 1 | | 1 | | 1 | | 1 | | 1 | | 1 | | 1 | |
| Revenue from GT Synchronisation to ST Synchronisation | 4,144,646 | PKR | 11,538,864 | PKR | 17,688,299 | PKR | 8,125,801 | PKR | 20,658,848 | PKR | 31,221,197 | PKR | 2,883,334 | PKR | 5,768,732 | PKR | 8,834,105 | PKR |
| Net Revenue | 1,711,837 | PKR | 9,988,147 | PKR | 5,880,734 | PKR | 1,389,812 | PKR | 2,895,150 | PKR | 4,128,884 | PKR | 889,627 | PKR | 2,349,571 | PKR | 3,066,290 | PKR |

Note 1: Formula for start up charges is given in position which includes MDI charge and Start up charge. Calculation of start up charge is given above

Note 2: Start up charge is to be included due to change in fuel price and Part unit charge for import based on latest applicable Consumer tariff rates and adjustments notified by Govt

Note 3: Efficiency above represent Base year efficiency, which shall be updated based on applicable degradation as per the curve



Karachi Combined Cycle Power Plant (KCCPP) Startup Cost - HSD

| | 1 GT CC | | | | | | 1 GT SC | | | | | | 2 GT CC (When 2 GTs already in CC Mode) | | | | | | 1 GT CC (When 2 GTs already in CC Mode) | | | | | |
|---|-------------|---------------|--------------|---------------|--------------|---------------|-------------|---------------|--------------|---------------|--------------|---------------|---|---------------|--------------|---------------|--------------|---------------|---|---------------|--------------|---------------|--------------|---------------|
| Backfeed charges (Up to GT Synchronisation) | Hot Startup | | Warm Startup | | Cold Startup | | Hot Startup | | Warm Startup | | Cold Startup | | Hot Startup | | Warm Startup | | Cold Startup | | Hot Startup | | Warm Startup | | Cold Startup | |
| Backfeed import duration | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min | 63 | min |
| Power import | 2.38 | MW | 2.38 | MW | 2.38 | MW | 1.40 | MW | 1.40 | MW | 1.40 | MW | 2.50 | MW | 2.50 | MW | 2.50 | MW | 2.38 | MW | 2.38 | MW | 2.38 | MW |
| Power import rate | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh | 24.68 | PKR/kWh |
| Backfeed charges | 61,794.17 | PKR | 61,794.17 | PKR | 61,794.17 | PKR | 36,374.08 | PKR | 36,374.08 | PKR | 36,374.08 | PKR | 64,882.36 | PKR | 64,882.36 | PKR | 64,882.36 | PKR | 61,794.17 | PKR | 61,794.17 | PKR | 61,794.17 | PKR |
| HSD price (MWh) | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh | 6,066.91 | PKR/MWh |
| HSD GCV | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter | 36,252.36 | litre / liter |
| Panel Cost Up to GT Synchronisation on HSD consumption from start to Sync | 390.00 | Litre | 390.00 | Litre | 390.00 | Litre | 390.00 | Litre | 390.00 | Litre | 390.00 | Litre | 780.00 | Litre | 780.00 | Litre | 780.00 | Litre | 390.00 | Litre | 390.00 | Litre | 390.00 | Litre |
| Fuel cost for operation up to sync | 86,776.68 | PKR | 86,776.68 | PKR | 86,776.68 | PKR | 86,776.68 | PKR | 86,776.68 | PKR | 86,776.68 | PKR | 171,553.36 | PKR | 171,553.36 | PKR | 171,553.36 | PKR | 86,776.68 | PKR | 86,776.68 | PKR | 86,776.68 | PKR |
| Panel Cost From GT Synchronisation on up to ST Synchronisation on Operation from GT Sync to ST Sync Load from GT Sync to ST Sync (MWh) Open Cycle Station base load | 52 | min | 144 | min | 220 | min | | | | | | | 52 | min | 144 | min | 220 | min | 52 | min | 144 | min | 220 | min |
| | 25 | MW | 25 | MW | 25 | MW | | | | | | | 50 | MW | 50 | MW | 50 | MW | 25 | MW | 25 | MW | 25 | MW |
| | 174.38 | MW | 174.38 | MW | 174.38 | MW | | | | | | | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW | 174.38 | MW |
| Load (Stage of base load of GT) | 14.36% | | 14.36% | | 14.36% | | | | | | | | 38.72% | | 28.72% | | 38.72% | | 14.36% | | 14.36% | | 14.36% | |
| Base load GT efficiency | 34.18% | | 34.18% | | 34.18% | | | | | | | | 34.18% | | 34.18% | | 34.18% | | 34.18% | | 34.18% | | 34.18% | |
| Part load GT efficiency base rate ratio | 1.1806 | | 1.1806 | | 1.1806 | | | | | | | | 1.0829 | | 1.0829 | | 1.0829 | | 1.1806 | | 1.1806 | | 1.1806 | |
| Fuel cost from GT Sync to ST Sync | 1,964,884 | PKR | 4,333,534 | PKR | 6,430,662 | PKR | | | | | | | 2,846,515 | PKR | 7,882,488 | PKR | 12,842,949 | PKR | 1,964,884 | PKR | 4,333,534 | PKR | 6,430,662 | PKR |
| Start-up Charges (MWh) | 1,712,825 | PKR | 4,481,053 | PKR | 6,768,193 | PKR | 132,315 | PKR | 132,315 | PKR | 132,315 | PKR | 3,882,845 | PKR | 8,115,183 | PKR | 12,278,396 | PKR | 1,712,825 | PKR | 4,481,053 | PKR | 6,768,193 | PKR |
| Panel GT Synchronisation on up to ST Synchronisation on Operation from GT Sync to ST Sync Load from GT Sync to ST Sync (MWh) | 52 | min | 144 | min | 220 | min | | | | | | | 52 | min | 144 | min | 220 | min | 52 | min | 144 | min | 220 | min |
| | 25 | MW | 25 | MW | 25 | MW | | | | | | | 50 | MW | 50 | MW | 50 | MW | 25 | MW | 25 | MW | 25 | MW |
| Base load Unit efficiency (MWh) | 43.13% | | 43.13% | | 43.13% | | | | | | | | 43.13% | | 43.13% | | 43.13% | | 43.13% | | 43.13% | | 43.13% | |
| Part load GT efficiency base rate ratio | 1 | | 1 | | 1 | | | | | | | | 1.0118 | | 1.0118 | | 1.0118 | | 1.0386 | | 1.0386 | | 1.0386 | |
| Minimum from GT Sync to ST Sync | 1,041,667 | PKR | 2,884,618 | PKR | 4,407,052 | PKR | | | | | | | 2,187,883 | PKR | 5,887,388 | PKR | 8,917,957 | PKR | 1,041,667 | PKR | 2,884,618 | PKR | 4,407,052 | PKR |
| Net Revenue | 679,748 | PKR | 1,506,688 | PKR | 2,364,141 | PKR | 133,110 | PKR | 133,110 | PKR | 133,110 | PKR | 979,880 | PKR | 2,364,141 | PKR | 3,361,038 | PKR | 679,748 | PKR | 1,506,688 | PKR | 2,364,141 | PKR |

Note 1: Formula for start up charges is given in position which includes MWh charge and start up charge. Calculation of start up charge is given above
 Note 2: Start up charge is to be indexed due to change in fuel prices and Per unit charge for import based on latest applicable Consumer tariff rates and adjustments notified by GoP
 Note 3: Efficiencies used above represent three year efficiencies, which shall be updated based on applicable degradation as per the curve

M. J. Memon



| Black Start Cost - KCCPP | | | |
|---|----------------|------------|---|
| Cost For GT Startup | | | Remarks / References |
| EDG's Operation with Aux Till GT sync with 400V bus | 45 | min | |
| EDGS Specific Fuel Consumption (Base Load @ 1097KW) | 0.24 | Liter/KWh | |
| Aux Consumption Till GT Startup (KWh) | 571.94 | KWh | |
| Diesel Consumed By EDGs | 136.08 | Liters | |
| Rate of Diesel | 219.94 | PKR/Liter | Rate of Diesel @ 219.94 PKR/Liter for the month of August 2022. |
| Cost of Diesel Consumed by EDGs (A) | 29,929 | PKR | |
| Fuel Consumed by GT till Sync with 400V bus | 390 | Liter | |
| Cost of Fuel Consumed by GT till Sync with 400V bus (B) | 85,777 | PKR | |
| Cost of Diesel Consumed by EDGs & GT during startup C=(A+B) | 115,705 | PKR | |
| House Normalization time with GT on house Load (HV Switching) | 10 | Min | |
| GT House load operation time (EDG off - house load on GT) | 30 | Min | |
| Total Aux Load on GT for 40 Min after synchronization | 1,680 | KW | |
| GT fuel flow during 40 Min operation (while GT on house load) | 53 | LPM | |
| Fuel Consumption by GT in 40 Min. synchronization (while HV switching and GT on house load) | 2,120 | Liters | |
| Cost of Fuel Consumed by GT in 40 minuts "D" | 466,273 | PKR | |
| Cost of Diesel Consumed by GT E=(C+D) | 581,978 | PKR | |

| Fuel Cost From GT Synchronization up to ST Synchronization | Hot Startup | Warm Startup | Cold Startup |
|--|------------------|------------------|------------------|
| Operation from GT Synch to ST Synch (min) | 52 | 144 | 220 |
| Load from GT Synch to ST Synch (MW) | 25 | 25 | 25 |
| Open Cycle Station base load (MW) | 174.375 | 174.375 | 174.375 |
| HSD price (HHV) (Rs./MMBTU) | 6067 | 6067 | 6067 |
| Load (%age of base load of GT) | 14.36% | 14.36% | 14.36% |
| Baseload GT efficiency | 34.18% | 34.18% | 34.18% |
| Part load GT efficiency heat rate ratio | 1.19062 | 1.19062 | 1.19062 |
| Fuel Cost from GT Synch to ST Synch "F" | 1,564,884 | 4,333,524 | 6,620,662 |
| Cost of Diesel Consumed by GT I=(E+F) | 2,146,862 | 4,915,503 | 7,202,640 |

| Net Revenue: | | | |
|---|------------------|------------------|------------------|
| From GT Synchronization up to ST Synch | | | |
| Operation from GT Synch to ST Synch | 52 | 144 | 220 |
| Load from GT Synch to ST Synch (MW) | 25.04 | 25.04 | 25.04 |
| Baseload Unit efficiency (HHV) | 43.13% | 43.13% | 43.13% |
| Part load GT efficiency heat rate ratio | 1 | 1 | 1 |
| Revenue from GT Synch to ST Synch | 1,041,667 | 2,884,616 | 4,407,052 |
| Net Revenue | 1,105,195 | 2,030,886 | 2,795,588 |

Muhammad

Qun



SCHEDULE 2

Description of the Complex:

1. General

Korangi Combined Cycle Power Plant (KCCPP) is a 247.5 MW combined cycle power Plant situated at Korangi Creek area of Karachi, commissioned in 2008. Plant comprises of 04 Gas Turbine (General Electric, LM6000 PC Sprint), 02 HRSGs (IEG & METKA) and 02 Steam Turbine (General Electric, Thermodyn). Each Heat recovery steam generator (HRSG) is connected to the exhaust of two Gas Turbines. The primary fuel of the power plant is natural gas with RLNG as alternate fuel and HSD serving as alternate / backup fuel for Gas Turbines.

The Complex is situated at Ibrahim Hyderi Road, Korangi, Karachi.

1.1 Gross Dependable Capacity of the Complex

GAS FUEL

| | |
|---------------------------------|--------------|
| KCCPP (4 GTs + 2 STs) GDC | = 237.078 MW |
| AUXILIARY CONSUMPTION (COMPLEX) | = 16.250 MW |
| NET CAPACITY (COMPLEX) | = 220.828 MW |

HSD FUEL

| | |
|---------------------------------|--------------|
| KCCPP (4 GTs + 2 STs) GDC | = 228.704 MW |
| AUXILIARY CONSUMPTION (COMPLEX) | = 8.686 MW |
| NET CAPACITY (COMPLEX) | = 220.018 MW |

The figures are based on NEPRA determination

2. Plant Reference Site Conditions

Reference Conditions at the Plant Site are as follows:

1. Ambient Air Temperature = 30 deg. C
2. Total Barometric Pressure = p_r = 1013.25 mbar
3. Relative Humidity = 60%
4. Sea water temperature = 25 deg C



3. Plant Characteristics

| Description | Gas Fuel | HSD Fuel |
|---|----------------------------------|------------------|
| Gross Dependable Capacity at mean site conditions | 237.078 MW | 228.704 MW |
| Auxiliary Consumption | 16.250 MW | 8.686 MW |
| Net Plant capacity | 220.828 MW | 220.018 MW |
| Net Heat Rate (HHV) | 8178.259 Btu/kWh | 7911.771 Btu/kWh |
| Net Efficiency (HHV) | 41.722 % | 43.127 % |
| Generation voltage (GT/ST) | 11.5/11 kV | |
| Grid voltage | 220 kV | |
| Frequency | 50 Hz | |
| Power factor | Leading - 0.95 Lagging - 0.85 | |
| Complex Cold Start Up Time upto base load | 346 mints | |
| Complex Warm Startup upto base load | 243 mints | |
| Complex Hot Start Up upto base load | 140 mints | |

4. Performance Curves

The Power Producer shall provide all performance and correction factors/curves for the units/Complex including but not limited to the following:

- Output vs. Ambient Temperature
- Output vs. Barometric Pressure
- Output vs. Ambient Relative Humidity
- Output vs. CW temperature.

5. Civil Structure Safety Design Factor

A maximum earthquake design factor of 0.24g per Uniform Building Code (UBC) utilized for the design of the plant buildings and structures.

6. Description of the Complex

Complex comprises of 02 combined cycle blocks each having 02 gas turbines, 01 HRSG



and 01 steam turbine. The EPC Contractor for Phase I: 4 GTs + ST-2 was METKA S.A and for Phase II ST-1 EPC Contractor was IEG A.S. Plant can be operated both in combined cycle and simple cycle modes, Primary fuel for the Plant operation is natural gas, supplied by Sui Southern Gas Company Ltd (SSGC) through a dedicated 24-inch pipeline, while the HSD is used backup fuel. The plant is connected to the Offtaker's system through 220 kV GIS and 132 kV new KTPS Grid.

KCCPP has 220 kV Switchyard, 11kV, 6.6kV and 0.4kV system, Water treatment plant, demin water tank, fire water tank, High Speed Diesel Storage Tanks and decanting station, Wastewater treatment plant, Central Control Room building, Office buildings, security check post, Warehouse & workshop building, Emergency Diesel Generator (for Black Start) and Firefighting pump house.

The cooling water system is based on sea water which is supplied through intake tunnels and cooling water pits where dedicated pumps are used to supply water to steam turbine, condensers, chillers condensers, heat exchangers and return to sea through outlet channel. The secondary cooling system is used for cooling gas turbine/steam turbine/gas compressors and related auxiliaries.

Generator Data of gas turbine and steam turbine is tabulated below.

| | |
|--|---|
| Gas Turbine Generator: 64.5 MVA (at 15 degree C ambient temperature) | Steam Turbine Generator (ST-1): 35.75 MVA Steam Turbine Generator (ST-2): 33.125 MVA |
| Stator Current Gas Turbine: 3238 A | Stator Current Steam Turbine-1: 1876 A Stator Current Steam Turbine-2: 1739 A |
| Stator Voltage Gas Turbine: 11.5kV | Stator Voltage Steam Turbine: 11kV |

The Complex will be capable of operation within a voltage range of $\pm 10\%$ on the 220 kV voltage level.

The GT and ST Generators have brushless DC excitation (PMG) and are equipped with generator-transformer with on load tap changer. GT Generators are equipped with 115 MVA rated transformers, and ST-1 and ST-2 Generators are equipped with 40MVA and 35MVA rated transformers with OLTC and Transformer Type of Cooling is oil natural air forced (ONAF).

The Generation voltage of each Unit is at 11.5 kV (GTs) and 11.0 kV (STs) and is stepped up to 220 kV through unit step up transformers. Interconnection with the Offtaker system will be via 220 kV, indoor type GIS (Gas Insulated Switchgear) with double bus bar with single breaker scheme.

KCCPP has a central control room (CCR) to monitor and control the Complex. The power plant is controlled through a distributed control system (Honeywell) and Gas Turbine

Control System (GE Micronet Simplex). The control room operator is provided with color graphic display of the power plant equipment with sufficient detail to allow proper control and monitoring of plant fluctuations. The required control, alarm, and monitoring functions for all the necessary balance of plant equipment are also integrated into the DCS/Micronet.

7. Weather Station

KCCPP is equipped with an installed weather monitoring system which measures following weather readings on round the clock basis:

- Barometric Pressure
- Wind Speed
- Humidity
- Ambient Temperature

Sea water temperature: Reference Condenser inlet temperature (when plant is in operation). Reference from website when plant in standby.

8. Fuel Supply and Storage

The plant is designed to be operated on dual fuel; Gas and HSD. The primary fuel is natural gas with RLNG as alternate fuel and HSD as the alternate/back-up fuel.

The main function of Gas Receiving Station (GRS) is to provide gas at 46.5 bar to the Gas Turbines. The gas is supplied by Sui Southern Gas Company (SSGC). KCCPP Fuel Gas system consists of emergency shutdown (ESD) valve, Gas Receiving Station (GRS) with Cartridge Filters, Gas Metering Unit, and Gas Chromatograph.

The HSD fuel system includes the unloading system, storage system, supply system and waste recovery system. There are two storage tanks with a volume of 8000 m³ each. The daily tank with a volume of 1500 m³ ensures the fuel level for four Gas turbines for period of 24 hours.



SCHEDULE 3**INTERCONNECTION FACILITIES AND TRANSMISSION FACILITIES****1. Interconnection and Transmission Facilities**

- 1.1** The Interconnection between Power Producer and the Offtaker Grid System is stated below.
- a) One 220kV transmission line CCPP - KCR Circuit-1, from CCPP to KCR Grid Station.
 - b) One 220kV transmission line CCPP - KCR Circuit-2, from CCPP to KCR Grid Station.
 - c) One 220kV interconnection CCPP - New KTPS, from CCPP to New KTPS Grid station (Terminated at BTW PTR-1).
 - d) One 220kV interconnection CCPP - New KTPS, from CCPP to New KTPS Grid station (Terminated at BTW PTR-2).
- 1.2** The transmission lines terminate in the substation of Complex and connect at bushings/cable sealing to line terminal gantries provided by the Power Producer. The boundary of responsibility between the Power Producer and the Offtaker are at the top of the bushings clamping terminal or cable sealing of the gantries (the “**Interconnection Point**”).
- 1.3** The installed Metering System other than backup meters (including its equipment, CT / PT, remote terminal units, protection relays and electronic data recording system) which together with the transmission line referred to above within the Complex’s boundary shall comprise the “Offtaker Interconnection Facilities”. This equipment will remain the property of the Offtaker and shall be maintained thereafter by the Offtaker.
- 1.4** A carrier inter-tripping circuit for each 220kV transmission line and a Fiber Optic Cable (FOC) tripping circuit for each BTW Power Transformer, shall be provided between the line circuit breakers at the Complex owned by the Power Producer and the line circuit breakers at the adjacent 220kV and 132kV substations respectively.

2 Interconnection Works:

The Power Producer shall be responsible for maintaining all auxiliary and interconnecting equipment including Remote Terminal Unit (RTU) for SCADA, telemetry tele-protection and system of its side of the Interconnection Point, and except for the Metering System, the Power Producer shall own all such auxiliary and interconnection equipment.

The Power Producer will be responsible for the provision of an exclusive dedicated set of Current and Voltage transformers for the Main Metering system. In addition, the Main and Back-up Meter should have an accuracy of 0.2s.



3 Modification of Protective Devices

- 3.1** All protective devices are to be installed by the Power Producer at its own switch yard. After the Commercial Operations Date, the Offtaker may require the Power Producer to modify or expand the requirements for protective devices, subject to giving the Power Producer reasonable notice. Following approval by the Offtaker of the costs of such modification or expansion, the Power Producer shall perform such modification or expansion, and the Offtaker shall reimburse the Power Producer for the reasonable costs of such modification or expansion. Notwithstanding any provision of this Agreement to the contrary, the Power Producer shall not incur any liability to the Offtaker (including without limitation any damages or penalties for Forced Outage or Partial Forced Outage) while undertaking any modification or expansion of the protective devices at the Offtaker's request and at such time or times approved in advance by the Offtaker. Such work shall be completed within a reasonable time under the circumstances. The Offtaker shall be notified in advance of, and shall have the right to observe all work on the protective devices.
- 3.2** Together with an invoice for reimbursement, the Power Producer shall provide reasonable documentation of the expenses incurred in modifying or expanding the protective devices. Payments shall be due thirty (30) Days after delivery of the invoice by the Power Producer; provided, however, that in case of any Dispute, the provisions of Section 9.7 shall apply.
- 3.3** The Power Producer shall notify the Offtaker in advance of any changes to either the Complex and the Offtaker shall notify the Power Producer in advance of any changes to the Grid System or interconnection facilities; in each case affecting the proper co-ordination of protective devices between the two systems connected through the Offtaker Interconnection Facilities. The Power Producer shall not in the case of the Complex make any such change without the approval of the Offtaker. The Offtaker shall not in the case of the Grid System make any such changes, without the Power Producer's approval.



4. Design Data

Below are the design data for the major component installed at the complex.

4.1 Gas Turbines

| <u>Gas Turbines</u> | <u>GT-1</u> | <u>GT-2</u> | <u>GT-3</u> | <u>GT-4</u> |
|---|-------------------------|-------------------------|-------------------------|-------------------------|
| Unit Identification (Type/Model) | LM 6000 PC sprint | LM 6000 PC sprint | LM 6000 PC sprint | LM 6000 PC sprint |
| Manufacturer | General Electric USA | General Electric USA | General Electric USA | General Electric USA |
| GT rating at ISO conditions | 48375 kW | 48375 kW | 48375 kW | 48375 kW |
| GT rating at Reference Site conditions | 30°C | 30°C | 30°C | 30°C |
| GT rated Speed (rpm) | 3627 | 3627 | 3627 | 3627 |
| Air flow at GT inlet | 45,975 m³/hr | 45,975 m³/hr | 45,975 m³/hr | 45,975 m³/hr |
| GT inlet air temperature | 30°C | 30°C | 30°C | 30°C |
| Compression Ratio | 1:30 | 1:30 | 1:30 | 1:30 |
| Gas consumption/day | 10.675MMCFD | 10.675MMCFD | 10.675MMCFD | 10.675MMCFD |
| Gas pressure required | 46.5 bar | 46.5 bar | 46.5 bar | 46.5 bar |
| GT Exhaust gas flow | 47,798 m³/hr | 47,798 m³/hr | 47,798 m³/hr | 47,798 m³/hr |
| GT Exhaust gas temperature | 450-460°C | 450-460°C | 450-460°C | 450-460°C |

4.2 Heat Recovery Steam Generator (HRSG)

| <u>Heat Recovery Steam Generator (HRSG)</u> | <u>HRSG-1</u> | <u>HRSG2</u> |
|--|---|---|
| Type/Model | HRSG of vertical type, double pressure | HRSG of vertical type, double pressure |
| HP Steam pressure at HRSG outlet | 57 barg | 57 barg |
| HP steam temperature | 408 °C | 408 °C |
| HP Steam flow rate | 92.15 t/h | 91.3 t/h |
| LP Steam pressure at HRSG outlet | 7 barg | 7 barg |
| LP steam temperature | 242 °C | 242 °C |
| LP steam flow rate | 31.14 t/h | 30.6 t/h |



4.3 Steam Turbine and Condenser

| <u>Steam Turbine and Condenser</u> | <u>ST-1</u> | <u>ST-2</u> |
|---|--|--|
| Type/Model: | Impulse-type Multivalve Condensing GE Thermodyn 8-9MC9 | Impulse-type Multivalve Condensing GE Thermodyn 8-11 MC9 |
| Manufacturer: | GE, France | GE, France |
| ST Rating: | 27,500 kW | 26,500 kW |
| ST Rated Speed: | 4727 rpm | 4450 |
| Number of Casings / Stages: | 9 Stages | 9 Stages |
| Output at reference conditions: | N/A | N/A |
| Steam pressure at Steam turbine inlet (HP/LP): | 54 bara / 6 bara | 54 bara / 6 bara |
| Steam temperature at Steam turbine inlet (HP/LP): | 404.1 °C / 241.5 °C | 404.7 °C / 240 °C |
| Steam pressure at Steam turbine outlet: | 0.077 bara | 0.078 bara |
| Steam temperature at Steam turbine outlet: | 39 °C | 41 °C |
| Steam flow rate at ST inlet (HP/LP): | 91.7 / 27.96 t/hr | 91.61 / 28.63 t/hr |
| Circulating water flow rate at condenser: | 7813 m ³ /hr | 7873 m ³ /hr |
| Circulating water temperature at inlet of condenser: | 25 °C | 25 °C |
| Condenser vacuum: | 0.07 bara | 0.07 bara |
| Circulating water temperature rise in condenser at base load: | 8 °C | 8 °C |

4.4 Generators (GTG)

| <u>Generators</u> | <u>Gas Turbine GT1-4</u> |
|---|------------------------------|
| Name plate Rating (At 15°C Ambient temperature) | 64,500 kVA |
| Rated voltage at generator terminal | 11.5 kV |
| Number of Phases/poles | 3 Phase / 2 Pole |
| Frequency | 50Hz |
| Rated Speed | 3000rpm |
| Power Factor | 85% |
| Stator Thermal Class | F |
| Rotor Thermal Class | F |

| | |
|---|----------|
| Stator Winding Temperature Rise Limit | 109°C |
| Rotor Winding Temperature Rise Limit | 115°C |
| Type of cooling (Hydrogen/Air/Water Pressure PSIG) | Air |
| Continuous operating voltage limits per unit for continuous operation at rated kVA and power factor | +/- 5% |
| Apparent power base in MVA (At 15°C Ambient temperature) | 64.5 MVA |
| Voltage base in kV | 11.5 kV |
| Direct axis synchronous reactance unsaturated | 294 % |
| Direct axis synchronous reactance saturated | 260 % |
| Direct axis transient reactance unsaturated | 29% |
| Direct axis transient reactance saturated | 27% |
| Direct axis sub-transient unsaturated | 22% |
| Direct axis sub-transient saturated | 18% |

4.5 Generators (STG)

| <u>Generators</u> | <u>Steam Turbine (GT1/2) ST1</u> | <u>Steam Turbine (GT3/4) ST2</u> |
|---|----------------------------------|----------------------------------|
| Nameplate Rating | 35,750 kVA | 33,125 kVA |
| Rated voltage at generator terminal | 11.0 kV | 11.0 kV |
| Number of Phases/poles | 3 Phase / 4 Pole | 3 Phase / 4 Pole |
| Frequency | 50hz | 50hz |
| Rated Speed | 1500rpm | 1500rpm |
| Power Factor | 80% | 80% |
| Stator Thermal Class | F | F |
| Rotor Thermal Class | F | F |
| Stator Winding Temperature Rise Limit | 125°C | 130°C |
| Rotor Winding Temperature Rise Limit | 130°C | 130°C |
| Type of cooling (Hydrogen/Air/Water Pressure PSIG) | Water | Water |
| Continuous operating voltage limits per unit for continuous operation at rated KVA and power factor | +/-5% | +/-5% |
| Apparent power base in MVA | 35.75 | 33.125 |
| Voltage base in kV | 11.0 | 11.0 |
| Direct axis synchronous reactance unsaturated | 2.243p.u. | 2.84p.u. |
| Direct axis synchronous reactance saturated | | 2.38p.u. |
| Direct axis transient reactance unsaturated | 0.276p.u. | 0.39p.u. |
| Direct axis transient reactance saturated | 0.227p.u. | 0.33p.u. |

Qus

ky

| <u>Generators</u> | <u>Steam Turbine (GT1/2) ST1</u> | <u>Steam Turbine (GT3/4) ST2</u> |
|---------------------------------------|----------------------------------|----------------------------------|
| Direct axis sub-transient unsaturated | 0.196p.u. | 0.25p.u. |
| Direct axis sub-transient saturated | 0.155p.u. | 0.23p.u. |

4.6 Excitation System GTG

| <u>Excitation System</u> | <u>Gas Turbine GT1-4</u> |
|--|---------------------------|
| Type/ model | Brushless (EX 2100) |
| Exciter model diagram | EX 2100 Regulator Control |
| Field current at rated load (Main Exciter) | 6.9A |
| Field voltage at rated load (Main Exciter) | 82.1 V |

4.7 Excitation System STG

| <u>Excitation System</u> | <u>Steam Turbine (GT1/2) ST1</u> | <u>Steam Turbine (GT3/4) ST2</u> |
|--|----------------------------------|----------------------------------|
| Type/ model | Brushless | Brushless |
| Exciter model diagram | GE, K13970 | Brush, DG185ZP-04 |
| Field current at rated load (Main Exciter) | 7.4A | 8.2A |
| Field voltage at rated load (Main Exciter) | 67V | 120V |

4.8 Generator Characteristic Curves

| | |
|--|--------------|
| Generator Capability Curves | Annexure 3.1 |
| Generator V Curves | Annexure 3.1 |
| Generator saturation Curves, full load and no-load | Annexure 3.1 |

4.9 Generator Main Transformer & Auxiliary Transformers

| <u>Generator Main Transformers</u> | <u>GT Transformer SUT-1 & SUT-2</u> | <u>ST2 Transformer (ST2) SUT-3</u> | <u>ST1 Transformer (ST1) SUT-4</u> |
|--|---|------------------------------------|------------------------------------|
| General | | | |
| Quantity | 2 | 1 | 1 |
| Type (Single phase/ 3-phase, Shell/core) | 3-Phase | 3-Phase | 3-Phase |

| <u>Generator Main Transformers</u> | <u>GT Transformer SUT-1 & SUT-2</u> | <u>ST2 Transformer (ST2) SUT-3</u> | <u>ST1 Transformer (ST1) SUT-4</u> |
|---|--|---|---|
| Applicable IEC Standards | IEC 60076 | IEC 60076 | IEC 60076 |
| <u>Design Data</u> | | | |
| Maximum Continuous Rating (MVA) | 57.5/57.5/115 | 35 | 40 |
| Rated Voltage (HV/LV) (kV) | 220/11.5/11.5 | 220/11 | 220/11 |
| Rated temperature rise (°C) | 60°C | 55°C | 55°C |
| Voltage between phases (kV) | 220 | 220 | 220 |
| Max./Min. operating voltage at rated power (kV) | 242/198 | 242/198 | 242/198 |
| Vector Group | YNd1d1 | YNd1 | YNd1 |
| Tap-changer (Off-load or On-load) | On-load | On-load | On-load |
| Winding Taps | 17 | 17 | 17 |
| Percentage Impedance Voltage on MV A base H-L, H-T, L-T | 12% | 12.5% | 13.5% |
| No-load loss at rated voltage and rated frequency (kW) | 65 | 27 | 18 |
| Copper loss at rated power and voltage at Principal tap for reference temperature of 75 °C (kW) | 350 | 150 | 158 |
| <u>Basic Insulation Level:</u> | | | |
| • Of HV winding (kV) | 850 | 850 | 950 |
| • Of neutral of HV winding (kV) | 325 | 325 | 480 |
| • Of LV winding (kV) | 75 | 95 | 75 |
| Type of cooling | ONAF | ONAF | ONAF |
| Percent Impedance | 12% | 12.5% | 13.5% |
| Max Tap | 12.09 | 12.7 | 14.52 |
| Rated Tap | 12.2 | 12.5 | 13.78 |
| Min Tap | 12.0 | 12.1 | 13.59 |
| Tapping voltages at plus and minus tappings | 220±8×1.25% | 220±8×1.25% | 220±8×1.25% |
| Diagram of tap changer connections | Yes | Yes | Yes |

4.10 **Generator Auxiliary Transformer**

| <u>Generator Auxiliary Transformers</u> | <u>Auxiliary Unit Transformer AUT-1 & AUT-2</u> | <u>Auxiliary Unit Transformer AUT-3 & AUT-4</u> |
|--|--|--|
| <u>General</u> | | |
| Quantity | 2 | 2 |
| Type (Single phase/ 3-phase, Shell/core) | 3-Phase | 3-Phase |

| <u>Generator Auxiliary Transformers</u> | <u>Auxiliary Unit Transformer AUT-1 & AUT-2</u> | <u>Auxiliary Unit Transformer AUT-3 & AUT-4</u> |
|---|--|--|
| Applicable IEC Standards | IEC60076, IEC60354 | IEC60076 |
| <u>Design Data</u> | | |
| Maximum Continuous Rating (MVA) | 18.5 | 5 |
| Rated Voltage (H.V./LV) (kV) | 11.5/6.6 | 11.5/6.6 |
| Rated temperature rise (°C) | 65°C | 65°C |
| Voltage between phases (kV) | 11.5 | 11.5 |
| Max./Min. operating voltage at rated power (kV) | 12.65/10.35 | 12.65/10.35 |
| Vector Group | Dyn11 | Dyn11 |
| Tap-changer (Off-load or On-load) | On-load | On-load |
| Winding Taps | 17 | 17 |
| Percentage Impedance Voltage on MV A base H-L, H-T, L-T | 11.40% | 7.28% |
| No-load loss at rated voltage and rated frequency (kW) | 11 | 4.32 |
| Copper loss at rated power and voltage at Principal tap for reference temperature of 75 °C (kW) | 106 | 35.9 |
| <u>Basic Insulation Level:</u> | | |
| • Of HV winding (kV) | 75 (Peak) | 85 (Peak) |
| • Of LV winding (kV) | 60 (Peak) | 60 (Peak) |
| • Of neutral of LV winding (kV) | 60 (Peak) | 60 (Peak) |
| Type of cooling | ONAF | ONAF |
| Percent Impedance | 11.40% | 7.28% |
| Max Tap | 12.0 | 7.61 |
| Rated Tap | 11.42 | 7.28 |
| Min Tap | 10.1 | 7.14 |
| Tapping voltages at plus and minus tapplings | 11.5±8×1.25% | 11.5±8×1.25% |
| Diagram of tap changer connections | Yes | Yes |

4.11 Current Transformer Data

| <u>Current Transformer Data</u> | <u>Units</u> | <u>D02</u> | <u>D03</u> | <u>D05</u> | <u>D07</u> |
|--|---------------------|-------------------|-------------------|-------------------|-------------------|
| Manufacturer | | SIEMENS | SIEMENS | SIEMENS | SIEMENS |
| Serial Number (Bay) | | K 31254031 | K 31254032 | K 31254034 | K 31266330 |
| Rated Voltage / Operational Voltage | kV | 245 | 245 | 245 | 245 |

| <u>Current Transformer Data</u> | <u>Units</u> | <u>D02</u> | <u>D03</u> | <u>D05</u> | <u>D07</u> |
|--|---------------------|-------------------|-------------------|-------------------|--------------------|
| <u>Rated normal primary current</u> | A | | | | |
| • Core (1) | | 750 | 750 | 750 | 200 |
| • Core (2) | | 750 | 750 | 750 | 150 |
| • Core (3) | | 750 | 750 | 750 | 150 |
| • Core (4) | | 3000 | 3000 | 3000 | 3000 |
| • Core (5) | | 3000 | 3000 | 3000 | 3000 |
| Rated secondary current | A | 1 | 1 | 1 | 1 |
| <u>Rated secondary output</u> | VA | | | | |
| • Core (1) | | 30 | 30 | 30 | 10 |
| • Core (2) | | 30 | 30 | 30 | 7.5 |
| • Core (3) | | 30 | 30 | 30 | 7.5 |
| • Core (4) | | 30 | 30 | 30 | 30 |
| • Core (5) | | 30 | 30 | 30 | 30 |
| <u>Accuracy class:</u> | | | | | |
| • Measuring core | - | 0.2fs | 0.2fs | 0.2fs | 0.2fs |
| • Protection core | | 5P20 | 5P20 | 5P20 | 5P20 |
| Rated transformation ratios | - | 750/1,3000/1 | 750/1,3000/1 | 750/1,3000/1 | 200/1,150/1,3000/1 |
| Accuracy limit factor for protective core | | 20 | 20 | 20 | 20 |
| <u>Short time current rating</u> | | | | | |
| • Thermal (I _{th}) | kA | 40 | 40 | 40 | 50 |
| • Dynamic (I _{dyn}) | kA _{peak} | 100 | 100 | 100 | 100 |
| Impulse withstand voltage | kV _{peak} | 1050 | 1050 | 1050 | 1050 |
| Power frequency withstand voltage | kV _{peak} | 460 | 460 | 460 | 460 |

4.12 Voltage Transformer Data

| <u>Voltage Transformer Data</u> | <u>Units</u> | <u>D04 Coupler</u> | <u>D07 ST1</u> |
|---|--------------------|------------------------|--------------------|
| Rated Voltage primary Voltage phase to neutral | kV | 127 | 127 |
| Rated normal secondary Voltage phase to neutral | V | 57.7 | 57.7 |
| <u>Rated secondary output</u> | | | |
| • Measuring core | VA | 100 | 100 |
| • Protection core | | 100 | 100 |
| <u>Accuracy class</u> | - | | |
| • Measuring core | - | 0.2 | 0.2 |
| • Protection core | - | 3P | 3P |
| Impulse withstand voltage for primary winding | kV _{peak} | 1050 | 1050 |
| Power frequency withstand voltage for primary winding | kV _{rms} | 460 | 460 |


4.13 Circuit Breakers

| <u>Circuit Breakers</u> | <u>Units</u> | <u>D02</u> | <u>D03</u> | <u>D05</u> | <u>D07</u> |
|---|--------------------|-----------------------|-----------------------|-----------------------|-----------------------|
| Manufacturer | | SIEMENS | SIEMENS | SIEMENS | SIEMENS |
| Circuit - Breaker Type - Operating years | | SF6 | SF6 | SF6 | SF6 |
| Rated Voltage | kV _{rms} | 245 | 245 | 245 | 245 |
| Rated Normal Current | kA | 2.5 | 2.5 | 2.5 | 2.5 |
| Short - Circuit Breaking Current | kA | 40 | 40 | 40 | 50 |
| <u>Rated lightning and switching impulse withstand voltage,</u> | kV _{peak} | | | | |
| • To earth | | 1050 | 1050 | 1050 | 1050 |
| • Across open breaker | | 1050 | 1050 | 1050 | 1050 |
| <u>Rated one minute power frequency test withstand Voltage</u> | KV _{rms} | | | | |
| • To earth | | 460 | 460 | 460 | 460 |
| • Across open breaker | | 460 | 460 | 460 | 460 |
| Operating Sequence | | 0-0.3s-C0- 3min-C0 | 0-0.3s-C0- 3min-C0 | 0-0.3s-C0- 3min-C0 | 0-0.3s-C0- 3min-C0 |

| <u>Circuit Breakers</u> | <u>Units</u> | <u>D02</u> | <u>D03</u> | <u>D05</u> | <u>D07</u> |
|--|---------------------|-------------------|-------------------|-------------------|-------------------|
| Rated normal current at 50 Hz And 50 deg.C not less than A_{rms} . Rated short – time withstand current | kA_{rms} | 2.5 | 2.5 | 2.5 | 2.5 |
| Rated peak withstand current | kA_{peak} | 135 | 135 | 135 | 135 |
| Rated duration of short circuit | Sec | 3 | 3 | 3 | 3 |
| Rated short circuit breaking Current at rated voltage and 50 Deg. C not less than kA_{rms} | kA_{peak} | ≤ 50 | ≤ 50 | ≤ 50 | ≤ 50 |
| Rated short-circuit making Current kA_{peak} | kA_{peak} | 135 | 135 | 135 | 135 |
| Rated out-of-phase breaking Current kA_{rms} | kA_{rms} | 10kA | 10kA | 10kA | 10kA |
| Rated line charging breaking Current A | A | - | - | - | - |

Annexure 3.1


GT Generator Capability Curves



Decy

Ry


GT Generator Saturation Curve



Copy

24


GT Generator Vee Curve



Exu

Ky


STG-1 Generator Capability Curve



Am

Hy


STG-1 Generator Vee Curve



Am

Am


STG-1 Generator Saturation Curve



(Signature)

(Signature)


STG-2 Generator Capability Curve



Handwritten signature

Handwritten signature


STG-2 Generator Saturation Curve



Handwritten signature

Handwritten signature

STG-2 Vee Curve



Handwritten signature

Handwritten signature

SCHEDULE - 5

KCCPP TECHNICAL LIMITS:

5.1 KCCPP Technical Limits

| Gas Fuel | MMSCFD / Day Approx Min per GT ³ | MMSCFD / Day Approx Max per GT ³ | Min Gross Load (MW) ² | Installed Capacity (MW) | Leading PF | Lagging PF | Hot start ¹ | Warm start ¹ | Cold Start ¹ |
|----------|---|--|---|-------------------------------|---------------|---------------|---------------------------|----------------------------|----------------------------|
| Complex | 7 | 11 | 31 | 247.5 | 0.95 | 0.85 | 140 | 243 | 346 |

1. Time in minutes required from Offtaker demand to Base Load.
2. Against GT's 25MW, ST output is approximately 8MW in winters, and approximately 6MW in summer.
3. Fuel is approximated for reference only.
4. Above timings are maximum and units can be synchronized earlier with the permission of the Offtaker.

| HSD Fuel | Liters/Hr Approx Min per GT ³ | Liters/Hr Approx Max per GT ³ | Min Gross Load (MW) ² | Installed Capacity (MW) | Leading PF | Lagging PF | Hot start ¹ | Warm start ¹ | Cold Start ¹ |
|----------|---|--|---|-------------------------------|---------------|---------------|---------------------------|----------------------------|----------------------------|
| Complex | 8000 | 12000 | 31 | 247.5 | 0.95 | 0.85 | 140 | 243 | 346 |

1. Time in minutes required from Offtaker demand to Base Load.
2. Against GT's 25MW, ST output is approximately 8MW in winters, and approximately 6MW in summer.
3. Fuel is approximated for reference only.
4. Above timings are maximum and units can be synchronized earlier with the permission of the Offtaker.

5.2 Over Frequency / Under Frequency:

| Unit | Under Frequency (Hz) | Time delay (sec) | Over Frequency (Hz) | Time delay (sec) ² |
|-------|-------------------------|---------------------|------------------------|----------------------------------|
| GTG-1 | 48.0 | 60ms (Alarm) | 51.50 | 60ms (Alarm) |
| GTG-2 | 48.0 | 60ms (Alarm) | 51.50 | 60ms (Alarm) |
| GTG-3 | 48.0 | 60ms (Alarm) | 51.50 | 60ms (Alarm) |
| GTG-4 | 48.0 | 60ms (Alarm) | 51.50 | 60ms (Alarm) |
| STG-1 | 48.5/47 | 5000 ms / 500 ms | 51.5/53 | 10000 ms / 1000 ms |
| STG-2 | 48 | 5000 ms | 52 | 5000 ms |

5.3 Island Mode Operation:

Plant is capable of islanding in case of disturbance in the network, the range of the voltage and frequencies are as under.

| | PROTECTION | D02 (GT1/2) | | D03 (GT3/4) | |
|---|--------------------------|-------------|------|-------------|------|
| 1 | Over Frequency (Step-1) | 51.5Hz | 0.2s | 51.5Hz | 0.2s |
| 2 | Under Frequency (Step-1) | 48.3Hz | 0.4s | 48.3Hz | 0.4s |
| 3 | Under Frequency (Step-2) | 47.8Hz | 0.2s | 47.8Hz | 0.2s |
| 4 | Under Voltage | 171.6kV | 1.3s | 171.6kV | 1.3s |

5.4 Unit Operating Limits:

| Description | Unit | Limits |
|---------------------------------|------|-------------|
| GT Min Gross Load (SC) Gas | MW | 25 |
| GT Min Gross Load (SC) HSD | MW | 25 |
| ST Min Gross Load | MW | 06* |
| Complex min Gross Load (OC) Gas | MW | 25 |
| Complex min Gross Load (CC) Gas | MW | 31* |
| Complex min Gross Load (OC) HSD | MW | 25 |
| Complex min Gross Load (CC) HSD | MW | 31* |
| System Voltage | kV | 220 |
| Operating Frequency Range | Hz | 48.5 - 51.0 |

*This is based on summer capacity of ST, in winters these figures shall be increased by 2 MWs approximately.

5.5 Plant Start-up Duration:

| Plant Start-up Time in (Minutes) | | | |
|---|-----------------|-----------------------|---------------|
| | Cold (>12 h) | Warm (<12 h, >1 h) | Hot (<1 h) |
| Startup of 2 Gas Turbines (from receipt of dispatch instruction till Synchronization) | 63 | 63 | 63 |
| HRSR (Pressurization) + remaining 2 Gas Turbines startup | 175 | 113 | 35 |
| Steam Turbines (Rolling: From Start Command to FSNL) | 40 | 26 | 12 |
| Steam Turbines Synchronization | 05 | 05 | 05 |
| Steam Turbines (Loading: From Synchronization to full load) | 63 | 36 | 25 |
| Total Time | 346 | 243 | 140 |

5.6 Load Gradient:

| Ramp Rate | Hot Start MW/Min | Warm Start MW/Min | Cold Start MW/Min |
|-----------|---------------------|----------------------|----------------------|
| GT | 5 | 5 | 5 |
| ST | 1 | 0.7 | 0.4 |

5.7 Number of Yearly Startups:

Startup of the Gas Turbine shall be subject to the following limits.

| Type of Startup | Maximum Number of Starts for the term of this agreement (16 years)* | | Maximum Number of Starts for each Agreement year* | |
|-----------------|---|---------------|---|--------------|
| | GT | ST** | GT | ST** |
| HOT | 2400 (per GT) | 1600 (Per ST) | 150 (Per GT) | 100 (Per ST) |
| WARM | | 800 (Per ST) | | 50 (Per ST) |
| COLD | | | | |

*The number of startups for each type is interchangeable considering the maximum yearly/term limits with mutual consent of Offtaker and Power Producer.

**The numbers are as per prudent engineering practices.

5.8 Plant Outage Intervals & Duration:

| Station | Maintenance | Outage Days |
|---------|--|-------------|
| KCCPP | Gas Turbine (GT) 25K Maintenance (Hot section exchange, HSE) | 9 |
| KCCPP | GT 50K Maintenance (Major Overhaul) | 6* |
| KCCPP | GT Reduction Gear Box (RGB) 32K Maintenance (Major Overhaul) | 8 |
| KCCPP | Gas Turbine Generator (GTG) 25K Maintenance (Minor Overhaul) | 3 |
| KCCPP | GTG 64K Maintenance (Major Overhaul) | 20 |
| KCCPP | Steam Turbine (ST) 25K Maintenance (Minor Overhaul) | 15 |
| KCCPP | ST 50K Maintenance (Major Overhaul) | 30 |
| KCCPP | ST RGB 32K Maintenance (Major Overhaul) | 8 |



| Station | Maintenance | Outage Days |
|---------|---|-------------|
| KCCPP | Steam Turbine Generator (STG) 32K Maintenance (Minor Overhaul) | 4 |
| KCCPP | STG 96K Maintenance (Major Overhaul) | 25 |
| KCCPP | GT annual Maintenance Condition based | 7.5 |
| KCCPP | Balance of Plant (BOP) Maintenance System Cooling Water Pits Repair & cooling Pumps Maintenances | 17 |
| KCCPP | Complex Outage for Sea Water Cooling Water Pits Maintenance, Dredging of sea water intake channel. Dredging Operation | 30 |

* GT 50K Maintenance time is for engine swapping.

Overhaul includes hot section exchange, Major overhaul/inspection.

Maintenance cycle shall include:

- One Major Overhaul for each GT at every 50K fired hours
- One Hot Section Exchange (HSE) for each GT at every 25K factored fired hours (One fired hour on HSD is equivalent to two fired hours on gas)
- One Minor overhaul for ST at every 25K hours
- One Major overhaul for ST at every 50K hours

Overhaul cycle shall be completed when

- Major inspections/overhaul of all GTs are completed at every 50K fired hours; and
- Major overhaul of ST is completed at every 50K hours.

5.9 Fuel Pressure Requirement:

- Inlet pressure of Gas Compressor=4.2 bar for rated flow (26335 Nm³/h).
- Decrease in inlet pressure will reduce the flow of the gas compressor.
- Minimum pressure =2.2 bar which will reduce the flow rating of gas compressor by 60% (15800 Nm³/h).


5.10 Steam Turbine Start-up Mode / Time:

| Start-up category | Recommended start-up mode | Note-1 Start Up Time As per Curve (Min) From Turbine Rolling to Synchronization |
|-----------------------------|---------------------------|---|
| Ambient start and > 12h | (Cold) | 45 |
| Shutdown time >1h and < 12h | Warm | 29 |
| Shutdown time <1h | (Hot) | 17 |


Note-1: HRSG pressurization time is separately mentioned in Section 5.5 of this Schedule.

5.11 Generator Capability Curve:

5.11.1 GT capability curve




5.11.2 ST-1 capability curve



Handwritten signature/initials

Handwritten signature/initials

5.11.3 ST-2 capability curve



Handwritten signature

Handwritten signature

SCHEDULE - 6

METERING STANDARDS AND TESTING

1. Provision of Tariff Metering

- 1.1** The metering points to record the MWh and MVARh exchange between the Complex and the Offtaker's grid system shall be on the high voltage side of the generating unit transformer as shown in an appropriate diagram to be provided by the Power Producer. The Metering System has been installed by the Power Producer. Exclusive dedicated set of current and voltage transformers is provided by the Power Producer to feed the current and voltage to the Metering System of the Complex. The meters owned by the Offtaker will be located within the GIS Relay building in a separate identified area housing all marshalling cubicles, control and metering panels and communication equipment. Photographic facilities will be provided by the Power Producer as part of the verification process for monthly meter readings.
- 1.2** The Metering System and the Back-up Meter system shall be in accordance with a mutually agreed international standard, having an accuracy class of 0.2s.

2. Testing

- 2.1** The calibration of the Metering System and the Back-up Meter system will be checked to ensure that the accuracy remains within the specified limits. The method of calibration and frequency of tests will be agreed between the Power Producer and the Offtaker based on knowledge of the performance and the design of the installed meters and the manufacturers' recommendations.
- 2.2** Testing and calibration of the Metering System shall be carried out by the Offtaker after giving appropriate notice to the Power Producer in line with the agreed frequency of testing or in the event of either party having reasonable cause to believe the meters are outside specified limits. During such tests and calibration, the Power Producer shall have the right to have a representative present at all times.
- 2.3** Testing and calibration of the Back-up Meter system shall be carried out by the Power Producer after giving appropriate notice to the Power Producer in line with the agreed frequency of testing or in the event of either party having reasonable cause to believe the meters are outside specified limits. During such tests and calibration, the Offtaker shall have the right to have a representative present at all times.

3.0 CT and PT Error Compensation

- 3.1** Compensation will be made for the errors of current and voltage transformers in the meter calibration or during the computation of records. Current and voltage transformers will be tested for ratio and phase angle errors following manufacture at an accredited testing station in the presence of representatives from the Power Producer and the Offtaker. Test certificates issued by the testing station will be issued independently to both parties.



SCHEDULE 8

INSURANCE

OPERATING PERIOD

Sum Insured, Deductible and Indemnity Period for All Risk, BI following All Risk including Machinery Breakdown

8.1 All Risks Insurance Including Machinery Break Down - Fixed Assets:

Cover: All Risk of Direct Physical Loss or Damage Including Machinery Break Down. All property of any nature and description which is the subject matter of the Plant or used for or in connection with the operation and maintenance of the Plant which is the property of the Insured and/ or property under the care/ custody/ control of the Insured for which the Insured is responsible.

Sum insured: Full replacement value of the Complex.

Property All Risk = PKR 84,819,159,624

Deductible:

5% of loss amount minimum PKR 140,000,000 (equivalent to USD 500,000) each occurrence for earth quake and all ensuing damages

PKR 140,000,000 (equivalent to USD 500,000) for Machinery Breakdown with respect to Gas and Steam Turbine & associated Generator and gearboxes

PKR 98,000,000 (equivalent to USD 350,000) each occurrence for all other losses including Act of God I-e Rain, Flood, Storm, Typhoon.

Insured: Principal Insured: K-Electric Limited

Additional Insured:

Financiers
Security Trustee
Lenders
Each for their respective rights and interest.

8.2 Consequential Loss (Business Interruption (BI)) Following All Risk Including Machinery Break Down:

Cover: Loss of revenue and in addition increased costs following loss or damage which is indemnifiable or would be indemnifiable but for the application of the deductible under Section of Property Damage – All Risk Including Machinery Break down .



Sum insured: PKR 15,577,320,590/- (An amount equal to the estimated capacity payments & Take and Pay during the indemnity period.

Indemnity Period: 18 months

Deductibles:

Time Excess: 60 Days each occurrence in respect of Machinery Breakdown of Gas Turbines & Generator Sets, Steam Turbine Generator Sets & Natural Catastrophe Perils.

45 days each occurrence in respect of all other losses.

Deductible based on Average Daily Value of Loss.

Insured: Principal Insured: K-Electric Limited

Additional Insured:

Financiers

Security Trustee

Lenders

Each for their respective rights and interest

Note: Total Limit of Liability (All Risk Including Machinery Break down and Business Interruption):
PKR 100,396,480,215.

8.3 Terrorism

Cover: All real and personal property of every kind

| | | | |
|---------------------|-----------------------|---|---------------------|
| Sum insured: | Property Damaged | = | PKR 84,819,159,624 |
| | Business Interruption | = | PKR 15,577,320,590 |
| | Total | = | PKR 100,396,480,215 |

Deductible:

PKR 7,000,000/-any one occurrence in respect of Property Damage,
30 days any one occurrence in respect of Business Interruption.

Limit of Liability:

PKR 35,000,000,000 any one occurrence and in the annual Aggregate in respect of Property Damage and Business Interruption only. This limit is for all generating plants of the Company, however, full amount can be claimed at the KCCP Annually.



Insured: Principal Insured: K-Electric Limited

Additional Insured:

Financiers
Security Trustee
Lenders
Each for their respective rights and interest

8.4 Public Liability Insurance

Cover: Bodily Injury including death and Property Damage to third party due to Power Generation, Transmission and Distribution of K Electric

Limit of Liability:

Bodily Injury including death and Property Damage to third party PKR 50,000,000 per occurrence and PKR 300,000,000 in Annual Aggregate. This limit is for all assets of the Company, however, full amount can be claimed at the KCCP annually.

Deductible:

PKR 500,000/- for bodily injury including death.
PKR 1,000,000 for property per accident for each and every loss.

Insured: Principal Insured: K-Electric Limited



SCHEDULE - 10
KCCPP CORRECTION CURVES

Table of Contents

| | | |
|---------------|---|----------|
| 10.1 | Correction Curves | 2 |
| 10.1.1 | Gas Fuel Correction Curves (Combine Cycle Base Load)..... | 2 |
| 10.1.1.1 | Correction in Power Output and Heat Rate due to Variation in Ambient Temperature..... | 2 |
| 10.1.1.2 | Correction in Power Output and Heat Rate due to Variation in Ambient Pressure | 3 |
| 10.1.1.3 | Correction in Power Output and Heat Rate due to Variation in Relative Humidity | 4 |
| 10.1.1.4 | Correction in Power Output due to Variation in Cooling Water Temperature..... | 4 |
| 10.1.2 | HSD Fuel Correction Curves (Combine Cycle Base Load)..... | 5 |
| 10.1.2.1 | Correction in Power Output and Heat Rate due to Variation in Ambient Temperature..... | 5 |
| 10.1.2.2 | Correction in Power Output and Heat Rate due to Variation in Ambient Pressure | 6 |
| 10.1.2.3 | Correction in Power Output and Heat Rate due to Variation in Relative Humidity | 7 |
| 10.1.2.4 | Correction in Power Output due to Variation in Cooling Water Temperature..... | 8 |
| 10.1.3 | Gas Fuel Correction Curves (Simple Cycle Base Load) | 9 |
| 10.1.3.1 | Correction in Power Output and Heat Rate due to Variation in Ambient Temperature..... | 9 |
| 10.1.3.2 | Correction in Power Output and Heat Rate due to Variation in Ambient Pressure | 10 |
| 10.1.3.3 | Correction in Power Output and Heat Rate due to Variation in Relative Humidity | 11 |



10.1 Correction Curves

10.1.1 Gas Fuel Correction Curves (Combine Cycle Base Load)

10.1.1.1 Correction in Power Output and Heat Rate due to Variation in Ambient Temperature

| | | | | |
|---|--|-----------------|-----------------|---|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's base load @ 100% GTGe load Document Name Ambient air temperature correction factors for complete CCPP | Project Ref. N° | IEWEA/12018 | IEI ISTROENERGO INTERNATIONAL, s.a. |
| | | File Name | L_01_a_20180905 | |
| | | Revision date | Sept. 5th, 2018 | |

Table I.1.a: Ambient air temperature correction factors

| Calculation point No. | Ambient temperature T [°C] | Plant power | | Plant heat rate | | Power correction | | Heat rate correction | |
|-----------------------|----------------------------------|---------------------------------|-------------------------------|----------------------|--------------------|----------------------------|--------------------------|-----------------------|---------------------|
| | | GROSS | NET | GROSS | NET | GROSS | NET | GROSS | NET |
| | | PWR_gross [kW _e] | PWR_net [kW _e] | HR_gross [kJ/kWh] | HR_net [kJ/kWh] | α_{1_gross} [-] | α_{1_net} [-] | f_{1_gross} [-] | f_{1_net} [-] |
| 1 | 5.0 | 253 089 | 238 043 | 6 961.8 | 7 401.9 | 0.977093 | 0.960514 | 1.000429 | 1.017697 |
| 2 | 10.0 | 253 281 | 238 231 | 6 980.7 | 7 421.7 | 0.976353 | 0.959755 | 0.997718 | 1.014972 |
| 3 | 15.0 | 250 845 | 234 633 | 6 974.4 | 7 456.3 | 0.985833 | 0.974474 | 0.998629 | 1.010270 |
| 4 | 20.0 | 250 610 | 233 796 | 6 967.6 | 7 468.7 | 0.986758 | 0.977961 | 0.999599 | 1.008590 |
| 5 | 25.0 | 250 563 | 232 721 | 6 966.6 | 7 500.7 | 0.986945 | 0.982480 | 0.999746 | 1.004289 |
| 6 | 30.0 | 247 292 | 228 644 | 6 964.8 | 7 532.9 | 1.000000 | 1.000000 | 1.000000 | 1.000000 |
| 7 | 35.0 | 237 673 | 219 071 | 6 959.7 | 7 550.7 | 1.040470 | 1.043694 | 1.000727 | 0.997636 |
| 8 | 40.0 | 228 127 | 209 588 | 6 955.8 | 7 571.1 | 1.084008 | 1.090921 | 1.001292 | 0.994947 |
| 9 | 45.0 | 217 675 | 199 202 | 6 962.6 | 7 608.2 | 1.136060 | 1.147797 | 1.000322 | 0.990093 |

| $\alpha_1 = a_5 \cdot T^5 + a_4 \cdot T^4 + a_3 \cdot T^3 + a_2 \cdot T^2 + a_1 \cdot T + a_0$ | | |
|--|-----------------------|-----------------------|
| | α_{1_gross} | α_{1_net} |
| a_5 | -2.16007906095400E-08 | -2.24060113642000E-08 |
| a_4 | 2.54768318464029E-06 | 2.67888820138547E-06 |
| a_3 | -1.04336446208434E-04 | -1.12258993103667E-04 |
| a_2 | 1.87652925614206E-03 | 2.09632123149331E-03 |
| a_1 | -1.39826518914502E-02 | -1.59726208542090E-02 |
| a_0 | 1.01119197580037E+00 | 9.99844904210947E-01 |

| $f_1 = a_5 \cdot T^5 + a_4 \cdot T^4 + a_3 \cdot T^3 + a_2 \cdot T^2 + a_1 \cdot T + a_0$ | | |
|---|-----------------------|-----------------------|
| | f_{1_gross} | f_{1_net} |
| a_5 | 0.00000000000000E+00 | -1.84514971553000E-09 |
| a_4 | 0.00000000000000E+00 | 2.15864092911300E-07 |
| a_3 | 0.00000000000000E+00 | -9.13787043897594E-06 |
| a_2 | 1.34775237871712E-06 | 1.69899697685455E-04 |
| a_1 | -1.77564871749505E-05 | -2.01270982199658E-03 |
| a_0 | 9.99206144966699E-01 | 1.02465315348668E+00 |



Qau

R

10.1.1.2 Correction in Power Output and Heat Rate due to Variation in Ambient Pressure


| | | | | |
|---|---|-----------------|-----------------|--|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's base load @ 100% GTGe load Document Name Ambient air pressure correction factors for complete CCPP | Project Ref. No | IEVKE/01/2018 |  ISTROENERGO INTERNATIONAL, s.a. |
| | | File Name | I_02_a_20180905 | |
| | | Revision date | Sept. 5th, 2018 | |

Table I.2.a: Ambient air pressure correction factors

| Calculation point No. | Ambient pressure p [bar(a)] | Plant power | | Plant heat rate | | Power correction | | Heat rate correction | |
|-----------------------|-----------------------------------|---------------------------------|-------------------------------|----------------------|--------------------|------------------------------|----------------------------|------------------------------|----------------------------|
| | | GROSS | NET | GROSS | NET | GROSS | NET | GROSS | NET |
| | | PWR_gross [kW _e] | PWR_net [kW _e] | HR_gross [kJ/kWh] | HR_net [kJ/kWh] | α ₂ _gross [-] | α ₂ _net [-] | f ₂ _gross [-] | f ₂ _net [-] |
| 1 | 1.001300 | 244 386 | 225 757 | 6 963.8 | 7 538.4 | 1.011891 | 1.012790 | 1.000146 | 0.999258 |
| 2 | 1.003690 | 244 978 | 226 341 | 6 963.8 | 7 537.3 | 1.009444 | 1.010175 | 1.000139 | 0.999415 |
| 3 | 1.006080 | 245 612 | 226 968 | 6 964.1 | 7 536.1 | 1.006840 | 1.007384 | 1.000103 | 0.999563 |
| 4 | 1.008460 | 246 197 | 227 545 | 6 964.4 | 7 535.2 | 1.004446 | 1.004828 | 1.000060 | 0.999680 |
| 5 | 1.010860 | 246 819 | 228 161 | 6 963.7 | 7 533.2 | 1.001916 | 1.002118 | 1.000152 | 0.999951 |
| 6 | 1.013250 | 247 292 | 228 644 | 6 964.8 | 7 532.8 | 1.000000 | 1.000000 | 1.000000 | 1.000000 |
| 7 | 1.015670 | 247 852 | 229 197 | 6 965.1 | 7 532.0 | 0.997743 | 0.997586 | 0.999956 | 1.000114 |
| 8 | 1.018070 | 248 440 | 229 778 | 6 965.1 | 7 530.8 | 0.995379 | 0.995065 | 0.999957 | 1.000272 |
| 9 | 1.020490 | 248 992 | 230 324 | 6 966.0 | 7 530.7 | 0.993173 | 0.992708 | 0.999822 | 1.000291 |
| 10 | 1.022910 | 249 567 | 230 893 | 6 966.5 | 7 530.0 | 0.990883 | 0.990260 | 0.999750 | 1.000378 |
| 11 | 1.025330 | 250 119 | 231 437 | 6 969.3 | 7 531.9 | 0.988697 | 0.987933 | 0.999351 | 1.000125 |

| α ₂ = a ₁ *p + a ₀ | | |
|---|-----------------------|-----------------------|
| | α ₂ _gross | α ₂ _net |
| a ₁ | -9.59202769707057E-01 | -1.02923101915655E+00 |
| a ₀ | 1.97198103736369E+00 | 2.04297903770114E+00 |

| f ₂ = a ₃ *p ³ + a ₂ *p ² + a ₁ *p + a ₀ | | |
|---|-----------------------|-----------------------|
| | f ₂ _gross | f ₂ _net |
| a ₃ | -1.41642081923782E+02 | -1.62488237574696E+02 |
| a ₂ | 4.28728684553746E+02 | 4.91780463845896E+02 |
| a ₁ | -4.32568172868321E+02 | -4.96063751380016E+02 |
| a ₀ | 1.46481778958078E+02 | 1.67770751657543E+02 |



[Handwritten signature]

[Handwritten signature]

10.1.1.3 Correction in Power Output and Heat Rate due to Variation in Relative Humidity

| | | | | |
|---|---|-----------------|-----------------|---|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Document Name Correction curves for Plant's base load @ 100% GTGs load Ambient air RH correction factors for complete CCPP | Project Ref. N° | IEWKE/01/2018 | IEI ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | I_03_a_20180905 | |
| | | Revision date | Sept. 5th, 2018 | |

Table I.3.a: Ambient air RH correction factors

| Calculation point No. | Ambient air RH | Plant power | | Plant heat rate | | Power correction | | Heat rate correction | |
|-----------------------|----------------|-----------------|---------------|-------------------|-----------------|-------------------------|-----------------------|----------------------|------------------|
| | RH | GROSS | NET | GROSS | NET | GROSS | NET | GROSS | NET |
| | [%] | PWR_gross [kWe] | PWR_net [kWe] | HR_gross [kJ/kWh] | HR_net [kJ/kWh] | α_{p_gross} [-] | α_{p_net} [-] | f_{h_gross} [-] | f_{h_net} [-] |
| | | | | | | | | | |
| 1 | 30.0 | 250 651 | 233 195 | 6 968.9 | 7 490.6 | 0.986597 | 0.980485 | 0.999404 | 1.005635 |
| 2 | 40.0 | 250 566 | 232 534 | 6 966.5 | 7 506.7 | 0.986935 | 0.983270 | 0.999756 | 1.003482 |
| 3 | 50.0 | 250 566 | 231 901 | 6 966.5 | 7 527.2 | 0.986935 | 0.985954 | 0.999756 | 1.000750 |
| 4 | 60.0 | 247 292 | 228 644 | 6 964.8 | 7 532.8 | 1.000000 | 1.000000 | 1.000000 | 1.000000 |
| 5 | 70.0 | 243 512 | 224 886 | 6 962.5 | 7 539.1 | 1.015523 | 1.016709 | 1.000332 | 0.999165 |
| 6 | 80.0 | 239 874 | 221 267 | 6 960.7 | 7 546.1 | 1.030823 | 1.033338 | 1.000585 | 0.998246 |
| 7 | 90.0 | 236 630 | 218 027 | 6 959.1 | 7 552.9 | 1.045058 | 1.048697 | 1.000818 | 0.997346 |
| 8 | 98.0 | 234 056 | 215 476 | 6 957.2 | 7 557.1 | 1.058551 | 1.061112 | 1.001093 | 0.996790 |

| $\alpha_p = a_5 \cdot RH^5 + a_4 \cdot RH^4 + a_3 \cdot RH^3 + a_2 \cdot RH^2 + a_1 \cdot RH + a_0$ | | |
|---|-----------------------|-----------------------|
| | α_{p_gross} | α_{p_net} |
| a_5 | 5.38415633720000E-10 | 4.79597496180000E-10 |
| a_4 | -1.74552470369880E-07 | -1.55846876102120E-07 |
| a_3 | 2.14704092044691E-05 | 1.92124707158842E-05 |
| a_2 | -1.22706388037384E-03 | -1.10015569605941E-03 |
| a_1 | 3.27540470519819E-02 | 2.96701788928034E-02 |
| a_0 | 6.57056627360132E-01 | 6.76461679403321E-01 |

| $f_h = a_3 \cdot RH^3 + a_2 \cdot RH^2 + a_1 \cdot RH + a_0$ | | |
|--|----------------------|-----------------------|
| | f_{h_gross} | f_{h_net} |
| a_3 | 4.15538962610000E-10 | -3.27223342222400E-08 |
| a_2 | 2.77532956234600E-08 | 7.77076578679014E-06 |
| a_1 | 1.50330578355953E-05 | -6.87219235012336E-04 |
| a_0 | 9.98960574290789E-01 | 1.02024358035953E+00 |



Page 1 of 3

10.1.1.4 Correction in Power Output due to Variation in Cooling Water Temperature

| | | | | |
|---|--|-----------------|-----------------|---|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Document Name Correction curves for Plant's base load @ 100% GTGs load Condenser cooling water temperature correction factors for complete CCPP | Project Ref. N° | IEWKE/01/2018 | IEI ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | I_09_a_20180905 | |
| | | Revision date | Sept. 5th, 2018 | |

Table I.9.a.: Condenser cooling water temperature additive correction factor

| Calculation point No. | Condenser cooling temperature | Plant power | | Power correction | |
|-----------------------|-------------------------------|-----------------|---------------|----------------------------|--------------------------|
| | CT | GROSS | NET | GROSS | NET |
| | [°C] | PWR_gross [kWe] | PWR_net [kWe] | Δ_{sb_gross} [kWe] | Δ_{sb_net} [kWe] |
| | | | | | |
| 1 | 20.0 | 247 369 | 228 713 | -73 | -66 |
| 2 | 22.5 | 247 420 | 228 766 | -124 | -119 |
| 3 | 25.0 | 247 295 | 228 647 | 0 | 0 |
| 4 | 27.5 | 246 941 | 228 300 | 354 | 347 |
| 5 | 30.0 | 246 386 | 227 752 | 909 | 895 |
| 6 | 32.5 | 245 705 | 227 079 | 1 590 | 1 568 |
| 7 | 35.0 | 244 950 | 226 331 | 2 346 | 2 316 |
| 8 | 37.5 | 244 147 | 225 535 | 3 148 | 3 112 |

| $\Delta_{sb} = a_3 \cdot CT^3 + a_2 \cdot CT^2 + a_1 \cdot CT + a_0$ | | |
|--|-----------------------|-----------------------|
| | Δ_{sb_gross} | Δ_{sb_net} |
| a_3 | -4.19220277359670E-01 | -4.13101708302577E-01 |
| a_2 | 4.82354700435764E+01 | 4.76508678242492E+01 |
| a_1 | -1.51859956017598E+03 | -1.50314178097538E+03 |
| a_0 | 1.43718940920456E+04 | 1.42551958298015E+04 |



Handwritten signature

Handwritten signature

10.1.2 HSD Fuel Correction Curves (Combine Cycle Base Load)

10.1.2.1 Correction in Power Output and Heat Rate due to Variation in Ambient Temperature

| | | | | |
|---|---|------------------|-------------------|---|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's base load @ 100% GT/Gs load - Liquid fuel operation - Ambient air temperature correction factors for complete CCPP | Project Ref. No. | IEWKED12021 | IEI ISTROENERGO INTERNATIONAL, s.s. |
| | | File Name | L_I_01_a_20210304 | |
| | | Revision date | March, 4th, 2021 | |

Table L.I.1.a: Ambient air temperature correction factors

| Calculation point No. | Ambient temperature T [°C] | Power correction | | Heat rate correction | |
|-----------------------|----------------------------------|---------------------|-------------------|----------------------|--------------|
| | | GROSS | NET | GROSS | NET |
| | | α_{1_gross} | α_{1_net} | f_{1_gross} | f_{1_net} |
| 1 | 5.0 | 0.976779 | 0.980671 | 1.002793 | 1.019607 |
| 2 | 10.0 | 0.975655 | 0.959545 | 0.999718 | 1.016502 |
| 3 | 15.0 | 0.986294 | 0.975197 | 0.999794 | 1.011171 |
| 4 | 20.0 | 0.986397 | 0.977856 | 1.000541 | 1.009280 |
| 5 | 25.0 | 0.990181 | 0.985998 | 0.996717 | 1.000946 |
| 6 | 30.0 | 1.000000 | 1.000000 | 1.000000 | 1.000000 |
| 7 | 35.0 | 1.041672 | 1.043506 | 1.000695 | 0.998936 |
| 8 | 40.0 | 1.085008 | 1.088918 | 1.001358 | 0.997763 |
| 9 | 45.0 | 1.138126 | 1.144846 | 1.000543 | 0.994670 |

| $\alpha_1 = a_5 \cdot T^5 + a_4 \cdot T^4 + a_3 \cdot T^3 + a_2 \cdot T^2 + a_1 \cdot T + a_0$ | | |
|--|-----------------------|-----------------------|
| | α_{1_gross} | α_{1_net} |
| a_5 | -2.19029493602500E-08 | -2.19355532167200E-08 |
| a_4 | 2.61103166728266E-06 | 2.64983756885741E-06 |
| a_3 | -1.08569891311847E-04 | -1.12671200686606E-04 |
| a_2 | 1.99229124621789E-03 | 2.14323578042968E-03 |
| a_1 | -1.51793239517857E-02 | -1.66504876824109E-02 |
| a_0 | 1.01448570822865E+00 | 1.00232233020305E+00 |

| $f_1 = a_5 \cdot T^5 + a_4 \cdot T^4 + a_3 \cdot T^3 + a_2 \cdot T^2 + a_1 \cdot T + a_0$ | | |
|---|-----------------------|-----------------------|
| | f_{1_gross} | f_{1_net} |
| a_5 | 0.00000000000000E+00 | 0.00000000000000E+00 |
| a_4 | 0.00000000000000E+00 | -5.14327357322700E-08 |
| a_3 | -3.35492888465030E-07 | 5.30919215706176E-06 |
| a_2 | 3.18056952820483E-05 | -1.73712915403203E-04 |
| a_1 | -8.71654947965975E-04 | 1.26412135438847E-03 |
| a_0 | 1.00628748144724E+00 | 1.01679435178925E+00 |



Signature

Signature

10.1.2.2 Correction in Power Output and Heat Rate due to Variation in Ambient Pressure

| | | | | |
|---|---|------------------|-------------------|---|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's partial load @ 100% GTGs load Document Name - Liquid fuel operation - Ambient air pressure correction factors for complete CCPP | Project Ref. No. | IE/KE/01/2021 | IEI ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | L_1_02_a_20210304 | |
| | | Revision date | March, 4th, 2021 | |

Table L.1.2.a: Ambient air pressure correction factors

| Calculation point No. | Ambient pressure p [bar(a)] | Power correction | | Heat rate correction | |
|-----------------------|-----------------------------------|---------------------|-------------------|----------------------|--------------|
| | | GROSS | NET | GROSS | NET |
| | | α_{2_gross} | α_{2_net} | f_{2_gross} | f_{2_net} |
| 1 | 1,001300 | 1,011818 | 1,012257 | 1,001081 | 1,000647 |
| 2 | 1,003690 | 1,009608 | 1,009971 | 1,000730 | 1,000370 |
| 3 | 1,006080 | 1,007326 | 1,007600 | 1,000506 | 1,000234 |
| 4 | 1,008460 | 1,004968 | 1,005153 | 1,000391 | 1,000207 |
| 5 | 1,010860 | 1,002506 | 1,002603 | 1,000329 | 1,000232 |
| 6 | 1,013250 | 1,000000 | 1,000000 | 1,000000 | 1,000000 |
| 7 | 1,015670 | 0,997886 | 0,997815 | 1,000140 | 1,000211 |
| 8 | 1,018070 | 0,996206 | 0,995998 | 1,000014 | 1,000223 |
| 9 | 1,020490 | 0,994086 | 0,993803 | 0,999775 | 1,000060 |
| 10 | 1,022910 | 0,991581 | 0,991207 | 1,000043 | 1,000420 |
| 11 | 1,025330 | 0,989059 | 0,988599 | 0,999892 | 1,000358 |

| $\alpha_2 = a_1 \cdot p + a_0$ | | |
|--------------------------------|-----------------------|-----------------------|
| | α_{2_gross} | α_{2_net} |
| a_1 | -9,37414223132511E-01 | -9,75492492468236E-01 |
| a_0 | 1,95032429290931E+00 | 1,98890484337744E+00 |

| $f_2 = a_3 \cdot p^3 + a_2 \cdot p^2 + a_1 \cdot p + a_0$ | | |
|---|-----------------------|-----------------------|
| | f_{2_gross} | f_{2_net} |
| a_3 | -5,97519838884472E+01 | -7,44647322595119E+01 |
| a_2 | 1,84142577174387E+02 | 2,28981023835260E+02 |
| a_1 | -1,89166073584579E+02 | -2,34675945982958E+02 |
| a_0 | 6,57766955407062E+01 | 8,11603973856333E+01 |

10.1.2.3 Correction in Power Output and Heat Rate due to Variation in Relative Humidity

| | | | | |
|---|--|----------------|-------------------|---|
| K-Electric Limited 348 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's base load @ 100% GTGs load Document Name - Liquid fuel operation - Ambient air RH correction factors for complete CCGP | Project Ref. # | IEEKE-01/2021 | IEI ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | L_I_03_a_20210304 | |
| | | Revision date | March, 4th, 2021 | |

Table L.I.3.a: Ambient air RH correction factors

| Calculation point No. | Ambient air RH | Power correction | | Heat rate correction | |
|-----------------------|----------------|---------------------|-------------------|----------------------|--------------|
| | RH | GROSS | NET | GROSS | NET |
| | RH | α_{3_gross} | α_{3_net} | f_{3_gross} | f_{3_net} |
| | [%] | [-] | [-] | [-] | [-] |
| 1 | 30,0 | 0,986219 | 0,980388 | 1,000322 | 1,006272 |
| 2 | 40,0 | 0,986397 | 0,983009 | 1,000541 | 1,003989 |
| 3 | 50,0 | 0,986397 | 0,985739 | 1,000541 | 1,001209 |
| 4 | 60,0 | 1,000000 | 1,000000 | 1,000000 | 1,000000 |
| 5 | 70,0 | 1,015958 | 1,016663 | 1,000211 | 0,999519 |
| 6 | 80,0 | 1,031433 | 1,032856 | 1,000558 | 0,999180 |
| 7 | 90,0 | 1,045979 | 1,048055 | 1,000662 | 0,998679 |
| 8 | 98,0 | 1,057464 | 1,060045 | 1,000866 | 0,998429 |

| $\alpha_3 = a_5 \cdot RH^5 + a_4 \cdot RH^4 + a_3 \cdot RH^3 + a_2 \cdot RH^2 + a_1 \cdot RH + a_0$ | | |
|---|-----------------------|-----------------------|
| | α_{3_gross} | α_{3_net} |
| a_5 | 5,40216353080000E-10 | 4,68066617610000E-10 |
| a_4 | -1,74838074602610E-07 | -1,51658805368810E-07 |
| a_3 | 2,14490392520913E-05 | 1,86199979326656E-05 |
| a_2 | -1,22084964486924E-03 | -1,06013108373858E-03 |
| a_1 | 3,24103214464465E-02 | 2,83958570369210E-02 |
| a_0 | 6,62175212221873E-01 | 6,91465933908302E-01 |

| $f_3 = a_3 \cdot RH^3 + a_2 \cdot RH^2 + a_1 \cdot RH + a_0$ | | |
|--|-----------------------|-----------------------|
| | f_{3_gross} | f_{3_net} |
| a_3 | 8,67866330038000E-09 | -3,34181558894500E-08 |
| a_2 | -1,33523184700718E-06 | 8,67328063769478E-06 |
| a_1 | 6,20346231394271E-05 | -7,78544614477918E-04 |
| a_0 | 9,99514078188305E-01 | 1,02290459588554E+00 |

10.1.2.4 Correction in Power Output due to Variation in Cooling Water Temperature

| | | | | |
|---|--|-----------------|-------------------|---|
| K-Electric Limited 348 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's base load @ 100% GTGs load - Liquid fuel operation - Condenser cooling water temperature correction factors for complete CCPP | Project Ref. N° | E/KE/01/2021 | IEI ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | L_I_09_a_20210304 | |
| | | Revision date | March, 4th, 2021 | |

Table L.I.9.a.: Condenser cooling water temperature additive correction factor

| Calculation point No. | Condenser cooling temperature | Power correction | |
|-----------------------|-------------------------------|----------------------|--------------------|
| | | GROSS | NET |
| | CT | Δ_{SB_gross} | Δ_{SB_net} |
| | [°C] | [kWt] | [kWt] |
| 1 | 20,0 | -51 | -52 |
| 2 | 22,5 | -105 | -105 |
| 3 | 25,0 | 0 | 0 |
| 4 | 27,5 | 299 | 299 |
| 5 | 30,0 | 762 | 760 |
| 6 | 32,5 | 1 332 | 1 328 |
| 7 | 35,0 | 1 951 | 1 944 |
| 8 | 37,5 | 2 609 | 2 599 |

| $\Delta_{SB} = a_3 \cdot CT^3 + a_2 \cdot CT^2 + a_1 \cdot CT + a_0$ | | |
|--|-----------------------|-----------------------|
| | Δ_{SB_gross} | Δ_{SB_net} |
| a_3 | -3,83916931119018E-01 | -3,82061294791100E-01 |
| a_2 | 4,30761619024974E+01 | 4,28698026284077E+01 |
| a_1 | -1,34417516522383E+03 | -1,33755002299643E+03 |
| a_0 | 1,26836477819173E+04 | 1,26180484721145E+04 |

(Signature)

(Signature)

10.1.3 Gas Fuel Correction Curves (Simple Cycle Base Load)

10.1.3.1 Correction in Power Output and Heat Rate due to Variation in Ambient Temperature


| | | | | |
|---|---|------------------|------------------|--|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Document Name Ambient air temperature correction factors for Simple Cycle Plant | Project Ref. No. | IESKE/01/2018 |  ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | L_01_d_20180905 | |
| | | Revision date | Sept. 05th, 2018 | |

Table I.1.d: Ambient air temperature correction factors

| Calculation point No. | Ambient temperature T [°C] | Plant power | | Plant heat rate | | Power correction | | Heat rate correction | |
|-----------------------|----------------------------------|-------------------|-----------------|----------------------|--------------------|----------------------------|--------------------------|-----------------------|---------------------|
| | | GROSS | NET | GROSS | NET | GROSS | NET | GROSS | NET |
| | | PWR_gross [kW] | PWR_net [kW] | HR_gross [kJ/kWh] | HR_net [kJ/kWh] | α_{1_gross} [-] | α_{1_net} [-] | f_{1_gross} [-] | f_{1_net} [-] |
| 1 | 5.0 | 199 244 | 187 472 | 8 854.0 | 9 410.0 | 0.971051 | 0.950010 | 1.006438 | 1.028729 |
| 2 | 10.0 | 199 244 | 187 472 | 8 882.0 | 9 439.7 | 0.971051 | 0.950010 | 1.003265 | 1.025485 |
| 3 | 15.0 | 196 884 | 183 947 | 8 894.0 | 9 519.5 | 0.982690 | 0.968216 | 1.001911 | 1.016890 |
| 4 | 20.0 | 196 628 | 183 090 | 8 890.0 | 9 547.4 | 0.983970 | 0.972748 | 1.002362 | 1.013926 |
| 5 | 25.0 | 196 628 | 182 062 | 8 890.0 | 9 601.3 | 0.983970 | 0.978240 | 1.002362 | 1.008233 |
| 6 | 30.0 | 193 476 | 178 100 | 8 911.0 | 9 680.3 | 1.000000 | 1.000000 | 1.000000 | 1.000000 |
| 7 | 35.0 | 184 540 | 169 200 | 8 974.0 | 9 787.6 | 1.048423 | 1.052601 | 0.992980 | 0.989038 |
| 8 | 40.0 | 175 808 | 160 519 | 9 037.0 | 9 897.8 | 1.100496 | 1.109527 | 0.986057 | 0.978031 |
| 9 | 45.0 | 166 324 | 151 089 | 9 126.0 | 10 046.2 | 1.163248 | 1.178771 | 0.976441 | 0.963582 |

| $\alpha_1 = a_5 \cdot T^5 + a_4 \cdot T^4 + a_3 \cdot T^3 + a_2 \cdot T^2 + a_1 \cdot T + a_0$ | | |
|--|-----------------------|-----------------------|
| | α_{1_gross} | α_{1_net} |
| a_5 | -2.54264436771000E-08 | -2.63415824847100E-08 |
| a_4 | 2.99305243820256E-06 | 3.14863973959785E-06 |
| a_3 | -1.22031738604847E-04 | -1.31483936430805E-04 |
| a_2 | 2.17676912516892E-03 | 2.44308265230591E-03 |
| a_1 | -1.59103261334855E-02 | -1.83268614117634E-02 |
| a_0 | 1.00913312822551E+00 | 9.94437531406767E-01 |

| $f_1 = a_6 \cdot T^6 + a_5 \cdot T^5 + a_4 \cdot T^4 + a_3 \cdot T^3 + a_2 \cdot T^2 + a_1 \cdot T + a_0$ | | |
|---|-----------------------|-----------------------|
| | f_{1_gross} | f_{1_net} |
| a_6 | 2.53009706003000E-09 | 1.26265382796000E-09 |
| a_5 | -3.03750756038540E-07 | -1.09109167004440E-07 |
| a_4 | 1.26390495741146E-05 | 1.27868134011668E-06 |
| a_3 | -2.37014770220216E-04 | 6.99545321816160E-05 |
| a_2 | 9.29594930171786E-04 | -1.79664691001207E-03 |
| a_1 | 1.02886638759266E+00 | 1.01364735740421E+00 |
| a_0 | | |



(Signature)

(Signature)

10.1.3.2 Correction in Power Output and Heat Rate due to Variation in Ambient Pressure

| | | | | |
|---|--|-----------------|-----------------|---|
| K-Electric Limited 348 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's base load @ 100% GTGs load Document Name Ambient air pressure correction factors for Simple Cycle Plant | Project Ref. N° | IEKE/01/2018 | IEI ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | L_02_d_20180905 | |
| | | Revision date | Sept. 5th, 2018 | |

Table I.2.d: Ambient air pressure correction factors

| Calculation point No. | Ambient pressure p [bar(a)] | Plant power | | Plant heat rate | | Power correction | | Heat rate correction | |
|-----------------------|-----------------------------------|---------------------------------|-------------------------------|----------------------|--------------------|-----------------------------|---------------------------|-----------------------------|---------------------------|
| | | GROSS | NET | GROSS | NET | GROSS | NET | GROSS | NET |
| | | PWR_gross [kW _e] | PWR_net [kW _e] | HR_gross [kJ/kWh] | HR_net [kJ/kWh] | a _{2_gross} [-] | a _{2_net} [-] | f _{2_gross} [-] | f _{2_net} [-] |
| 1 | 1.001300 | 191 172 | 175 802 | 8 912.0 | 9 691.2 | 1.012052 | 1.013071 | 0.999888 | 0.998882 |
| 2 | 1.003690 | 191 660 | 176 285 | 8 911.0 | 9 688.2 | 1.009475 | 1.010298 | 1.000000 | 0.999195 |
| 3 | 1.006080 | 192 140 | 176 761 | 8 911.0 | 9 686.3 | 1.006953 | 1.007577 | 1.000000 | 0.999381 |
| 4 | 1.008460 | 192 620 | 177 235 | 8 910.0 | 9 683.4 | 1.004444 | 1.004878 | 1.000112 | 0.999580 |
| 5 | 1.010860 | 193 116 | 177 727 | 8 910.0 | 9 681.5 | 1.001864 | 1.002096 | 1.000112 | 0.999881 |
| 6 | 1.013250 | 193 476 | 178 100 | 8 911.0 | 9 680.3 | 1.000000 | 1.000000 | 1.000000 | 1.000000 |
| 7 | 1.015670 | 193 948 | 178 568 | 8 910.0 | 9 677.4 | 0.997566 | 0.997378 | 1.000112 | 1.000302 |
| 8 | 1.018070 | 194 416 | 179 031 | 8 910.0 | 9 675.7 | 0.995165 | 0.994801 | 1.000112 | 1.000478 |
| 9 | 1.020490 | 194 860 | 179 471 | 8 911.0 | 9 675.1 | 0.992897 | 0.992360 | 1.000000 | 1.000541 |
| 10 | 1.022910 | 195 324 | 179 931 | 8 911.0 | 9 673.3 | 0.990539 | 0.989823 | 1.000000 | 1.000724 |
| 11 | 1.025330 | 195 820 | 180 422 | 8 911.0 | 9 671.5 | 0.988030 | 0.987131 | 1.000000 | 1.000911 |

| $a_2 = a_1 \cdot p + a_0$ | | |
|---------------------------|-----------------------|-----------------------|
| | a _{2_gross} | a _{2_net} |
| a ₁ | -9.87055823765579E-01 | -1.06745559042834E+00 |
| a ₀ | 2.00007443046891E+00 | 2.08158094545306E+00 |

| $f_2 = a_3 \cdot p^3 + a_2 \cdot p^2 + a_1 \cdot p + a_0$ | | |
|---|-----------------------|-----------------------|
| | f _{2_gross} | f _{2_net} |
| a ₃ | 4.77581346482038E+01 | 2.68567506894469E+01 |
| a ₂ | -1.46200512630419E+02 | -8.29221127896950E+01 |
| a ₁ | 1.49176329846985E+02 | 8.54020019597167E+01 |
| a ₀ | -4.97341182806908E+01 | -2.83379177725270E+01 |



Handwritten signature

Handwritten signature

10.1.3.3 Correction in Power Output and Heat Rate due to Variation in Relative Humidity


| | | | | |
|---|--|-----------------|-----------------|--|
| K-Electric Limited 248 MW Combined Cycle Power Plant Korangi Creek, Karachi Pakistan | Correction curves for Plant's base load @ 100% GTGs load Document Name Ambient air RH correction factors for Simple Cycle Plant | Project Ref. N° | IE/KE/01/2018 |  ISTROENERGO INTERNATIONAL, s.r.l. |
| | | File Name | I_03_d_20180805 | |
| | | Revision date | Sept. 5th, 2018 | |

Table I.3.d: Ambient air RH correction factors

| Calculation point No. | Ambient air RH [%] | Plant power | | Plant heat rate | | Power correction | | Heat rate correction | |
|-----------------------|--------------------|-------------|---------|-----------------|----------|---------------------|-------------------|----------------------|--------------|
| | | GROSS | NET | GROSS | NET | GROSS | NET | GROSS | NET |
| | | PWR_gross | PWR_net | HR_gross | HR_net | α_{3_gross} | α_{3_net} | f_{3_gross} | f_{3_net} |
| | | [kWe] | [kWe] | [kJ/kWh] | [kJ/kWh] | [-] | [-] | [-] | [-] |
| 1 | 30.0 | 196 712 | 182 531 | 8 891.0 | 9 581.8 | 0.983550 | 0.975726 | 1.002249 | 1.010288 |
| 2 | 40.0 | 196 628 | 181 872 | 8 890.0 | 9 611.3 | 0.983970 | 0.979259 | 1.002362 | 1.007184 |
| 3 | 50.0 | 196 628 | 181 239 | 8 890.0 | 9 644.8 | 0.983970 | 0.982680 | 1.002362 | 1.003678 |
| 4 | 60.0 | 193 476 | 178 100 | 8 911.0 | 9 680.3 | 1.000000 | 1.000000 | 1.000000 | 1.000000 |
| 5 | 70.0 | 189 972 | 174 614 | 8 935.0 | 9 720.9 | 1.018445 | 1.019962 | 0.997314 | 0.995830 |
| 6 | 80.0 | 186 600 | 171 257 | 8 959.0 | 9 761.7 | 1.036849 | 1.039960 | 0.994842 | 0.991667 |
| 7 | 90.0 | 183 620 | 168 276 | 8 981.0 | 9 799.9 | 1.053676 | 1.058377 | 0.992206 | 0.987799 |
| 8 | 98.0 | 181 212 | 165 889 | 8 998.0 | 9 829.1 | 1.067678 | 1.073608 | 0.990331 | 0.984860 |

| $\alpha_3 = a_5 \cdot RH^5 + a_4 \cdot RH^4 + a_3 \cdot RH^3 + a_2 \cdot RH^2 + a_1 \cdot RH + a_0$ | | |
|---|-----------------------|-----------------------|
| | α_{3_gross} | α_{3_net} |
| a_5 | 6.53141323590000E-10 | 5.78751508620000E-10 |
| a_4 | -2.11080327651910E-07 | -1.87377870225500E-07 |
| a_3 | 2.58824646677472E-05 | 2.30158291629829E-05 |
| a_2 | -1.47472899841465E-03 | -1.31324956495791E-03 |
| a_1 | 3.92506762640003E-02 | 3.53163401949772E-02 |
| a_0 | 5.89714163614029E-01 | 6.14567602715647E-01 |

| $f_3 = a_3 \cdot RH^3 + a_2 \cdot RH^2 + a_1 \cdot RH + a_0$ | | |
|--|-----------------------|-----------------------|
| | f_{3_gross} | f_{3_net} |
| a_3 | 6.88485077375800E-08 | 2.67008184336400E-08 |
| a_2 | -1.56424015200283E-06 | -5.74840628943902E-06 |
| a_1 | 9.03838841910338E-04 | 3.19277808219585E-06 |
| a_0 | 9.87237138893077E-01 | 1.01460675697523E+00 |



Handwritten signature

Handwritten signature