

- i) Whether EPC bidding process has been conducted in a transparent manner and justifiable?
- ii) Whether the cost of project of US\$. 32.363 million on given technology is justified?
- iii) Whether the average annual load factor of 66.25% based on the (70% of 10MW WHRSG and 60% of 6MW WHRSG)
- iv) Whether the power purchaser agrees with the cost and specification of the proposed interconnection line?
- v) Whether the arrangements of take & pay basis is reasonable and justifiable?
- vi) Whether increase in construction period from 9 months claimed by the petitioner is justified?
- vii) Whether the proposed gross capacity (92.856GWh) and annual net energy generation for sale (87.433 Gwh) claimed by the petitioner are justified?
- viii) Whether O & M cost of Rs. 2.53/KWhr claimed by the petitioner is justified?
- ix) Whether insurance during construction claimed @ 0.66% of EPC cost is justifiable?
- x) Whether insurance during operation claimed @ 3% of project capital expenditures is justifiable?
- xi) Whether claimed return on equity @ 21.50% (20% IRR based) is justified?
- xii) Any other issue with the approval of the Authority.